

YUANLING, China

WMO: 576550

Lat: 28.4634N

Lon: 110.4032E

Elev: 143

StdP: 99.62

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.7	0.4	-9.1	1.8	4.9	-6.9	2.1	4.9	5.4	5.9	4.6	5.7	1.5	40	0.331

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	35.9	25.4	34.7	25.5	33.6	25.3	27.2	32.1	26.7	31.6	26.3	31.0	2.5	220

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.8	29.4	25.6	21.1	29.0	25.1	20.6	28.6	87.6	32.3	85.2	31.7	83.1	31.4	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.9	4.2	3.6	DB	-2.1	37.8	1.4	1.0	-3.1	38.5	-3.9	39.1	-4.7	39.7	-5.7	40.4	(4)
			WB	-3.1	28.2	1.2	0.7	-4.0	28.7	-4.7	29.1	-5.4	29.5	-6.3	30.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	5.8	8.0	12.3	17.7	22.0	25.4	28.5	28.3	24.5	19.0	13.5	8.2
	DBStd	8.44	3.30	3.86	4.05	3.79	2.93	2.65	2.37	2.67	3.36	3.32	3.57	2.85
	HDD10.0	315	133	78	22	1	0	0	0	0	0	0	11	69
	HDD18.3	1424	387	291	191	55	4	0	0	2	32	147	315	
	CDD10.0	3167	4	21	93	233	372	461	573	568	434	279	116	13
	CDD18.3	1236	0	1	4	37	119	211	315	309	185	52	3	0
	CDH23.3	11635	0	4	38	256	742	1740	3606	3487	1494	256	12	0
	CDH26.7	4898	0	1	9	68	244	650	1680	1609	578	59	1	0
Wind	WSAvg	1.5	1.6	1.6	1.5	1.5	1.4	1.3	1.5	1.6	1.6	1.5	1.5	1.5
Precipitation	PrecAvg	1422	38	56	96	190	219	251	165	113	85	101	70	37
	PrecMax	2005	93	105	250	382	465	504	435	369	213	240	172	129
	PrecMin	1065	2	3	37	38	112	60	32	12	5	1	4	1
	PrecStd	223	21	30	50	83	84	109	102	95	62	59	44	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	22.7	27.4	31.2	33.4	35.1	37.3	37.7	35.7	30.9	25.0	18.3
		MCWB	10.4	14.8	18.7	21.7	23.1	25.4	25.5	25.1	24.2	20.7	17.1	11.1
	2%	DB	14.4	18.4	23.5	28.7	31.3	33.4	35.9	36.1	33.7	28.2	22.7	16.1
		MCWB	8.7	12.0	15.7	20.1	22.3	25.0	25.7	25.4	24.0	19.5	15.9	10.3
	5%	DB	12.3	15.6	21.0	26.4	29.4	32.0	34.7	34.8	31.9	26.2	20.7	14.1
		MCWB	8.0	10.6	14.6	19.2	21.9	24.7	25.8	25.7	23.8	18.8	14.9	9.5
	10%	DB	10.7	13.5	18.4	24.0	27.5	30.4	33.5	33.4	30.1	24.2	18.7	12.5
		MCWB	7.2	9.5	13.6	18.3	21.5	24.3	25.8	25.4	22.7	18.4	14.2	8.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	16.1	20.5	23.6	25.6	27.1	28.0	27.9	26.5	23.6	18.8	13.0
		MCDB	14.5	22.3	26.2	29.3	30.7	31.6	32.7	33.0	31.3	27.8	22.2	16.1
	2%	WB	9.9	13.0	17.4	21.8	24.3	26.2	27.3	27.2	25.7	21.5	17.2	11.4
		MCDB	12.9	16.7	21.6	26.5	28.7	30.9	32.2	32.2	30.8	25.1	20.8	14.5
	5%	WB	8.7	11.4	15.6	20.3	23.2	25.7	26.8	26.7	25.1	20.2	16.0	10.2
		MCDB	11.6	14.5	19.3	24.3	26.9	30.0	31.7	31.6	29.6	24.0	19.2	13.2
	10%	WB	7.4	10.0	14.2	19.0	22.2	25.1	26.4	26.2	24.2	19.3	14.8	9.1
		MCDB	10.3	13.2	17.5	22.8	25.8	29.0	31.2	30.9	28.6	22.9	17.7	12.0
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.1	7.2	8.0	7.8	7.0	7.9	7.8	7.6	6.6	6.4	5.7
		MCDBR	10.0	12.0	13.4	13.4	12.5	10.4	10.3	10.2	10.7	10.8	10.4	10.3
		MCWBR	5.2	5.9	6.0	5.2	4.3	3.2	2.2	2.2	2.8	3.4	4.3	5.1
	5% WB	MCDDBR	8.4	10.0	10.7	10.9	9.5	8.3	9.0	8.6	9.0	8.0	8.3	8.8
MCWBR		4.8	5.6	5.9	5.3	4.0	3.1	2.7	2.6	2.9	3.4	4.1	4.9	
Clear-Sky Solar Irradiance	taub	0.719	0.758	0.801	0.775	0.688	0.679	0.601	0.683	0.721	0.767	0.726	0.707	
	taud	1.436	1.404	1.376	1.458	1.644	1.686	1.883	1.674	1.575	1.443	1.482	1.468	
	Ebn at Noon	519	550	567	607	667	670	723	660	612	536	511	500	
	Edh at Noon	270	300	326	308	257	245	200	245	263	284	255	251	
All-Sky Solar Radiation	RadAvg	1.59	1.88	2.63	3.21	3.57	3.80	4.87	4.43	3.56	2.61	2.16	1.70	
	RadStd	0.34	0.51	0.28	0.47	0.65	0.56	0.48	0.42	0.42	0.44	0.40	0.36	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	-0.45	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	+0.46	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page