

BIJIE, China

WMO: 577070

Lat: 27.2975N

Lon: 105.2885E

Elev: 1511

StdP: 84.44

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.7	-1.7	-5.5	2.9	0.3	-4.1	3.2	0.4	4.0	7.9	3.4	7.1	0.8	110	0.345

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	30.0	20.5	28.8	20.2	27.7	19.9	22.1	27.5	21.6	26.6	21.1	25.8	2.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.7	18.5	24.1	20.2	17.9	23.7	19.7	17.4	23.3	73.4	27.8	71.2	26.8	69.2	25.9	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.2	3.4	3.1	-4.0	32.2	1.4	1.0	-5.0	32.9	-5.8	33.6	-6.5	34.1	-7.5	34.9		
			-4.8	23.3	1.4	0.6	-5.8	23.7	-6.6	24.1	-7.4	24.4	-8.4	24.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.0	3.4	6.0	10.2	15.2	18.0	20.3	22.6	22.1	19.2	14.6	10.4	5.1	(6)
(7)		DBStd	7.35	3.51	4.70	4.58	4.20	3.17	2.61	2.03	2.20	3.13	3.27	3.64	3.03	(7)
(8)		HDD10.0	595	205	131	55	7	0	0	0	0	2	39	156		(8)
(9)		HDD18.3	2029	462	347	253	111	44	10	1	2	27	123	238	411	(9)
(10)		CDD10.0	2044	2	18	62	162	249	308	391	375	276	146	51	3	(10)
(11)		CDD18.3	435	0	0	2	16	35	68	133	118	53	8	0	0	(11)
(12)		CDH23.3	2395	1	9	36	127	214	326	717	644	286	36	2	0	(12)
(13)		CDH26.7	491	0	1	7	22	43	59	155	151	51	3	0	0	(13)
(14)	Wind	WSAvg	1.1	0.9	1.0	1.2	1.3	1.2	1.0	1.1	1.1	0.9	0.9	0.9	(14)	
(15)	Precipitation	PrecAvg	882	16	15	24	58	120	147	147	150	112	59	31	16	(15)
(16)		PrecMax	1155	33	30	54	176	293	290	309	353	196	109	70	36	(16)
(17)		PrecMin	617	5	5	9	16	39	62	27	43	40	22	8	4	(17)
(18)		PrecStd	125	7	6	12	33	58	51	64	68	44	22	18	8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.7	24.6	27.3	29.2	30.1	30.3	31.1	31.3	30.2	26.8	22.4	17.6	(19)
(20)		0.4%	MCWB	10.5	11.7	13.7	16.7	18.6	21.0	21.3	20.9	20.9	18.5	14.6	10.7	(20)
(21)		2%	DB	13.4	19.9	23.4	26.7	27.8	28.3	29.6	29.8	28.1	24.2	19.8	13.9	(21)
(22)		2%	MCWB	8.3	11.3	14.1	16.7	18.5	20.6	21.2	20.7	19.9	17.2	13.8	9.1	(22)
(23)		5%	DB	10.6	16.0	20.2	24.5	25.8	26.8	28.4	28.4	26.5	21.9	17.8	11.2	(23)
(24)		5%	MCWB	6.9	10.2	13.2	16.2	17.9	19.9	21.0	20.5	19.3	16.7	12.9	7.8	(24)
(25)		10%	DB	8.0	12.2	17.2	22.0	23.9	25.2	27.2	27.0	24.9	19.7	15.6	9.1	(25)
(26)		10%	MCWB	5.6	8.5	12.0	15.5	17.4	19.6	20.7	20.3	18.6	15.8	12.2	6.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	13.1	15.7	19.0	21.2	22.5	23.0	22.6	21.5	19.3	15.6	11.1	(27)
(28)		0.4%	MCDWB	16.7	20.9	23.4	25.5	26.8	27.7	28.1	28.6	28.1	24.7	19.5	16.1	(28)
(29)		2%	WB	8.6	11.6	14.5	17.9	19.9	21.7	22.2	21.7	20.7	18.2	14.4	9.6	(29)
(30)		2%	MCDWB	13.1	18.6	21.3	24.0	24.9	26.4	27.4	27.3	26.4	22.6	18.7	13.0	(30)
(31)		5%	WB	7.2	10.2	13.5	17.0	19.1	21.1	21.7	21.2	20.1	17.2	13.4	8.3	(31)
(32)		5%	MCDWB	10.0	15.7	19.1	22.5	23.6	25.1	26.7	26.4	25.0	20.7	17.0	10.8	(32)
(33)		10%	WB	5.8	8.7	12.3	16.0	18.2	20.4	21.2	20.7	19.4	16.2	12.5	6.9	(33)
(34)		10%	MCDWB	7.8	12.2	16.9	20.8	22.5	23.9	25.6	25.4	23.5	19.3	15.2	8.9	(34)
(35)	Mean Daily Temperature Range		MDBR	5.0	6.3	7.6	8.2	8.0	6.9	7.7	8.0	7.5	5.9	6.2	5.1	(35)
(36)		5% DB	MCDDBR	11.4	14.7	14.3	13.1	12.1	10.4	10.0	10.8	10.6	10.7	10.8	11.0	(36)
(37)			MCWBR	6.6	6.9	6.0	5.1	4.8	4.1	3.3	3.5	3.7	4.6	5.2	6.4	(37)
(38)			MCDDBR	10.7	13.6	12.6	11.0	9.7	8.2	8.7	9.2	9.1	9.2	9.4	10.1	(38)
(39)		5% WB	MCWBR	6.4	6.6	5.6	4.8	4.5	3.8	3.4	3.5	3.4	4.4	4.7	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.518	0.542	0.655	0.631	0.555	0.531	0.504	0.534	0.531	0.580	0.563	0.551	(40)	
(41)		taud	1.761	1.731	1.540	1.631	1.858	1.969	2.058	1.950	1.925	1.730	1.696	1.683	(41)	
(42)		Ebn at Noon	697	724	670	707	764	778	798	772	760	682	649	639	(42)	
(43)		Edh at Noon	195	217	278	260	207	184	168	187	186	214	207	203	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.75	2.54	3.21	3.97	4.12	3.75	4.90	4.49	3.59	2.36	2.23	1.61	(44)	
(45)		RadStd	0.41	0.53	0.45	0.56	0.58	0.71	0.44	0.51	0.53	0.46	0.29	0.36	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	+0.64	N/A	N/A	N/A	N/A	+109	+39

Nomenclature: See separate page