

HUICHUAN, China

WMO: 577120

Lat: 27.7266N

Lon: 106.9467E

Elev: 3228

StdP: 13.06

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.1	33.0	22.9	19.5	37.2	25.7	22.2	37.7	9.4	47.1	8.0	44.3	2.1	20	0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	90.8	72.9	88.8	72.6	86.9	72.1	75.6	85.4	74.8	84.1	74.1	83.0	5.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.1	138.7	80.0	72.4	135.3	79.2	71.7	132.0	78.3	41.9	85.7	41.0	84.4	40.3	83.4	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.0	8.6	7.4	DB	28.3	95.1	2.2	1.9	26.7	96.4	25.4	97.5	24.2	98.6	22.7	100.0
			WB	26.6	77.4	2.6	1.4	24.8	78.4	23.3	79.3	21.8	80.1	20.0	81.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	41.6	45.2	52.7	62.7	68.7	73.7	78.6	71.9	62.7	54.1	45.0
		DBStd	13.97	5.50	7.23	7.74	7.50	5.19	4.67	3.56	4.32	5.76	5.11	5.13
		HDD50	698	269	169	57	4	0	0	0	0	0	29	170
		HDD65	2891	727	556	391	131	22	1	0	10	104	329	620
		CDD50	4827	7	34	140	384	579	711	887	865	658	395	152
		CDD65	1546	0	1	9	62	136	262	422	400	217	34	0
		CDH74	11378	0	10	72	386	790	1620	3557	3315	1491	128	9
		CDH80	3610	0	2	17	83	188	427	1216	1201	452	24	0
(14)	Wind	WSAvg	2.7	2.5	2.8	2.9	3.2	3.0	2.6	3.0	2.8	2.7	2.2	2.2
(15)	Precipitation	PrecAvg	41.8	1.1	1.0	1.5	3.3	5.8	8.1	6.8	4.4	3.1	4.0	1.7
		PrecMax	51.3	1.9	2.0	3.0	5.1	10.0	16.6	16.7	9.0	5.3	7.2	3.7
		PrecMin	28.9	0.5	0.1	0.6	1.4	3.4	2.7	1.9	1.1	1.5	0.3	0.4
		PrecStd	5.8	0.4	0.6	0.6	1.1	1.7	3.5	3.8	2.5	1.2	1.5	0.8
		PrecStd	5.8	0.4	0.6	0.6	1.1	1.7	3.5	3.8	2.5	1.2	1.5	0.8
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	62.5	74.0	81.9	86.4	88.0	89.7	92.7	93.8	92.0	83.7	74.7	63.8
		0.4% MCWB	51.4	57.5	63.2	66.8	68.4	72.9	73.1	72.2	70.8	69.0	61.9	54.7
		2% DB	56.4	64.6	74.3	82.4	84.9	87.1	90.4	90.9	87.9	77.8	70.3	59.0
		2% MCWB	48.9	55.5	61.6	66.4	67.9	72.5	73.6	73.3	69.6	65.3	59.0	51.3
		5% DB	51.9	59.0	68.8	78.6	81.7	84.7	88.2	88.9	85.1	73.8	66.7	55.3
		5% MCWB	46.7	51.7	58.5	65.3	67.3	72.1	73.6	73.0	70.0	63.9	58.1	49.1
		10% DB	49.1	54.8	64.3	74.7	78.7	82.2	86.3	86.6	82.2	70.9	63.4	52.5
		10% MCWB	45.3	49.7	56.8	63.8	66.8	71.7	73.3	72.7	68.9	63.2	57.3	47.5
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	53.2	58.2	63.9	71.3	73.5	75.9	77.0	76.7	74.6	70.1	63.5	56.1
		0.4% MCDB	62.3	70.2	77.6	81.3	82.2	84.9	87.4	87.6	86.4	80.3	69.9	62.4
		2% WB	49.5	55.5	62.2	68.7	71.5	74.6	75.8	75.5	73.2	68.1	61.7	53.0
		2% MCDB	54.9	64.5	73.0	78.1	79.3	82.8	85.3	86.2	83.2	75.0	67.6	56.9
		5% WB	47.3	52.5	59.9	66.6	69.9	73.7	75.0	74.6	72.0	66.2	59.7	50.0
		5% MCDB	51.4	57.8	67.9	75.7	78.1	81.3	83.9	84.5	80.8	70.9	64.6	53.8
		10% WB	45.8	50.1	57.1	64.7	68.3	72.7	74.3	73.7	70.8	64.2	57.9	47.7
		10% MCDB	49.2	54.4	63.7	73.0	75.1	79.7	83.0	82.7	78.9	69.0	63.0	51.9
(35)	Mean Daily Temperature Range	MDBR	7.3	8.5	11.4	13.2	12.7	11.2	12.7	13.5	13.6	9.4	9.7	8.4
		5% DB	16.2	19.1	21.6	21.5	20.5	16.5	16.6	18.2	19.4	17.2	18.1	17.1
		5% WB	9.8	10.1	9.5	8.0	7.2	5.2	4.4	4.4	5.4	6.9	8.2	9.6
		5% DB	15.1	17.4	20.6	18.3	14.7	12.5	13.7	14.9	14.6	12.4	12.8	13.2
		5% WB	9.3	9.2	9.3	7.8	7.2	4.8	4.4	4.4	5.0	6.4	6.7	8.0
(40)	Clear-Sky Solar Irradiance	taub	0.637	0.650	0.723	0.691	0.596	0.571	0.523	0.565	0.574	0.666	0.670	0.671
		taud	1.527	1.529	1.447	1.546	1.791	1.895	2.040	1.905	1.840	1.577	1.520	1.480
		Ebn at Noon	186	200	197	211	232	237	248	237	229	194	176	168
		Edh at Noon	78	84	96	90	70	63	54	62	64	79	78	79
(44)	All-Sky Solar Radiation	RadAvg	448	630	865	1084	1165	1131	1548	1430	1117	705	608	441
		RadStd	105	134	124	167	207	207	141	162	146	135	110	98

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+1.08	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page