

NANYUE, China

WMO: 577760

Lat: 27.2960N

Lon: 112.6936E

Elev: 4160

StdP: 12.62

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.8	19.4	2.1	7.2	35.8	8.3	9.8	34.8	41.0	48.1	35.7	47.0	10.2	0	0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	79.9	72.2	78.2	71.7	76.6	71.0	73.7	77.6	72.7	76.4	71.9	75.3	6.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.6	141.3	75.8	71.6	136.7	74.9	70.8	132.7	74.0	40.5	77.8	39.6	76.7	38.7	75.4	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.1	33.6	28.2	DB	14.6	83.3	3.4	1.7	12.2	84.5	10.3	85.5	8.4	86.5	5.9	87.7	(4)
(5)			WB	13.5	75.6	3.2	0.8	11.2	76.2	9.4	76.7	7.6	77.1	5.3	77.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	54.3	33.5	37.6	45.1	55.1	62.2	67.6	71.5	70.4	64.6	56.6	48.0	37.8	(6)
(7)		DBStd	14.92	9.54	10.59	9.33	7.68	5.60	4.13	3.60	4.28	6.16	6.66	8.67	8.58	(7)
(8)		HDD50	1672	516	365	207	39	1	0	0	0	1	20	138	385	(8)
(9)		HDD65	4526	977	767	618	302	121	23	4	10	82	268	512	842	(9)
(10)		CDD50	3224	4	19	54	192	378	528	668	634	439	224	77	7	(10)
(11)		CDD65	601	0	0	0	5	33	101	206	178	70	8	0	0	(11)
(12)		CDH74	1091	0	0	0	3	19	83	480	406	93	7	0	0	(12)
(13)		CDH80	44	0	0	0	0	0	1	19	23	1	0	0	0	(13)
(14)	Wind	WSAvg	11.4	10.7	12.0	12.4	13.6	12.0	13.6	15.2	9.8	8.6	8.9	9.8	10.0	(14)
(15)	Precipitation	PrecAvg	78.9	3.3	4.7	6.5	10.0	11.0	9.8	5.7	7.6	6.3	6.5	4.8	2.6	(15)
(16)		PrecMax	116.0	7.6	9.6	10.7	20.7	21.3	20.9	13.4	17.0	24.9	13.8	10.0	6.6	(16)
(17)		PrecMin	58.8	0.5	1.2	3.0	5.4	5.2	2.7	0.6	0.6	0.2	0.1	0.2	0.0	(17)
(18)		PrecStd	14.5	1.7	2.0	1.9	3.2	4.0	4.2	3.4	4.4	5.1	3.4	2.7	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.3	62.9	66.9	73.4	76.2	78.4	82.2	82.5	79.2	74.4	68.5	58.7	(19)
(20)			MCWB	52.0	57.1	59.4	62.8	67.3	71.7	73.1	72.3	71.8	66.1	59.0	51.6	(20)
(21)		2%	DB	54.1	58.7	63.1	69.8	73.8	76.3	80.1	80.0	76.6	70.5	64.5	55.2	(21)
(22)			MCWB	49.7	53.4	57.3	62.9	66.6	70.9	72.4	72.1	70.5	63.7	57.6	48.2	(22)
(23)		5%	DB	51.0	55.7	60.5	67.4	71.6	74.5	78.4	78.1	74.5	67.5	61.8	52.7	(23)
(24)			MCWB	47.0	52.0	56.2	61.8	65.4	69.8	72.0	71.8	69.3	61.7	55.9	46.9	(24)
(25)		10%	DB	48.3	53.2	57.9	65.1	69.7	72.9	76.7	76.3	72.5	65.3	59.3	50.1	(25)
(26)			MCWB	43.9	50.3	54.2	60.7	64.8	69.1	71.3	71.2	68.1	60.2	53.8	44.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	57.8	62.6	67.5	70.9	73.6	75.3	74.7	73.1	68.3	62.9	56.9	(27)
(28)			MCD B	55.4	61.1	65.5	70.0	74.0	76.8	79.0	78.5	76.8	71.8	65.2	57.3	(28)
(29)		2%	WB	51.2	55.2	59.8	65.4	69.3	72.0	73.8	73.6	71.7	65.7	60.6	52.0	(29)
(30)			MCD B	53.1	57.8	61.3	67.9	71.6	74.7	77.8	77.6	75.3	68.3	63.2	53.2	(30)
(31)		5%	WB	48.5	52.9	57.6	63.8	68.0	71.0	72.8	72.7	70.4	63.6	58.1	49.0	(31)
(32)			MCD B	50.6	55.1	59.1	65.7	69.8	73.3	76.7	76.4	73.5	66.1	60.2	51.1	(32)
(33)		10%	WB	44.9	50.9	55.3	62.4	66.6	69.9	71.9	71.7	69.0	61.7	55.3	45.4	(33)
(34)			MCD B	47.3	52.7	57.1	64.0	68.4	71.9	75.5	75.0	71.7	64.2	58.3	48.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.3	8.8	8.9	9.4	8.3	6.6	7.2	7.1	7.9	8.6	9.1	8.9	(35)
(36)			MCDBR	11.3	12.3	11.3	11.9	10.0	8.6	9.5	9.9	9.6	11.0	10.7	11.4	(36)
(37)			MCWBR	8.9	9.3	8.8	8.9	8.0	6.0	5.7	5.9	6.6	8.2	8.0	9.4	(37)
(38)		5% WB	MCD BR	10.8	12.3	10.0	11.0	8.5	7.3	8.4	8.6	9.1	9.6	9.2	10.8	(38)
(39)			MCWBR	9.2	9.8	8.6	8.7	6.8	5.3	5.8	5.9	6.4	7.4	7.6	9.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.542	0.570	0.615	0.595	0.532	0.517	0.471	0.523	0.539	0.572	0.526	0.519	(40)	
(41)		taud	1.705	1.686	1.628	1.726	1.934	2.018	2.169	1.989	1.892	1.725	1.789	1.767	(41)	
(42)		Ebn at Noon	213	222	222	233	248	250	261	248	239	218	217	213	(42)	
(43)		Edh at Noon	66	72	81	75	61	56	48	57	61	68	60	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	524	627	812	1035	1210	1303	1701	1458	1206	959	755	619	(44)	
(45)		RadStd	121	176	107	142	175	167	176	122	131	149	135	146	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	+1.22	+0.52	+0.63	N/A	N/A	N/A	N/A	(46)
(47)	Regional (6 neighbors)	+0.54	N/A	N/A	+0.85	N/A	N/A	N/A	N/A	+259	N/A	(47)

Nomenclature: See separate page