

JI'AN JIANGXI, China

WMO: 577990

Lat: 27.0434N

Lon: 114.9138E

Elev: 256

StdP: 14.56

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.9	33.8	20.4	15.5	41.7	24.3	18.6	41.4	12.4	45.0	11.5	44.0	2.9	0	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	98.1	79.8	96.2	79.7	94.3	79.4	82.3	91.4	81.6	90.5	80.8	89.5	4.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	159.2	85.5	79.6	154.8	85.2	78.8	150.8	84.9	46.5	91.5	45.7	90.4	44.9	89.6	92.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
13.3	11.3	9.6	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			28.8	100.7	2.6	2.1	26.9	102.2	25.4	103.4	23.9	104.6	22.1	106.1
			27.3	84.2	2.4	1.8	25.5	85.5	24.1	86.5	22.8	87.5	21.0	88.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.1	45.0	49.5	56.5	67.6	75.5	80.9	86.6	85.2	79.0	70.1	59.3	48.7	(6)
(7)		DBStd	15.62	6.92	8.93	8.39	7.59	5.40	5.05	4.18	4.34	6.01	5.81	6.92	5.92	(7)
(8)		HDD50	433	189	110	30	1	0	0	0	0	0	0	9	94	(8)
(9)		HDD65	2134	622	441	287	59	2	0	0	0	0	20	196	507	(9)
(10)		CDD50	6666	33	96	231	529	792	927	1133	1092	870	623	287	53	(10)
(11)		CDD65	2892	0	7	24	137	329	477	668	627	420	178	24	1	(11)
(12)		CDH74	30588	2	50	168	903	2505	4908	8948	7850	4090	1032	128	4	(12)
(13)		CDH80	13798	0	4	25	244	819	2025	4803	3897	1696	264	21	0	(13)
(14)	Wind	WSAvg	3.8	3.4	3.8	3.8	4.0	3.7	4.0	4.5	3.9	3.8	3.7	3.3	3.3	(14)
(15)	Precipitation	PrecAvg	63.0	3.1	3.6	7.0	7.9	8.9	10.0	5.4	5.9	3.1	2.4	3.4	2.3	(15)
(16)		PrecMax	84.1	7.7	6.6	18.6	17.8	21.0	18.3	11.9	14.4	6.9	10.3	8.2	8.1	(16)
(17)		PrecMin	37.6	0.4	0.4	3.1	3.0	1.7	4.1	0.7	0.4	0.2	0.0	0.2	0.0	(17)
(18)		PrecStd	12.2	1.5	1.7	3.2	3.0	3.9	3.9	2.8	3.3	2.0	2.4	2.4	2.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.9	79.5	83.6	89.5	93.6	96.6	100.7	100.8	97.3	91.4	83.6	70.6	(19)
(20)		MCWB	61.6	65.4	69.0	72.6	76.3	80.4	79.8	80.0	79.4	74.7	68.7	59.3	(20)	
(21)		2%	DB	64.4	74.4	78.8	85.9	90.5	93.8	98.5	98.1	94.2	86.2	77.7	64.6	(21)
(22)		MCWB	55.8	63.2	66.5	72.3	74.8	79.5	80.0	79.7	78.9	72.3	65.5	55.7	(22)	
(23)		5%	DB	59.3	68.8	74.4	82.7	87.6	91.6	96.7	95.9	91.9	82.7	73.6	61.2	(23)
(24)		MCWB	52.4	60.8	64.7	70.8	74.6	79.0	79.7	79.9	78.5	70.1	63.5	54.1	(24)	
(25)		10%	DB	55.0	62.8	69.6	79.4	84.7	89.3	94.7	93.5	88.9	79.9	69.9	57.9	(25)
(26)		MCWB	49.6	56.7	62.0	69.5	74.2	78.5	79.5	79.8	77.3	68.6	62.3	51.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.0	67.9	72.0	76.2	80.0	82.6	83.2	83.7	81.8	77.5	72.0	63.7	(27)
(28)		MCDWB	68.8	77.0	79.9	84.7	87.9	90.4	93.1	92.6	90.6	85.3	77.5	68.2	(28)	
(29)		2%	WB	57.2	64.1	68.8	74.4	78.5	81.3	82.2	82.4	80.6	75.0	68.6	58.8	(29)
(30)		MCDWB	62.0	72.4	76.0	82.2	85.5	89.0	91.7	91.6	89.4	81.9	73.6	62.6	(30)	
(31)		5%	WB	53.4	61.3	66.4	73.0	77.3	80.4	81.5	81.5	79.7	73.1	66.4	55.2	(31)
(32)		MCDWB	57.8	68.5	72.7	79.9	83.4	87.8	90.9	90.4	87.9	79.8	71.0	59.5	(32)	
(33)		10%	WB	50.0	57.5	63.5	71.4	75.9	79.4	80.8	80.8	78.8	71.3	63.6	52.5	(33)
(34)		MCDWB	53.9	62.0	68.1	77.1	81.6	86.7	90.0	89.3	86.4	77.1	68.4	56.2	(34)	
(35)	Mean Daily Temperature Range		MDBR	9.8	10.9	11.5	12.4	12.5	11.3	13.2	12.9	13.0	13.5	12.6	11.9	(35)
(36)		5% DB	MCDBR	19.3	21.5	20.9	18.4	17.5	14.5	16.0	16.4	16.5	17.9	19.6	19.0	(36)
(37)		MCWBR	10.7	11.2	9.5	7.3	5.9	4.6	4.1	4.2	4.5	6.1	8.1	10.0	(37)	
(38)		5% WB	MCDBR	15.9	19.2	17.8	15.3	13.6	13.0	14.6	15.1	15.0	14.2	14.1	14.4	(38)
(39)		MCWBR	9.6	10.7	10.0	7.3	5.9	5.2	4.7	4.8	4.7	5.9	7.5	8.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.677	0.719	0.786	0.759	0.665	0.640	0.585	0.641	0.661	0.696	0.639	0.626	(40)	
(41)		taud	1.534	1.498	1.426	1.511	1.721	1.787	1.934	1.774	1.705	1.580	1.642	1.631	(41)	
(42)		Ebn at Noon	179	186	185	197	217	221	233	220	209	188	187	184	(42)	
(43)		Edh at Noon	79	88	99	93	75	70	61	71	74	79	70	69	(43)	
(44)	All-Sky Solar Radiation	RadAvg	607	721	856	1068	1231	1288	1728	1502	1267	1085	825	725	(44)	
(45)		RadStd	143	177	123	154	171	168	155	127	125	179	155	167	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.79	N/A	N/A	+1.31	N/A	N/A	N/A	N/A	+299	+193
(47)	Regional (6 neighbors)	+0.74	N/A	N/A	+1.08	N/A	N/A	N/A	N/A	+288	+189

Nomenclature: See separate page