

JI'AN JIANGXI, China

WMO: 577990

Lat: 27.0434N

Lon: 114.9138E

Elev: 78

StdP: 100.39

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.1	1.0	-6.4	2.2	5.4	-4.3	2.7	5.2	5.5	7.2	5.1	6.7	1.3	0	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	36.7	26.6	35.7	26.5	34.6	26.3	27.9	33.0	27.5	32.5	27.1	32.0	2.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.9	22.7	29.7	26.4	22.1	29.5	26.0	21.5	29.4	90.2	33.1	88.3	32.5	86.5	32.0	33.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.0	5.0	4.3	-1.8	38.2	1.4	1.2	-2.8	39.0	-3.7	39.7	-4.5	40.3	-5.5	41.2
			-2.6	29.0	1.3	1.0	-3.6	29.7	-4.4	30.3	-5.1	30.8	-6.1	31.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.5	7.2	9.7	13.6	19.8	24.2	27.2	30.3	29.6	26.1	21.2	15.2	9.3	(6)
(7)		DBStd	8.68	3.84	4.96	4.66	4.22	3.00	2.81	2.32	2.41	3.34	3.23	3.85	3.29	(7)
(8)		HDD10.0	241	105	61	17	1	0	0	0	0	0	0	5	52	(8)
(9)		HDD18.3	1186	346	245	159	33	1	0	0	0	0	11	109	282	(9)
(10)		CDD10.0	3703	18	53	128	294	440	515	629	607	483	346	159	29	(10)
(11)		CDD18.3	1607	0	4	13	76	183	265	371	348	233	99	13	1	(11)
(12)		CDH23.3	16993	1	28	93	502	1392	2727	4971	4361	2272	573	71	2	(12)
(13)		CDH26.7	7666	0	2	14	136	455	1125	2668	2165	942	147	12	0	(13)
(14)	Wind	WSAvg	1.7	1.5	1.7	1.7	1.8	1.7	1.8	2.0	1.8	1.7	1.6	1.5	1.5	(14)
(15)	Precipitation	PrecAvg	1600	79	91	177	201	226	254	137	150	80	61	86	58	(15)
(16)		PrecMax	2137	196	168	472	451	533	465	303	366	175	261	208	207	(16)
(17)		PrecMin	954	11	9	80	75	44	103	17	11	4	1	4	1	(17)
(18)		PrecStd	310	39	42	82	75	99	99	70	84	50	61	60	53	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.6	26.4	28.7	32.0	34.2	35.9	38.2	38.2	36.3	33.0	28.7	21.5	(19)
MCWB			16.5	18.6	20.6	22.6	24.6	26.9	26.5	26.7	26.3	23.7	20.4	15.2	(20)	
2%		DB	18.0	23.6	26.0	30.0	32.5	34.3	37.0	36.7	34.6	30.1	25.4	18.1	(21)	
		MCWB	13.2	17.3	19.2	22.4	23.8	26.4	26.7	26.5	26.1	22.4	18.6	13.2	(22)	
5%		DB	15.2	20.4	23.6	28.2	30.9	33.1	35.9	35.5	33.3	28.2	23.1	16.2	(23)	
		MCWB	11.3	16.0	18.2	21.6	23.7	26.1	26.5	26.6	25.8	21.2	17.5	12.3	(24)	
10%		DB	12.8	17.1	20.9	26.3	29.3	31.9	34.8	34.2	31.6	26.6	21.0	14.4	(25)	
		MCWB	9.8	13.7	16.7	20.9	23.4	25.8	26.4	26.5	25.2	20.4	16.8	10.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.2	19.9	22.2	24.5	26.7	28.1	28.4	28.7	27.7	25.3	22.2	17.6	(27)
MCD B			20.4	25.0	26.6	29.3	31.1	32.5	34.0	33.7	32.5	29.6	25.3	20.1	(28)	
2%		WB	14.0	17.8	20.5	23.6	25.8	27.4	27.9	28.0	27.0	23.9	20.3	14.9	(29)	
		MCD B	16.7	22.4	24.5	27.9	29.7	31.7	33.2	33.1	31.9	27.7	23.1	17.0	(30)	
5%		WB	11.9	16.3	19.1	22.8	25.2	26.9	27.5	27.5	26.5	22.8	19.1	12.9	(31)	
		MCD B	14.3	20.3	22.6	26.6	28.5	31.0	32.7	32.4	31.1	26.6	21.7	15.3	(32)	
10%		WB	10.0	14.1	17.5	21.9	24.4	26.4	27.1	27.1	26.0	21.8	17.5	11.4	(33)	
		MCD B	12.2	16.7	20.1	25.1	27.5	30.4	32.2	31.8	30.2	25.0	20.2	13.4	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.5	6.0	6.4	6.9	7.0	6.3	7.3	7.2	7.2	7.5	7.0	6.6	(35)
MCD BR			10.7	12.0	11.6	10.2	9.7	8.1	8.9	9.1	9.2	9.9	10.9	10.6	(36)	
MCWBR			5.9	6.2	5.3	4.1	3.3	2.6	2.3	2.3	2.5	3.4	4.5	5.6	(37)	
5% WB		MCD BR	8.8	10.7	9.9	8.5	7.6	7.2	8.1	8.4	8.3	7.9	7.8	8.0	(38)	
		MCWBR	5.3	5.9	5.6	4.0	3.3	2.9	2.6	2.7	2.6	3.3	4.1	4.8	(39)	
		Clear-Sky Solar Irradiance	taub	0.677	0.719	0.786	0.759	0.665	0.640	0.585	0.641	0.661	0.696	0.639	0.626	(40)
taud	1.534		1.498	1.426	1.511	1.721	1.787	1.934	1.774	1.705	1.580	1.642	1.631	(41)		
Ebn at Noon	564		586	582	620	684	697	736	692	660	594	590	579	(42)		
Edh at Noon	248		276	312	293	238	221	191	223	233	250	220	216	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1.91	2.27	2.70	3.37	3.88	4.06	5.45	4.74	4.00	3.42	2.60	2.29	(44)	
RadStd		0.45	0.56	0.39	0.48	0.54	0.53	0.49	0.40	0.39	0.56	0.49	0.53	(45)		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.44	N/A	N/A	+0.73	N/A	N/A	N/A	N/A	+166	+107
(47)	Regional (6 neighbors)	+0.41	N/A	N/A	+0.60	N/A	N/A	N/A	N/A	+160	+105

Nomenclature: See separate page