

SANSUI, China

WMO: 578320

Lat: 26.9609N

Lon: 108.6764E

Elev: 2070

StdP: 13.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.8	29.2	19.4	15.7	36.6	22.3	18.1	34.2	12.0	42.2	10.4	41.1	3.4	40	0.330

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	91.8	74.4	89.9	74.0	87.9	73.8	77.3	86.0	76.4	84.8	75.6	83.6	5.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.2	142.9	81.1	74.4	138.7	80.1	73.6	135.0	79.3	42.7	86.3	41.8	85.1	40.9	84.0	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	11.3	9.7	8.6	24.7	95.1	1.8	1.8	23.4	96.4	22.3	97.4	21.3	98.5	20.0	99.8	
(5)				23.7	78.8	1.9	1.4	22.3	79.8	21.2	80.6	20.2	81.4	18.8	82.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	60.8	39.8	43.8	51.7	61.9	68.9	74.7	79.0	71.6	62.4	53.3	43.6	(6)	
(7)		DBStd	14.80	6.78	8.16	8.19	7.68	5.53	4.58	3.47	4.10	5.85	6.04	6.57	5.50	(7)
(8)		HDD50	860	323	207	77	7	0	0	0	0	1	37	208	(8)	
(9)		HDD65	3117	781	595	418	147	24	1	0	12	122	353	664	(9)	
(10)		CDD50	4811	8	34	131	364	586	741	900	867	647	386	137	10	(10)
(11)		CDD65	1590	0	1	7	53	146	292	435	402	210	41	3	0	(11)
(12)		CDH74	12312	0	12	68	425	975	1959	3876	3297	1453	224	23	0	(12)
(13)		CDH80	4260	0	1	13	102	272	561	1483	1282	501	44	1	0	(13)
(14)	Wind	WSAvg	3.7	3.7	4.0	3.9	4.0	3.7	3.5	3.7	3.5	3.6	3.4	3.5	3.5	(14)
(15)	Precipitation	PrecAvg	43.8	1.3	1.4	2.2	4.8	7.4	6.4	4.7	5.5	2.9	3.6	2.4	1.1	(15)
(16)		PrecMax	60.9	3.1	3.6	4.0	8.7	14.4	12.0	12.2	11.2	6.5	8.0	8.3	3.0	(16)
(17)		PrecMin	33.6	0.3	0.4	0.7	2.0	3.1	2.2	0.9	1.2	0.0	0.9	0.1	0.0	(17)
(18)		PrecStd	6.4	0.6	0.8	0.8	1.9	2.6	2.9	2.6	2.5	1.7	1.8	1.8	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.6	74.7	81.3	87.3	89.5	90.6	94.3	94.5	92.3	84.7	77.6	65.2	(19)
(20)		MCWB	54.4	59.8	64.2	68.9	70.7	73.7	74.9	74.2	72.6	69.2	63.5	52.5	(20)	
(21)		2%	DB	58.7	67.9	74.5	82.8	86.1	88.2	91.9	91.9	88.9	80.0	72.0	60.2	(21)
(22)		MCWB	49.7	56.7	62.5	68.2	69.7	73.9	75.1	74.5	72.4	66.4	60.6	49.8	(22)	
(23)		5%	DB	53.7	60.9	68.9	79.0	83.2	85.7	89.8	89.6	85.9	75.7	67.7	55.7	(23)
(24)		MCWB	46.7	52.9	58.9	66.4	69.6	73.5	74.9	74.6	72.1	65.1	58.5	48.6	(24)	
(25)		10%	DB	49.4	55.2	64.1	74.9	79.8	83.3	87.7	87.1	82.5	72.1	63.6	52.2	(25)
(26)		MCWB	44.4	49.5	56.9	65.2	68.8	73.1	74.8	74.3	70.8	63.8	57.2	46.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.3	60.8	66.4	72.1	75.3	77.3	78.9	78.4	76.1	71.8	66.0	55.7	(27)
(28)		MCD B	64.9	72.2	77.4	81.4	84.2	85.8	87.5	87.4	86.0	80.5	74.1	59.8	(28)	
(29)		2%	WB	51.0	57.7	63.4	70.0	73.6	76.2	77.6	77.2	75.0	69.6	62.8	52.2	(29)
(30)		MCD B	56.1	66.7	72.4	79.4	81.8	84.0	86.0	86.2	84.5	75.7	68.9	57.5	(30)	
(31)		5%	WB	47.8	54.0	60.7	68.2	72.1	75.3	76.6	76.3	73.7	67.5	60.5	49.6	(31)
(32)		MCD B	52.5	59.2	66.8	76.3	79.0	82.2	84.9	84.8	81.9	72.4	65.1	54.5	(32)	
(33)		10%	WB	45.0	50.5	57.9	66.3	70.6	74.4	75.8	75.4	72.4	65.6	58.1	47.2	(33)
(34)		MCD B	48.8	54.6	62.7	73.2	76.7	80.6	83.8	83.3	79.6	70.2	62.5	51.5	(34)	
(35)	Mean Daily Temperature Range		MDBR	9.3	10.6	12.5	13.9	13.8	12.0	14.0	14.8	14.7	12.1	12.4	11.1	(35)
(36)		5% DB	MCDBR	21.2	23.9	24.2	23.4	22.4	17.5	19.5	20.3	21.4	20.6	21.7	22.9	(36)
(37)		MCWBR	12.3	12.6	11.3	9.5	8.1	5.5	5.0	5.4	6.7	7.9	10.4	12.8	(37)	
(38)		5% WB	MCD BR	18.5	21.3	20.0	18.8	16.0	13.2	15.6	16.0	17.2	15.1	16.0	19.0	(38)
(39)		MCWBR	11.4	11.9	10.3	9.0	7.1	5.0	5.3	5.3	6.1	7.2	8.7	11.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.680	0.691	0.770	0.736	0.627	0.601	0.542	0.606	0.646	0.731	0.678	0.683	(40)	
(41)		taud	1.478	1.492	1.404	1.504	1.759	1.845	2.017	1.821	1.697	1.482	1.533	1.485	(41)	
(42)		Ebn at Noon	177	192	188	201	226	230	244	227	213	180	177	168	(42)	
(43)		Edh at Noon	83	88	101	94	73	66	56	68	74	88	78	80	(43)	
(44)	All-Sky Solar Radiation	RadAvg	467	615	818	1012	1106	1119	1488	1391	1140	811	692	526	(44)	
(45)		RadStd	115	154	111	159	183	162	128	119	141	121	140	118	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.56	N/A	N/A	+1.42	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.52	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	+158	N/A

Nomenclature: See separate page