

DUSHAN, China

WMO: 579220

Lat: 25.8325N

Lon: 107.5481E

Elev: 1016

StdP: 89.71

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.6	-1.2	-6.6	2.4	1.7	-4.9	2.8	1.8	7.3	10.7	6.5	8.8	2.2	340	0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.7	29.8	22.3	28.9	22.1	28.0	21.9	23.9	27.2	23.4	26.7	23.0	26.2	2.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.1	20.2	25.3	22.5	19.6	25.0	22.1	19.0	24.6	78.3	27.3	76.1	26.8	74.3	26.4	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.0	6.1	5.4		-3.6	31.8	1.6	0.8	-4.7	32.3	-5.6	32.8	-6.5	33.3	-7.6	33.8
				-4.4	24.9	1.5	1.0	-5.5	25.6	-6.4	26.2	-7.3	26.8	-8.4	27.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.9	5.4	7.9	11.7	16.7	20.2	22.5	24.0	23.8	21.3	17.2	12.8	7.6
	DBStd	7.31	4.42	5.34	4.67	4.17	2.90	2.08	1.56	1.81	2.74	3.23	3.85	3.67
	HDD10.0	401	156	98	35	4	0	0	0	0	0	1	16	92
	HDD18.3	1572	402	294	212	78	16	1	0	0	7	60	169	333
	CDD10.0	2572	12	38	87	206	315	374	433	427	338	224	101	18
	CDD18.3	702	0	1	6	29	72	126	174	168	96	26	3	0
	CDH23.3	3098	0	5	20	107	283	468	840	882	418	71	4	0
	CDH26.7	535	0	0	1	14	35	57	154	197	72	4	0	0
Wind	WSAvg	2.4	2.3	2.6	2.7	2.8	2.6	2.5	2.6	2.1	2.1	2.2	2.3	2.2
Precipitation	PrecAvg	1329	28	36	53	127	207	233	202	151	97	106	62	27
	PrecMax	1666	56	89	156	331	392	451	510	319	226	272	248	82
	PrecMin	968	2	5	8	24	117	111	12	34	7	4	1	1
	PrecStd	163	13	21	32	63	68	90	102	73	55	72	53	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.5	23.7	26.0	28.4	29.1	29.5	31.0	31.1	30.1	27.1	23.9	20.2
		MCWB	13.1	15.4	17.9	19.2	21.0	22.3	23.0	22.3	21.4	19.3	16.5	14.2
	2%	DB	15.7	20.5	22.9	26.1	27.6	28.2	29.6	29.9	28.6	25.3	21.7	17.1
		MCWB	11.7	14.8	17.2	19.5	20.2	22.3	22.9	22.5	21.1	18.8	15.8	12.0
	5%	DB	13.8	17.8	20.3	24.2	26.3	27.1	28.5	28.8	27.4	23.7	20.2	15.1
		MCWB	11.1	14.0	16.2	18.8	20.1	22.0	22.7	22.4	20.8	18.2	15.3	10.8
	10%	DB	11.9	15.6	18.2	22.4	24.8	26.0	27.3	27.7	25.9	22.2	18.6	13.2
		MCWB	9.7	13.0	15.2	18.4	19.9	21.8	22.5	22.2	20.3	17.9	14.9	9.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.1	16.8	19.0	21.7	23.7	24.7	24.6	24.2	23.2	21.3	18.8	15.3
		MCDB	16.6	21.2	23.3	24.5	26.5	27.2	27.7	28.5	26.8	24.3	21.3	18.5
	2%	WB	12.9	15.5	17.9	20.8	22.6	23.7	23.9	23.6	22.6	20.4	17.8	13.6
		MCDB	15.1	19.0	21.0	23.8	25.3	26.2	27.1	27.6	26.0	23.1	20.1	16.1
	5%	WB	11.7	14.4	16.9	19.9	21.8	23.1	23.4	23.1	22.1	19.7	16.8	11.9
		MCDB	13.4	17.4	19.9	22.8	24.6	25.6	26.6	27.0	25.1	22.2	19.0	14.0
	10%	WB	9.9	13.2	15.8	19.1	21.1	22.6	23.0	22.7	21.5	18.9	15.6	10.2
		MCDB	11.5	15.7	18.0	21.9	23.6	24.9	26.1	26.2	24.4	21.3	17.9	12.6
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.8	6.2	6.6	6.4	5.4	5.7	6.7	6.8	6.1	6.4	5.9
		MCDBR	8.9	9.3	9.4	9.0	8.8	7.4	8.0	8.8	9.0	8.6	9.1	10.1
		MCWBR	5.4	4.3	4.3	3.6	3.3	2.6	2.4	2.8	2.8	3.3	4.2	5.4
	5% WB	MCDBR	7.1	8.1	8.3	7.5	6.4	5.7	6.3	7.3	6.7	6.4	6.3	7.5
		MCWBR	4.8	4.2	4.4	3.9	3.2	2.6	2.4	2.8	2.6	3.0	3.8	4.6
Clear-Sky Solar Irradiance	taub	0.563	0.570	0.672	0.643	0.536	0.518	0.483	0.528	0.545	0.616	0.559	0.578	
	taud	1.684	1.710	1.544	1.654	1.976	2.063	2.169	2.011	1.922	1.680	1.747	1.662	
	Ebn at Noon	666	707	663	701	779	788	816	779	752	661	665	627	
	Edh at Noon	214	224	278	255	184	168	151	176	188	228	200	212	
All-Sky Solar Radiation	RadAvg	1.66	2.28	2.84	3.57	3.82	3.58	4.55	4.43	3.80	2.76	2.47	1.89	
	RadStd	0.40	0.48	0.41	0.52	0.50	0.49	0.35	0.34	0.41	0.40	0.43	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.25	N/A	N/A	+0.46	+0.38	+0.39	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+0.47	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page