

RONGJIANG, China

WMO: 579320

Lat: 25.9274N

Lon: 108.5123E

Elev: 287

StdP: 97.92

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.1	2.4	-4.2	2.7	5.8	-2.4	3.2	5.9	6.0	12.6	5.1	13.0	0.8	40	0.302

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	35.5	25.5	34.4	25.2	33.2	25.0	26.8	32.0	26.4	31.3	26.0	30.7	2.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	21.7	28.2	25.2	21.1	27.9	24.9	20.7	27.6	86.5	32.3	84.5	31.5	82.7	30.8	33.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.4	4.3	3.5	DB	-0.1	37.7	1.2	0.8	-0.9	38.3	-1.6	38.8	-2.3	39.2	-3.2	39.8	(4)
			WB	-0.9	27.9	1.2	1.3	-1.8	28.8	-2.5	29.6	-3.2	30.3	-4.0	31.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.5	8.5	11.0	14.9	20.1	23.7	26.5	28.2	28.1	25.4	20.8	15.9	10.6
	DBStd	7.58	3.77	4.68	4.34	3.96	2.79	2.19	1.81	2.06	2.92	3.19	3.48	3.07
	HDD10.0	151	73	40	8	1	0	0	0	0	0	0	2	27
	HDD18.3	1008	304	211	124	26	1	0	0	0	1	13	88	241
	CDD10.0	3623	28	67	159	304	426	494	564	559	462	336	178	46
	CDD18.3	1439	0	4	18	79	168	244	306	301	212	91	15	1
	CDH23.3	12416	2	36	118	543	1188	2116	3181	2977	1706	479	66	5
CDH26.7	4878	0	7	28	172	431	762	1356	1297	685	133	7	1	
Wind	WSAvg	1.1	1.1	1.2	1.2	1.3	1.2	1.1	1.2	1.2	1.1	1.0	1.0	0.9
Precipitation	PrecAvg	1177	32	37	53	119	188	212	149	142	72	88	59	27
	PrecMax	1469	83	84	145	237	305	356	370	398	233	275	174	87
	PrecMin	833	2	1	17	41	51	87	25	17	2	20	2	0
	PrecStd	181	19	21	33	49	63	90	86	93	48	64	45	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.1	27.6	29.8	32.9	34.4	35.0	36.9	36.7	35.8	32.3	27.8	23.1
		MCWB	16.1	18.7	20.8	23.1	23.8	25.4	26.0	25.5	25.0	22.6	20.5	16.9
	2%	DB	18.4	23.8	26.5	30.5	32.6	33.6	35.4	35.5	34.1	30.0	25.3	19.3
		MCWB	13.7	17.1	19.4	22.0	23.3	25.3	25.8	25.5	24.5	22.1	18.7	13.7
	5%	DB	15.9	21.0	23.8	28.7	31.1	32.2	34.0	34.3	32.6	28.0	23.3	17.1
		MCWB	12.1	16.0	17.7	21.5	23.1	25.1	25.6	25.5	24.1	21.0	17.8	12.3
	10%	DB	13.6	17.8	21.3	26.7	29.2	30.8	32.7	32.8	30.7	26.0	21.2	15.0
		MCWB	11.0	13.9	16.9	20.7	22.8	24.9	25.5	25.3	23.4	20.3	17.2	11.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.7	18.9	21.5	24.2	26.1	27.1	27.5	27.2	26.2	24.5	21.7	17.7
		MCDB	21.1	26.1	28.4	29.8	31.2	32.1	33.1	33.5	31.9	29.5	25.8	22.4
	2%	WB	14.6	17.5	20.0	23.1	25.1	26.5	26.9	26.7	25.6	23.4	20.4	15.0
		MCDB	17.9	23.1	25.2	28.7	29.9	30.9	31.9	32.4	31.0	27.4	23.8	17.9
	5%	WB	12.8	16.3	19.0	22.3	24.4	26.0	26.4	26.2	25.1	22.5	19.1	13.4
		MCDB	14.8	20.7	22.8	27.2	28.6	30.0	31.2	31.6	29.9	25.8	21.9	15.9
	10%	WB	11.3	14.6	17.6	21.5	23.8	25.5	26.0	25.8	24.6	21.6	17.8	12.0
		MCDB	13.5	17.3	20.5	25.7	27.4	29.0	30.6	30.6	28.8	24.6	20.2	14.2
Mean Daily Temperature Range	5% DB	MDBR	5.4	6.5	7.2	7.9	8.1	7.2	8.0	8.6	8.7	7.5	7.3	6.7
		MCDBR	11.0	12.5	12.6	11.7	12.3	10.0	10.9	11.3	11.8	11.4	11.1	12.0
		MCWBR	5.9	5.8	5.1	4.0	3.7	2.6	2.4	2.6	2.9	3.8	4.9	6.2
	5% WB	MCDBR	8.9	11.0	10.6	9.9	8.6	7.6	8.9	9.5	9.3	8.6	8.7	10.0
		MCWBR	5.2	5.3	4.9	3.9	3.2	2.4	2.5	2.8	2.6	3.6	4.3	5.5
Clear-Sky Solar Irradiance	taub	0.661	0.674	0.777	0.746	0.624	0.594	0.550	0.612	0.649	0.728	0.649	0.666	
	taud	1.541	1.557	1.423	1.521	1.805	1.896	2.020	1.834	1.720	1.518	1.617	1.550	
	Ebn at Noon	583	624	592	631	714	731	762	715	672	577	589	555	
	Edh at Noon	249	262	314	291	219	199	175	210	230	268	228	238	
All-Sky Solar Radiation	RadAvg	1.56	2.02	2.55	3.18	3.53	3.47	4.51	4.39	3.76	2.85	2.38	1.87	
	RadStd	0.38	0.47	0.38	0.48	0.53	0.47	0.39	0.34	0.43	0.39	0.48	0.39	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.35	N/A	N/A	+0.57	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	+0.47	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page