

GUILIN, China

WMO: 579570

Lat: 25.3226N

Lon: 110.3046E

Elev: 166

StdP: 99.35

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.0	2.3	-7.8	2.0	9.2	-5.1	2.5	8.8	7.8	8.1	7.1	7.4	2.3	20	0.346

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	35.2	25.6	34.2	25.5	33.2	25.4	27.2	31.6	26.8	31.1	26.4	30.6	2.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	22.0	28.9	25.9	21.7	28.7	25.3	20.8	28.2	88.0	31.5	85.8	31.6	83.9	30.7	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature										
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min		Max		Min	Max	Min		Max		Min		Max		Min		Max	
(a)	(b)	(c)	DB	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.1	6.2	5.4		WB	-0.8	37.3	1.1	1.1	-1.6	38.2	-2.3	38.8	-2.9	39.4	-3.8	40.3	
					-1.8	28.4	1.1	0.8	-2.6	28.9	-3.2	29.3	-3.8	29.8	-4.6	30.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.8	8.7	10.8	14.3	19.9	23.9	26.8	28.6	28.6	26.2	21.8	16.3	10.8
	DBStd	7.75	3.84	4.71	4.16	3.83	2.69	2.10	1.74	1.89	2.79	3.10	3.68	3.23
	HDD10.0	154	72	42	9	1	0	0	0	0	0	0	2	28
	HDD18.3	1002	300	216	137	27	1	0	0	0	1	8	81	233
	CDD10.0	3721	31	64	143	297	432	504	575	576	486	367	192	53
	CDD18.3	1526	0	4	12	73	174	254	317	318	236	116	20	1
	CDH23.3	14485	1	23	58	417	1240	2380	3597	3601	2269	773	122	3
	CDH26.7	5666	0	3	7	91	383	834	1573	1609	923	224	17	0
Wind	WSAvg	2.1	2.3	2.4	2.1	2.0	1.9	1.8	1.9	2.0	2.3	2.4	2.2	2.3
Precipitation	PrecAvg	1830	55	83	133	255	339	302	206	161	71	94	84	46
	PrecMax	2679	136	206	325	504	798	723	589	368	257	287	246	118
	PrecMin	1287	1	13	33	77	76	90	40	15	1	3	0	0
	PrecStd	316	37	46	62	106	140	151	135	87	52	77	69	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.8	26.1	27.8	31.1	33.2	34.6	36.6	37.0	35.4	33.0	28.8	23.0
		MCWB	16.1	18.9	21.4	23.3	24.5	25.7	25.9	25.9	24.8	22.3	20.0	14.9
	2%	DB	18.9	23.1	24.9	29.1	31.9	33.2	35.1	35.4	34.1	30.8	26.5	20.2
		MCWB	13.1	17.5	19.2	22.2	23.9	25.4	25.9	25.7	24.7	21.7	17.9	12.5
	5%	DB	16.6	20.7	22.9	27.3	30.4	32.1	34.0	34.2	33.0	29.1	24.6	18.2
		MCWB	12.1	16.7	18.0	21.9	23.6	25.4	25.9	25.6	24.4	20.5	17.4	11.9
	10%	DB	14.5	17.7	20.6	25.9	28.9	30.9	33.0	33.1	31.6	27.6	22.6	16.2
		MCWB	10.9	14.5	16.8	21.2	23.2	25.3	25.9	25.6	24.0	19.9	16.8	11.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.4	20.4	22.3	24.8	26.7	27.5	28.0	27.9	27.0	24.9	22.4	18.3
		MCDB	20.0	24.7	26.2	28.6	30.5	31.0	32.9	32.4	31.6	29.6	25.6	20.6
	2%	WB	15.3	18.5	20.8	23.9	25.9	26.8	27.2	27.2	26.2	23.8	21.0	15.2
		MCDB	17.7	22.2	23.7	27.4	29.6	30.3	31.8	31.9	30.7	27.8	24.4	17.6
	5%	WB	13.1	17.0	19.2	23.1	25.3	26.4	26.8	26.7	25.7	22.8	19.5	13.4
		MCDB	15.5	19.9	21.6	26.2	28.4	29.8	31.2	31.3	30.1	26.4	22.2	16.4
	10%	WB	11.3	15.1	17.7	22.3	24.6	26.0	26.4	26.2	25.2	21.8	17.9	12.0
		MCDB	13.8	17.4	19.7	25.0	27.3	29.3	30.6	30.6	29.5	25.5	21.1	15.3
Mean Daily Temperature Range	5% DB	MDBR	5.8	5.9	6.0	6.8	7.2	6.6	7.8	8.2	8.6	8.7	8.3	7.6
		MCDBR	11.3	11.1	10.8	10.1	10.4	9.0	10.0	10.5	10.8	11.8	12.6	12.9
	5% WB	MCWBR	6.2	6.0	5.4	4.6	4.3	3.1	2.9	2.8	3.2	3.9	5.2	6.4
		MCWBR	8.5	9.4	8.3	8.2	7.6	7.1	8.5	8.9	9.1	8.7	8.6	9.0
Clear-Sky Solar Irradiance	taub	taub	0.647	0.682	0.799	0.764	0.633	0.602	0.568	0.637	0.668	0.714	0.618	0.626
		taud	1.587	1.568	1.409	1.511	1.799	1.888	1.976	1.779	1.689	1.551	1.698	1.644
	Ebn at Noon	Ebn at Noon	600	623	580	620	708	725	749	697	660	590	620	594
		Edh at Noon	239	260	320	295	220	200	183	222	238	261	212	218
All-Sky Solar Radiation	RadAvg	RadAvg	1.71	1.94	2.32	2.93	3.50	3.57	4.67	4.50	4.04	3.39	2.62	2.14
	RadStd	RadStd	0.44	0.49	0.39	0.41	0.49	0.52	0.47	0.31	0.39	0.33	0.49	0.52

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.28	N/A	N/A	+0.79	N/A	N/A	N/A	N/A	+105	+79
(47)	Regional (6 neighbors)	+0.32	N/A	N/A	+0.51	N/A	N/A	N/A	N/A	+123	+81

Nomenclature: See separate page