

GANZHOU, China

WMO: 579930

Lat: 25.8705N

Lon: 115.0142E

Elev: 134

StdP: 99.73

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.8	1.9	-7.6	2.0	7.1	-4.8	2.6	6.7	4.6	10.1	4.2	9.5	1.4	340	0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	36.2	25.1	35.3	25.2	34.3	25.2	26.9	32.3	26.5	31.8	26.2	31.3	2.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.7	21.3	28.7	25.2	20.7	28.6	24.9	20.3	28.5	85.6	32.4	84.0	32.0	82.5	31.4	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.6	4.0	3.4	-1.0	37.7	1.0	1.0	-1.7	38.5	-2.3	39.1	-2.9	39.7	-3.6	40.4		
(5)			-2.1	27.4	1.2	0.8	-3.0	28.0	-3.7	28.5	-4.4	28.9	-5.3	29.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.4	8.8	11.4	14.9	20.8	24.8	27.7	30.1	29.5	26.6	22.2	16.5	10.7		
	DBStd	8.18	4.25	5.40	4.81	4.11	2.94	2.55	1.93	1.99	2.97	3.23	3.88	3.50		
	HDD10.0	165	75	44	11	1	0	0	0	0	0	0	2	33		
	HDD18.3	979	296	204	129	23	1	0	0	0	0	7	80	239		
	CDD10.0	3949	38	82	162	324	459	531	622	603	499	378	197	53		
	CDD18.3	1721	1	9	22	97	202	281	363	345	249	127	24	1		
	CDH23.3	17918	4	53	128	638	1657	3034	4755	4227	2467	823	127	5		
(13)	CDH26.7	7799	0	5	18	168	578	1286	2460	2016	1011	237	21	0		
(14)	Wind	WSAvg	1.4	1.3	1.4	1.3	1.4	1.5	1.7	1.5	1.5	1.4	1.3	1.3		
(15) Precipitation	PrecAvg	1424	67	93	162	178	217	205	115	143	84	59	60	46		
	PrecMax	2183	245	270	490	449	388	482	347	320	265	216	222	185		
	PrecMin	947	2	0	22	30	36	17	6	8	5	0	0	1		
	PrecStd	306	56	61	81	84	82	103	73	73	59	51	50	42		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.6	27.3	28.7	32.2	34.5	35.9	37.6	37.5	35.8	33.3	29.0	23.6		
		MCWB	17.1	19.0	20.1	22.5	24.1	25.4	24.8	25.1	24.9	23.2	20.6	17.3		
	2%	DB	20.2	25.0	26.5	30.3	32.9	34.6	36.4	36.1	34.4	30.8	26.7	20.4		
		MCWB	14.9	17.8	19.4	22.0	23.6	25.3	25.2	25.1	24.9	22.1	19.4	14.5		
	5%	DB	17.8	22.7	24.6	28.7	31.5	33.5	35.4	35.1	33.1	29.3	24.5	18.1		
		MCWB	13.6	16.9	18.7	21.4	23.4	25.2	25.2	25.3	24.7	20.9	17.8	13.4		
	10%	DB	15.3	19.8	22.4	27.0	29.9	32.2	34.4	33.9	31.8	27.7	22.5	16.2		
		MCWB	11.6	15.5	17.6	20.9	23.1	25.1	25.2	25.3	24.2	20.5	17.2	11.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.0	20.2	21.9	24.3	26.4	27.1	27.3	27.4	26.7	24.9	22.3	19.3		
		MCDB	21.6	26.0	26.4	29.2	31.6	32.4	32.9	32.9	31.4	29.5	26.3	22.9		
	2%	WB	16.3	18.7	20.8	23.3	25.5	26.5	26.8	26.8	26.1	23.9	20.9	16.5		
		MCDB	19.5	23.8	24.7	27.8	30.2	31.7	32.5	32.2	31.0	28.1	24.9	18.7		
	5%	WB	14.2	17.4	19.6	22.6	24.9	26.1	26.5	26.5	25.7	23.0	19.7	14.3		
		MCDB	17.1	21.7	23.3	26.9	29.0	31.1	32.0	31.7	30.5	27.0	22.9	16.8		
	10%	WB	11.9	15.9	18.4	21.9	24.2	25.7	26.1	26.1	25.2	22.1	18.3	12.6		
		MCDB	14.9	19.7	21.9	25.9	28.1	30.4	31.4	31.1	29.9	26.1	21.4	15.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.1	6.6	6.6	7.1	7.2	6.6	7.6	7.5	7.2	7.7	7.5	7.2		
		MCDBR	11.1	11.6	10.8	9.9	9.9	8.6	9.1	9.4	9.2	10.2	11.2	11.2		
	5% WB	MCWBR	6.0	5.3	4.9	3.5	2.8	2.0	1.8	2.0	2.0	2.9	4.3	5.7		
		MCWBR	9.3	9.9	8.7	8.0	7.5	7.2	8.0	7.9	7.6	8.3	8.3	7.8		
(40) Clear-Sky Solar Irradiance	taub	taub	0.674	0.721	0.812	0.788	0.669	0.633	0.588	0.652	0.669	0.700	0.637	0.622		
		taud	1.546	1.504	1.396	1.475	1.721	1.805	1.918	1.745	1.688	1.576	1.657	1.651		
	Ebn at Noon	Ebn at Noon	575	591	570	604	682	703	734	686	657	597	600	593		
		Edh at Noon	248	277	324	305	238	218	194	230	238	253	219	215		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.16	2.46	2.72	3.29	3.82	4.11	5.35	4.81	4.13	3.66	2.81	2.53		
	RadStd	RadStd	0.50	0.54	0.45	0.50	0.52	0.49	0.48	0.38	0.37	0.64	0.48	0.56		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.41	N/A	N/A	+0.48	N/A	N/A	N/A	N/A	+148	+113
(47)	Regional (6 neighbors)	+0.30	N/A	N/A	+0.47	N/A	N/A	N/A	N/A	+128	+95

Nomenclature: See separate page