

GANYU, China

WMO: 580400

Lat: 34.8567N

Lon: 119.1277E

Elev: 33

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.3	22.2	-2.8	4.7	27.6	1.8	6.0	29.0	16.6	32.7	15.0	34.3	3.9	320	0.400

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	92.4	79.7	89.8	78.8	87.5	78.2	83.0	89.3	81.9	87.5	80.8	85.6	7.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.4	163.2	87.2	80.3	157.6	86.0	79.3	152.2	84.9	47.2	90.0	45.9	87.9	44.6	85.6	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	13.8	12.0	15.2	97.0	3.5	2.0	12.7	98.4	10.6	99.6	8.6	100.7	6.0	102.2
			12.5	84.7	3.4	1.4	10.1	85.7	8.2	86.5	6.3	87.3	3.8	88.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.2	33.1	37.2	46.4	57.4	67.4	74.5	80.5	79.6	71.9	62.0	49.0	37.3	(6)
(7)		DBStd	17.39	5.37	5.92	6.85	6.39	5.70	4.79	4.50	4.32	4.49	5.57	7.04	5.95	(7)
(8)		HDD50	1546	524	359	155	10	0	0	0	0	0	1	102	395	(8)
(9)		HDD65	4093	989	779	577	242	39	1	0	4	124	480	858	(9)	
(10)		CDD50	4522	0	1	44	231	541	735	946	919	658	373	72	2	(10)
(11)		CDD65	1594	0	0	1	14	115	286	481	454	213	30	0	0	(11)
(12)		CDH74	13606	0	0	8	123	828	1976	4925	4525	1134	86	1	0	(12)
(13)		CDH80	4287	0	0	1	21	221	603	1805	1449	182	5	0	0	(13)
(14)	Wind	WSAvg	5.4	4.7	5.6	6.5	6.7	6.2	6.0	5.5	5.5	4.8	4.4	4.8	4.7	(14)
(15)	Precipitation	PrecAvg	37.0	0.6	0.8	1.1	2.0	2.4	4.3	10.2	7.7	4.3	1.7	1.1	0.5	(15)
(16)		PrecMax	58.4	2.7	2.1	2.8	6.2	7.4	13.0	27.2	26.3	11.5	8.1	3.7	2.2	(16)
(17)		PrecMin	18.9	0.0	0.0	0.1	0.1	0.1	0.5	3.3	1.0	0.3	0.0	0.0	0.0	(17)
(18)		PrecStd	10.2	0.7	0.6	0.7	1.5	1.8	2.9	5.0	5.8	3.2	1.6	1.1	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.9	58.7	73.9	82.9	91.0	94.1	96.0	94.1	88.2	80.0	70.1	56.8	(19)
(20)		MCWB	41.7	46.4	57.7	66.6	67.9	71.9	82.9	82.3	76.6	64.3	58.1	51.7	(20)	
(21)		2%	DB	46.6	53.6	67.6	77.5	85.4	89.6	93.1	91.0	84.3	76.2	65.7	52.7	(21)
(22)		MCWB	40.6	44.0	54.1	62.6	67.8	71.8	82.2	81.8	74.0	64.9	56.6	47.1	(22)	
(23)		5%	DB	44.2	49.6	62.2	73.2	81.9	86.3	90.5	88.4	81.8	73.6	62.8	49.6	(23)
(24)		MCWB	39.4	42.1	51.1	60.0	65.8	72.2	81.1	80.5	72.5	64.0	55.4	44.0	(24)	
(25)		10%	DB	41.8	46.3	57.6	69.1	78.7	83.2	88.0	86.3	79.7	71.2	60.1	46.8	(25)
(26)		MCWB	37.3	40.3	47.7	57.0	64.5	72.2	80.2	79.3	71.3	63.0	53.3	41.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.1	49.7	59.9	69.4	73.2	79.9	84.6	84.3	80.6	70.8	63.0	53.3	(27)
(28)		MCDWB	47.8	55.0	69.7	79.9	82.0	86.8	92.0	89.9	84.5	74.7	65.5	54.4	(28)	
(29)		2%	WB	42.6	46.0	56.0	64.7	70.9	78.0	83.4	82.8	77.3	68.7	59.6	48.3	(29)
(30)		MCDWB	44.7	50.7	65.0	74.0	79.5	84.5	90.4	88.4	81.0	72.7	63.5	51.1	(30)	
(31)		5%	WB	40.3	43.8	52.3	61.8	69.0	76.1	82.3	81.9	75.0	66.5	57.2	45.3	(31)
(32)		MCDWB	43.2	47.6	59.7	70.1	77.3	81.7	88.7	87.0	79.5	71.5	60.7	48.5	(32)	
(33)		10%	WB	37.9	41.8	49.5	59.3	67.2	74.0	81.2	80.9	73.3	64.4	54.2	42.7	(33)
(34)		MCDWB	41.3	45.3	55.9	66.5	75.1	79.7	86.9	85.3	78.1	69.5	59.0	46.2	(34)	
(35)	Mean Daily Temperature Range		MDBR	13.3	13.2	15.0	15.4	15.2	11.9	9.6	9.7	12.5	14.8	14.5	13.5	(35)
(36)		5% DB	MCDBR	16.8	18.6	22.9	22.4	22.1	18.2	13.3	12.0	14.7	17.3	17.5	16.5	(36)
(37)			MCWBR	11.6	11.7	12.5	11.6	9.3	6.9	5.4	5.3	6.2	8.4	10.4	11.2	(37)
(38)			MCDBR	13.7	15.0	20.5	19.9	17.6	12.9	11.9	10.1	11.7	13.2	13.7	13.4	(38)
(39)		5% WB	MCWBR	10.8	10.8	12.2	11.8	9.4	6.5	5.7	5.3	6.4	8.4	10.2	10.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.539	0.603	0.637	0.640	0.655	0.767	0.735	0.695	0.619	0.642	0.609	0.546	(40)	
(41)		taud	1.722	1.631	1.595	1.632	1.639	1.483	1.594	1.657	1.753	1.630	1.645	1.727	(41)	
(42)		Ebn at Noon	194	198	207	217	216	193	198	202	210	186	172	181	(42)	
(43)		Edh at Noon	58	71	80	80	81	95	84	78	67	70	63	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	775	942	1336	1574	1695	1601	1453	1420	1274	1077	813	711	(44)	
(45)		RadStd	89	133	111	124	136	137	159	176	130	120	108	69	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page