

GANYU, China

WMO: 580400

Lat: 34.8567N

Lon: 119.1277E

Elev: 10

StdP: 101.20

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.0	-5.4	-19.4	0.7	-2.5	-16.8	0.9	-1.6	7.4	0.4	6.7	1.3	1.7	320	0.400

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.3	33.5	26.5	32.1	26.0	30.8	25.7	28.3	31.8	27.7	30.8	27.1	29.8	3.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.4	23.3	30.6	26.9	22.5	30.0	26.3	21.7	29.4	91.8	32.2	88.9	31.0	86.0	29.8	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.1	6.2	5.4	-9.3	36.1	2.0	1.1	-10.7	36.9	-11.9	37.5	-13.0	38.2	-14.4	39.0
			-10.8	29.3	1.9	0.8	-12.1	29.8	-13.2	30.3	-14.3	30.7	-15.6	31.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.5	0.6	2.9	8.0	14.1	19.7	23.6	26.9	26.5	22.2	16.7	9.4	2.9	(6)
		DBStd	9.66	2.98	3.29	3.81	3.55	3.17	2.66	2.50	2.40	2.49	3.10	3.91	3.31	
		HDD10.0	859	291	199	86	6	0	0	0	0	1	57	219		
		HDD18.3	2274	549	433	321	134	22	1	0	2	69	267	477		
		CDD10.0	2512	0	1	24	128	301	408	526	511	366	207	40	1	
		CDD18.3	886	0	0	1	8	64	159	267	252	118	17	0	0	
		CDH23.3	7559	0	0	4	68	460	1098	2736	2514	630	48	1	0	
		CDH26.7	2382	0	0	1	12	123	335	1003	805	101	3	0	0	
(14)	Wind	WSAvg	2.4	2.1	2.5	2.9	3.0	2.8	2.7	2.4	2.5	2.1	2.0	2.1	2.1	(14)
(15)	Precipitation	PrecAvg	941	16	20	28	52	60	110	259	196	109	44	29	13	(15)
(16)		PrecMax	1483	68	53	70	158	189	329	690	667	293	205	94	55	(16)
(17)		PrecMin	481	0	0	2	2	2	12	85	25	7	0	0	0	(17)
(18)		PrecStd	258	18	15	17	38	46	73	126	148	81	41	27	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	10.5	14.8	23.3	28.3	32.8	34.5	35.6	34.5	31.2	26.7	21.2	13.8		(19)
(20)		0.4% MCWB	5.4	8.0	14.3	19.2	20.0	22.2	28.3	27.9	24.8	17.9	14.5	11.0		(20)
(21)		2% DB	8.1	12.0	19.8	25.3	29.6	32.0	33.9	32.8	29.0	24.6	18.7	11.5		(21)
(22)		2% MCWB	4.8	6.6	12.3	17.0	19.9	22.1	27.9	27.7	23.3	18.3	13.7	8.4		(22)
(23)		5% DB	6.8	9.8	16.8	22.9	27.7	30.2	32.5	31.3	27.7	23.1	17.1	9.8		(23)
(24)		5% MCWB	4.1	5.6	10.6	15.5	18.8	22.3	27.3	27.0	22.5	17.8	13.0	6.7		(24)
(25)		10% DB	5.5	7.9	14.2	20.6	26.0	28.5	31.1	30.2	26.5	21.8	15.6	8.2		(25)
(26)		10% MCWB	3.0	4.6	8.7	13.9	18.1	22.3	26.8	26.3	21.8	17.2	11.8	5.4		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	7.3	9.8	15.5	20.8	22.9	26.6	29.2	29.0	27.0	21.5	17.2	11.8		(27)
(28)		0.4% MCDB	8.8	12.8	20.9	26.6	27.8	30.5	33.3	32.2	29.2	23.7	18.6	12.4		(28)
(29)		2% WB	5.9	7.8	13.4	18.2	21.6	25.6	28.6	28.2	25.1	20.4	15.3	9.0		(29)
(30)		2% MCDB	7.1	10.4	18.3	23.3	26.4	29.2	32.4	31.3	27.2	22.6	17.5	10.6		(30)
(31)		5% WB	4.6	6.6	11.3	16.6	20.6	24.5	28.0	27.7	23.9	19.2	14.0	7.4		(31)
(32)		5% MCDB	6.2	8.7	15.4	21.2	25.2	27.6	31.5	30.5	26.4	22.0	15.9	9.2		(32)
(33)		10% WB	3.3	5.4	9.7	15.2	19.5	23.3	27.4	27.1	23.0	18.0	12.3	5.9		(33)
(34)		10% MCDB	5.2	7.4	13.3	19.2	24.0	26.5	30.5	29.6	25.6	20.8	15.0	7.9		(34)
(35)	Mean Daily Temperature Range	MDBR	7.4	7.3	8.3	8.6	8.4	6.6	5.3	5.4	6.9	8.2	8.1	7.5		(35)
(36)		5% DB MCDBR	9.3	10.3	12.7	12.4	12.3	10.1	7.4	6.7	8.1	9.6	9.7	9.1		(36)
(37)		5% WB MCWBR	6.4	6.5	6.9	6.4	5.2	3.8	3.0	3.0	3.5	4.7	5.8	6.2		(37)
(38)		5% WB MCDBR	7.6	8.4	11.4	11.1	9.8	7.2	6.6	5.6	6.5	7.3	7.6	7.4		(38)
(39)	Clear-Sky Solar Irradiance	taub	0.539	0.603	0.637	0.640	0.655	0.767	0.735	0.695	0.619	0.642	0.609	0.546		(40)
(41)		taud	1.722	1.631	1.595	1.632	1.639	1.483	1.594	1.657	1.753	1.630	1.645	1.727		(41)
(42)		Ebn at Noon	611	625	653	684	681	608	623	638	661	585	543	570		(42)
(43)		Edh at Noon	184	224	252	253	255	298	265	245	212	221	198	174		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.44	2.97	4.21	4.96	5.34	5.05	4.58	4.47	4.01	3.39	2.56	2.24		(44)
(45)		RadStd	0.28	0.42	0.35	0.39	0.43	0.43	0.50	0.56	0.41	0.38	0.34	0.22		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page