

BOXIAN, China

WMO: 581020

Lat: 33.7914N

Lon: 115.7353E

Elev: 132

StdP: 14.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.9	24.5	-0.9	5.3	32.5	4.2	6.9	32.9	16.0	42.5	14.0	38.8	3.4	340	0.399

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	96.1	78.3	93.9	77.6	91.7	76.8	83.0	91.3	81.8	89.5	80.6	87.6	7.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.8	161.0	88.2	79.7	155.1	87.1	78.6	149.1	85.9	47.3	91.5	45.9	89.5	44.5	87.7	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.6	12.6	11.2	16.4	100.3	3.3	2.1	14.0	101.8	12.1	103.1	10.2	104.3	7.8	105.8
			14.1	84.3	3.1	1.4	11.9	85.3	10.1	86.2	8.3	87.0	6.1	88.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.8	35.3	40.6	50.8	61.6	71.1	79.4	82.8	80.8	73.0	63.5	50.3	39.1
	DBStd	17.53	5.52	6.91	7.57	7.06	5.86	5.01	4.77	4.91	5.35	6.27	7.62	5.74
	HDD50	1243	457	270	82	5	0	0	0	0	1	87	341	
	HDD65	3560	922	682	442	144	15	0	0	5	103	444	803	
	CDD50	5184	0	8	107	354	653	883	1017	956	691	419	94	2
	CDD65	2029	0	0	2	43	203	433	552	491	246	57	2	0
	CDH74	20539	0	1	24	352	1711	4618	6492	5249	1762	320	10	0
	CDH80	8513	0	0	2	73	574	2111	3030	2159	514	50	0	0
Wind	WSAvg	5.5	5.1	5.7	6.5	6.5	6.1	5.7	5.3	5.1	4.8	4.7	5.1	5.0
Precipitation	PrecAvg	31.6	0.6	0.9	1.4	2.0	2.5	3.3	8.6	5.4	3.4	2.0	0.9	0.5
	PrecMax	58.0	2.6	2.8	3.9	6.0	11.2	8.2	22.0	23.3	9.3	5.7	3.6	2.1
	PrecMin	18.6	0.0	0.0	0.0	0.1	0.1	0.2	2.2	0.9	0.2	0.0	0.0	0.0
	PrecStd	8.5	0.7	0.8	0.9	1.8	2.6	2.2	4.7	4.1	2.2	1.7	0.9	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.7	65.2	77.3	86.6	93.5	98.7	99.0	97.0	92.4	84.7	75.2	60.5
		MCWB	44.4	52.1	60.8	69.5	68.1	73.8	80.0	80.6	75.8	65.3	58.8	47.8
	2%	DB	51.9	59.8	71.9	81.6	89.4	95.7	96.4	93.9	88.2	80.8	69.7	54.9
		MCWB	41.3	47.9	57.7	66.1	69.3	73.1	81.0	81.1	73.3	63.0	55.7	45.1
	5%	DB	47.9	55.9	68.0	78.1	86.1	92.9	94.3	91.5	85.3	77.6	65.5	51.3
		MCWB	39.3	45.3	55.2	64.2	68.3	72.4	80.1	80.0	71.4	62.4	53.8	43.1
	10%	DB	44.5	52.2	63.7	74.4	82.9	90.2	91.9	89.2	82.8	74.3	61.6	48.1
		MCWB	37.5	43.3	52.3	61.7	67.5	72.2	79.4	78.6	69.8	61.1	51.8	41.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	54.4	64.5	73.1	75.6	80.9	84.8	84.0	80.6	70.8	62.1	51.1
		MCDB	53.1	63.1	73.6	82.8	83.9	89.2	93.7	92.7	86.8	76.9	71.9	55.7
	2%	WB	43.1	49.9	59.9	69.2	72.8	78.7	83.4	82.8	77.2	67.4	58.2	47.1
		MCDB	49.7	57.3	69.3	78.4	82.6	88.0	92.1	90.7	84.0	74.2	65.6	52.5
	5%	WB	40.5	47.2	56.8	66.1	71.0	77.1	82.3	81.7	75.0	65.5	55.8	44.5
		MCDB	46.4	53.8	65.6	75.1	80.9	86.3	90.6	88.7	80.7	73.2	62.7	49.2
	10%	WB	38.4	44.5	53.6	63.4	69.3	75.4	81.2	80.4	73.0	63.6	53.6	42.4
		MCDB	43.4	50.5	61.8	72.4	79.0	84.9	89.0	86.7	79.5	71.2	60.1	47.0
Mean Daily Temperature Range	5% DB	MDBR	13.8	15.0	16.2	17.1	17.1	16.8	12.9	12.3	14.6	15.9	14.9	13.7
		MCDBR	20.4	21.1	22.0	22.1	22.4	21.5	16.0	14.7	17.9	20.6	21.1	19.5
		MCWBR	12.7	12.1	11.5	11.0	8.6	6.5	5.1	5.1	6.0	7.8	10.6	11.7
	5% WB	MCDBR	17.9	18.4	20.2	20.3	18.0	16.3	14.4	13.2	13.6	15.7	17.0	15.9
		MCWBR	11.8	11.7	11.8	11.7	9.0	6.5	5.6	5.5	6.8	7.6	9.7	10.5
Clear-Sky Solar Irradiance	taub	0.592	0.655	0.662	0.664	0.677	0.792	0.746	0.752	0.702	0.714	0.649	0.595	
	taud	1.623	1.543	1.554	1.579	1.600	1.436	1.558	1.532	1.583	1.513	1.575	1.638	
	Ebn at Noon	181	187	203	212	212	188	196	191	191	171	165	170	
	Edh at Noon	66	79	84	85	84	99	87	88	80	80	69	62	
All-Sky Solar Radiation	RadAvg	707	853	1236	1474	1587	1565	1453	1377	1178	987	765	668	
	RadStd	88	153	114	130	128	139	175	186	171	126	111	96	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+149	N/A
Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page