

SHEYANG, China

WMO: 581500

Lat: 33.7482N

Lon: 120.3008E

Elev: 10

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.4	24.9	6.0	7.5	30.1	10.0	9.2	30.6	20.2	32.9	18.2	35.0	5.5	320	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	93.3	81.4	90.8	80.6	88.5	79.3	83.4	90.5	82.3	88.8	81.1	86.9	8.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.6	164.1	87.9	80.5	158.5	86.9	79.5	153.0	85.5	47.5	90.8	46.3	89.0	45.0	86.9	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.4	16.1	14.2	DB	17.9	96.8	2.9	1.8	15.8	98.1	14.1	99.2	12.5	100.2	10.4	101.5
			WB	15.6	84.9	3.1	1.2	13.4	85.7	11.5	86.4	9.8	87.1	7.5	87.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.3	35.7	39.0	46.6	57.2	67.0	74.3	81.2	80.6	73.0	63.5	51.6	40.2
	DBStd	16.68	5.32	5.79	6.22	6.25	5.15	4.45	4.77	4.21	4.35	5.18	6.63	6.11
	HDD50	1273	443	309	143	10	0	0	0	0	0	0	59	309
	HDD65	3754	908	727	571	246	38	0	0	0	1	89	404	770
	CDD50	4658	0	2	37	226	526	730	967	949	691	420	106	4
	CDD65	1664	0	0	0	12	99	280	502	484	242	44	1	0
	CDH74	14330	0	0	6	114	693	1818	5298	4934	1339	125	3	0
	CDH80	4836	0	0	1	20	182	542	2139	1708	236	8	0	0
(14) Wind	WSAvg	7.0	6.8	7.2	7.9	8.1	7.5	7.2	6.7	6.9	6.2	6.0	6.6	6.7
(15) Precipitation	PrecAvg	40.6	1.0	1.3	1.8	2.2	3.2	4.1	10.6	7.2	4.9	1.9	1.7	0.6
	PrecMax	60.0	3.1	3.3	4.6	4.7	13.9	12.2	24.4	21.5	14.9	6.1	8.9	2.3
	PrecMin	21.1	0.0	0.0	0.3	0.2	0.3	0.4	3.5	2.2	0.4	0.0	0.0	0.0
	PrecStd	9.5	0.7	1.0	1.1	1.3	2.6	2.4	5.6	4.8	3.5	1.5	1.7	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	61.4	72.7	83.1	89.8	93.5	96.7	95.2	89.6	81.0	71.8	59.4
		MCWB	46.8	52.1	58.7	68.7	69.2	75.8	82.7	83.4	80.2	67.4	61.4	51.3
	2%	DB	49.4	55.3	66.2	77.1	84.9	89.3	94.1	92.3	85.0	77.3	67.2	55.1
		MCWB	44.6	47.1	55.2	64.6	68.2	74.4	82.5	82.5	75.9	66.0	59.4	49.6
	5%	DB	46.6	51.2	61.1	72.9	81.0	85.9	91.8	89.8	82.6	74.6	64.5	52.2
		MCWB	42.2	44.8	52.1	62.0	66.7	73.2	81.8	81.4	74.1	65.2	58.1	47.7
	10%	DB	44.1	47.7	56.8	68.9	77.7	82.7	89.3	87.5	80.4	72.2	62.0	49.8
		MCWB	40.4	43.2	49.6	59.0	65.5	72.6	80.9	80.3	72.8	64.2	56.2	45.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	54.1	60.9	71.2	73.8	80.5	85.0	85.0	81.7	72.6	65.6	54.3
		MCDB	51.6	59.4	69.4	79.5	82.0	88.9	92.5	92.3	87.0	75.7	67.9	56.5
	2%	WB	46.0	49.0	56.9	67.1	71.5	78.6	83.6	83.4	79.0	69.8	62.5	51.2
		MCDB	48.4	53.2	63.4	74.5	79.3	84.8	91.2	90.1	82.6	73.6	65.3	53.7
	5%	WB	43.3	46.3	53.6	63.8	69.6	76.8	82.6	82.2	77.0	67.9	59.9	48.5
		MCDB	45.6	49.2	59.4	70.3	76.5	81.6	89.6	88.3	79.9	72.0	63.1	51.3
	10%	WB	41.0	44.1	50.6	60.7	67.7	74.9	81.7	81.1	74.8	65.9	57.1	46.2
		MCDB	43.7	47.1	55.5	66.6	74.6	79.6	88.0	86.4	78.6	70.6	60.6	49.5
(35) Mean Daily Temperature Range	5% DB	MDBR	12.6	13.1	15.3	16.8	16.4	12.7	10.7	10.1	11.8	14.4	14.4	13.3
		MCDBR	17.1	19.4	23.4	24.1	23.6	19.2	14.4	13.1	13.8	17.5	17.6	16.6
		MCWBR	11.4	12.2	13.8	13.2	10.5	7.0	5.7	5.4	5.7	7.6	9.8	10.9
	5% WB	MCDBR	13.2	15.6	20.3	20.5	18.6	13.2	13.3	12.4	10.1	12.3	12.6	13.6
		MCWBR	10.4	11.3	13.6	13.1	10.3	6.7	6.1	5.7	5.8	7.2	8.9	10.4
(40) Clear-Sky Solar Irradiance	taub		0.547	0.609	0.638	0.641	0.646	0.738	0.732	0.682	0.597	0.613	0.607	0.550
	taud		1.717	1.630	1.596	1.639	1.669	1.541	1.605	1.687	1.811	1.689	1.651	1.722
	Ebn at Noon		195	199	208	218	219	199	199	206	217	195	176	184
	Edh at Noon		60	72	80	80	79	89	83	75	64	67	63	56
(44) All-Sky Solar Radiation	RadAvg		743	902	1267	1503	1587	1472	1459	1446	1263	1053	776	685
	RadStd		81	143	119	148	147	153	186	201	121	128	100	80

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page