

SHEYANG, China

WMO: 581500

Lat: 33.7482N

Lon: 120.3008E

Elev: 3

StdP: 101.29

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.3	-4.0	-14.4	1.1	-1.0	-12.2	1.3	-0.8	9.0	0.5	8.2	1.7	2.4	320	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	34.0	27.5	32.7	27.0	31.4	26.3	28.6	32.5	27.9	31.5	27.3	30.5	3.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.5	23.4	31.1	27.0	22.6	30.5	26.4	21.9	29.7	92.6	32.7	89.7	31.7	86.8	30.5	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.2	6.4	-7.8	36.0	1.6	1.0	-9.0	36.7	-9.9	37.3	-10.8	37.9	-12.0	38.6		
(5)			-9.1	29.4	1.7	0.7	-10.4	29.8	-11.4	30.2	-12.3	30.6	-13.6	31.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	2.1	3.9	8.1	14.0	19.4	23.5	27.3	27.0	22.8	17.5	10.9	4.5	(6)
(7)		DBStd	9.27	2.95	3.22	3.45	3.47	2.86	2.47	2.65	2.34	2.42	2.88	3.68	3.39	(7)
(8)		HDD10.0	707	246	172	79	6	0	0	0	0	0	0	33	172	(8)
(9)		HDD18.3	2086	504	404	317	137	21	0	0	0	1	49	224	428	(9)
(10)		CDD10.0	2588	0	1	21	126	292	406	537	527	384	233	59	2	(10)
(11)		CDD18.3	924	0	0	0	7	55	156	279	269	134	24	1	0	(11)
(12)		CDH23.3	7961	0	0	3	63	385	1010	2943	2741	744	69	2	0	(12)
(13)		CDH26.7	2687	0	0	1	11	101	301	1188	949	131	4	0	0	(13)
(14)	Wind	WSAvg	3.1	3.0	3.2	3.5	3.6	3.4	3.2	3.0	3.1	2.8	2.7	2.9	3.0	(14)
(15)	Precipitation	PrecAvg	1030	25	33	46	57	81	104	269	183	124	49	44	16	(15)
(16)		PrecMax	1525	78	83	117	119	352	309	620	546	378	154	225	58	(16)
(17)		PrecMin	535	0	0	7	5	8	11	90	57	9	0	0	0	(17)
(18)		PrecStd	241	19	25	28	33	67	62	141	123	88	37	43	14	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	16.3	22.6	28.4	32.1	34.2	35.9	35.1	32.0	27.2	22.1	15.2	(19)
(20)			MCWB	8.2	11.2	14.8	20.4	20.7	24.3	28.2	28.6	26.8	19.7	16.3	10.7	(20)
(21)		2%	DB	9.7	12.9	19.0	25.1	29.4	31.8	34.5	33.5	29.5	25.2	19.6	12.8	(21)
(22)			MCWB	7.0	8.4	12.9	18.1	20.1	23.5	28.1	28.1	24.4	18.9	15.2	9.8	(22)
(23)		5%	DB	8.1	10.6	16.2	22.7	27.2	29.9	33.2	32.1	28.1	23.7	18.1	11.2	(23)
(24)			MCWB	5.7	7.1	11.2	16.7	19.3	22.9	27.7	27.5	23.4	18.4	14.5	8.7	(24)
(25)		10%	DB	6.7	8.7	13.8	20.5	25.4	28.2	31.8	30.9	26.9	22.3	16.7	9.9	(25)
(26)			MCWB	4.7	6.2	9.8	15.0	18.6	22.6	27.1	26.8	22.7	17.9	13.4	7.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	12.3	16.1	21.8	23.2	27.0	29.4	29.4	27.6	22.5	18.7	12.4	(27)
(28)			MCDWB	10.9	15.2	20.8	26.4	27.8	31.6	33.6	33.5	30.6	24.3	19.9	13.6	(28)
(29)		2%	WB	7.8	9.5	13.8	19.5	21.9	25.9	28.7	28.6	26.1	21.0	17.0	10.7	(29)
(30)			MCDWB	9.1	11.8	17.4	23.6	26.3	29.3	32.9	32.3	28.1	23.1	18.5	12.1	(30)
(31)		5%	WB	6.3	7.9	12.0	17.6	20.9	24.9	28.1	27.9	25.0	19.9	15.5	9.2	(31)
(32)			MCDWB	7.6	9.5	15.2	21.3	24.7	27.6	32.0	31.3	26.6	22.2	17.3	10.7	(32)
(33)		10%	WB	5.0	6.7	10.4	15.9	19.8	23.9	27.6	27.3	23.8	18.8	13.9	7.9	(33)
(34)			MCDWB	6.5	8.4	13.1	19.2	23.7	26.4	31.1	30.2	25.9	21.4	15.9	9.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.0	7.3	8.5	9.4	9.1	7.0	5.9	5.6	6.6	8.0	8.0	7.4	(35)
(36)			MCDBR	9.5	10.8	13.0	13.4	13.1	10.7	8.0	7.3	7.7	9.7	9.8	9.2	(36)
(37)			MCWBR	6.4	6.8	7.6	7.3	5.8	3.9	3.2	3.0	3.2	4.2	5.4	6.1	(37)
(38)		5% WB	MCDBR	7.3	8.7	11.3	11.4	10.3	7.3	7.4	6.9	5.6	6.8	7.0	7.6	(38)
(39)			MCWBR	5.8	6.3	7.5	7.3	5.7	3.7	3.4	3.2	3.2	4.0	5.0	5.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.547	0.609	0.638	0.641	0.646	0.738	0.732	0.682	0.597	0.613	0.607	0.550	(40)	
(41)		taud	1.717	1.630	1.596	1.639	1.669	1.541	1.605	1.687	1.811	1.689	1.651	1.722	(41)	
(42)		Ebn at Noon	615	628	657	686	690	627	627	649	683	616	556	579	(42)	
(43)		Edh at Noon	188	227	253	253	248	281	262	238	201	211	200	178	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.34	2.85	3.99	4.74	5.00	4.64	4.60	4.56	3.98	3.32	2.44	2.16	(44)	
(45)		RadStd	0.26	0.45	0.38	0.47	0.46	0.48	0.59	0.63	0.38	0.40	0.31	0.25	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page