

FUYANG, China

WMO: 582030

Lat: 32.8776N

Lon: 115.7363E

Elev: 33

StdP: 100.93

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.8	-4.1	-15.4	1.0	0.2	-12.8	1.3	0.9	8.4	4.0	7.3	4.5	1.6	0	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	35.4	26.7	34.1	26.1	33.0	25.7	28.8	32.9	28.2	32.1	27.5	31.1	3.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.9	24.0	31.4	27.2	23.1	30.7	26.6	22.2	30.0	94.4	33.1	91.4	32.1	88.2	31.2	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.4	5.5	-9.1	37.3	2.3	1.1	-10.8	38.1	-12.1	38.7	-13.4	39.3	-15.1	40.1		
(5)			-10.0	29.4	2.2	0.9	-11.6	30.0	-12.9	30.5	-14.1	31.0	-15.7	31.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	2.2	5.1	10.5	16.3	21.6	25.8	28.1	27.1	22.8	17.5	10.5	4.5
	DBStd	9.52	3.30	3.86	4.11	3.93	3.22	2.65	2.61	2.79	2.94	3.43	4.09	3.29
	HDD10.0	644	241	142	44	3	0	0	0	0	0	0	41	173
	HDD18.3	1931	499	370	246	84	8	0	0	0	2	57	234	429
	CDD10.0	2858	1	6	58	191	358	474	562	531	386	233	57	2
	CDD18.3	1103	0	0	2	22	108	224	304	273	138	31	1	0
	CDH23.3	10964	0	1	14	196	919	2214	3521	2901	991	197	10	0
CDH26.7	4447	0	0	1	44	313	933	1616	1207	297	36	1	0	
Wind	WSAvg	2.6	2.6	2.8	3.1	2.9	2.7	2.6	2.4	2.4	2.3	2.2	2.5	2.6
Precipitation	PrecAvg	876	22	33	50	63	84	123	195	100	95	59	37	15
	PrecMax	1340	76	100	123	186	182	297	398	297	367	185	105	55
	PrecMin	493	0	0	1	13	7	26	27	21	2	0	0	0
	PrecStd	197	19	26	30	47	46	79	108	69	76	53	32	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.7	19.3	25.3	30.4	34.0	36.4	36.9	36.2	34.1	29.8	24.8	16.9
		MCWB	8.4	12.1	17.8	21.4	20.8	23.7	27.6	27.3	24.9	19.4	15.0	9.4
	2%	DB	11.8	15.9	22.2	27.8	32.0	34.4	35.6	34.5	31.4	27.4	21.7	13.6
		MCWB	6.4	9.6	15.1	19.8	21.4	23.5	27.7	27.8	23.8	18.7	13.7	8.0
	5%	DB	9.7	13.6	20.0	25.5	30.1	33.1	34.4	33.3	29.7	25.5	19.2	11.6
		MCWB	5.3	8.4	13.9	18.5	21.3	23.5	27.5	27.2	22.6	17.3	13.1	7.1
	10%	DB	7.7	11.5	17.6	23.5	28.2	31.6	33.1	31.9	28.2	23.7	17.0	9.7
		MCWB	4.2	7.3	12.0	17.2	20.3	23.2	27.1	26.7	21.8	17.1	11.8	6.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	13.9	19.4	23.2	25.0	27.8	29.7	29.6	27.3	22.5	17.7	11.4
		MCDB	12.8	18.1	23.3	28.2	28.7	32.2	33.8	33.6	32.2	25.3	22.0	13.9
	2%	WB	7.5	11.0	16.4	21.2	23.4	26.6	29.1	28.8	26.0	20.6	15.5	9.3
		MCDB	10.7	14.6	20.8	25.9	28.0	30.5	33.4	32.5	29.0	24.4	19.1	12.2
	5%	WB	6.0	9.4	14.6	19.7	22.5	25.7	28.5	28.2	24.8	19.4	14.0	7.9
		MCDB	8.9	12.5	18.9	24.1	27.4	29.7	32.6	31.6	27.5	23.2	17.5	10.4
	10%	WB	4.7	7.9	12.8	18.2	21.6	24.8	27.8	27.5	23.6	18.3	12.8	6.7
		MCDB	7.2	10.7	16.5	22.3	26.3	29.0	31.8	30.6	26.4	22.0	16.2	9.1
Mean Daily Temperature Range	5% DB	MDBR	7.8	8.1	9.0	9.8	9.8	8.8	6.9	6.9	8.3	9.3	9.0	8.2
		MCDBR	11.7	12.2	12.7	12.9	13.0	11.6	8.7	8.4	10.4	12.3	12.6	11.9
		MCWBR	7.4	7.3	7.1	6.8	4.9	3.6	2.9	3.1	3.6	4.8	6.2	6.9
	5% WB	MCDBR	10.5	10.3	11.5	11.2	10.4	8.7	7.9	7.4	7.9	9.2	9.9	9.6
		MCWBR	7.1	6.8	7.1	6.8	5.4	3.7	3.3	3.2	3.8	4.5	5.5	6.2
Clear-Sky Solar Irradiance	taub	0.616	0.674	0.680	0.677	0.689	0.776	0.731	0.742	0.711	0.716	0.659	0.615	
	taud	1.588	1.519	1.523	1.569	1.594	1.473	1.591	1.557	1.576	1.513	1.565	1.610	
	Ebn at Noon	560	582	630	662	661	604	629	611	602	543	522	529	
	Edh at Noon	218	257	274	272	268	301	267	272	257	255	221	203	
All-Sky Solar Radiation	RadAvg	2.17	2.56	3.78	4.49	4.79	4.71	4.61	4.30	3.66	3.05	2.40	2.09	
	RadStd	0.29	0.50	0.35	0.45	0.41	0.47	0.58	0.57	0.55	0.42	0.35	0.33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page