

GUSHI, China

WMO: 582080

Lat: 32.1717N

Lon: 115.6238E

Elev: 144

StdP: 14.62

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.4	26.7	8.1	8.4	35.6	12.7	10.5	35.1	15.3	42.5	13.4	40.5	3.4	200	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	95.2	81.2	93.1	80.3	90.9	78.9	83.2	91.7	82.2	90.4	81.1	88.6	6.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	161.5	88.5	79.9	156.2	87.5	79.0	151.2	86.4	47.4	92.0	46.3	90.6	45.1	88.7	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.3	12.2	10.8	DB	20.1	98.6	3.3	1.9	17.7	100.0	15.8	101.1	13.9	102.2	11.5	103.6	
			WB	18.2	84.8	3.1	1.0	15.9	85.5	14.1	86.1	12.4	86.6	10.1	87.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.7	37.3	42.1	52.1	62.8	71.9	77.7	83.0	81.3	73.9	64.2	52.2	41.3
	DBStd	16.79	5.99	6.88	7.82	7.33	5.66	4.55	4.67	5.20	5.49	6.10	7.22	5.74
	HDD50	1032	396	233	67	4	0	0	0	0	0	0	56	276
	HDD65	3254	859	641	406	124	10	0	0	0	4	89	385	736
	CDD50	5319	2	12	132	387	677	831	1022	970	718	440	123	5
	CDD65	2065	0	0	5	57	222	382	557	505	271	64	2	0
	CDH74	19827	0	1	55	485	1672	3355	6519	5434	1932	355	19	0
	CDH80	7709	0	0	8	129	518	1142	2976	2272	593	70	1	0
(14) Wind	WSAvg	5.1	5.1	5.7	6.3	5.9	5.4	5.0	4.8	4.7	4.7	4.4	4.8	4.9
(15) Precipitation	PrecAvg	42.6	1.1	1.7	2.7	3.6	4.3	5.8	8.7	4.9	4.1	2.8	2.2	0.9
	PrecMax	59.1	4.2	4.5	7.5	11.1	10.6	17.6	25.0	14.2	9.7	10.2	7.2	2.9
	PrecMin	21.4	0.0	0.0	0.3	0.6	0.7	0.9	2.3	0.2	0.0	0.0	0.1	0.0
	PrecStd	9.7	0.8	1.2	1.6	2.4	2.4	4.3	4.8	3.3	2.5	2.5	1.9	0.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.5	67.6	79.7	88.3	92.4	94.4	98.3	98.3	93.8	86.2	76.8	63.7
		MCWB	48.1	53.8	63.0	67.4	69.9	77.8	82.6	79.8	77.3	67.7	59.6	49.3
	2%	DB	54.4	61.6	73.9	83.6	88.9	91.2	95.8	94.7	89.3	81.6	71.7	57.6
		MCWB	44.3	50.1	58.4	66.2	70.4	77.3	82.1	81.7	74.9	66.1	57.3	46.1
	5%	DB	50.2	57.2	69.2	79.6	85.6	88.7	93.8	92.3	85.9	77.9	67.4	53.8
		MCWB	42.4	48.0	56.5	64.3	69.5	76.1	81.7	80.9	73.5	63.7	55.8	45.2
	10%	DB	46.7	53.2	65.1	75.5	82.5	86.4	91.6	89.7	83.1	74.6	63.5	50.5
		MCWB	40.5	45.7	54.1	62.2	68.8	75.0	81.0	80.0	71.9	63.1	54.2	43.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.5	57.2	66.4	72.8	76.6	81.5	84.6	84.4	80.6	72.7	63.7	52.0
		MCDB	57.0	64.4	75.2	82.4	85.3	89.6	93.3	93.2	90.0	78.6	70.2	56.7
	2%	WB	46.3	52.3	61.1	69.3	74.5	79.9	83.6	83.0	78.7	69.0	60.6	49.2
		MCDB	52.1	59.2	70.6	78.7	82.1	87.9	92.4	91.0	85.6	75.7	66.6	55.0
	5%	WB	43.6	49.3	58.2	66.8	72.8	78.5	82.6	81.9	76.8	67.1	58.1	46.9
		MCDB	48.9	54.9	66.9	76.0	80.3	85.3	91.5	89.4	82.5	73.9	64.3	51.9
	10%	WB	41.2	46.9	55.5	64.2	70.9	77.1	81.7	80.9	74.9	65.2	55.8	44.8
		MCDB	45.8	51.9	62.6	72.4	78.8	83.6	89.9	87.8	80.0	71.9	62.1	49.5
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	12.6	15.0	16.0	14.7	12.2	11.5	11.4	13.0	14.5	14.9	13.2
		MCDBR	20.2	21.2	22.5	23.0	20.3	16.4	15.1	14.9	17.2	20.6	22.5	21.2
		MCWBR	11.9	11.7	10.6	9.6	7.3	6.3	5.2	5.1	5.7	7.4	10.0	11.5
	5% WB	MCDBR	17.7	17.8	19.9	18.8	15.3	13.6	14.1	13.4	13.6	15.2	16.4	16.6
		MCWBR	11.2	10.9	10.7	9.8	7.2	6.1	5.8	5.4	6.0	7.1	8.5	10.0
(40) Clear-Sky Solar Irradiance	taub		0.632	0.688	0.702	0.697	0.698	0.759	0.709	0.734	0.718	0.711	0.664	0.623
	taud		1.560	1.497	1.494	1.549	1.586	1.509	1.635	1.575	1.568	1.520	1.557	1.594
	Ebn at Noon		175	183	196	206	208	195	204	196	190	175	166	168
	Edh at Noon		72	84	90	88	86	92	81	85	82	81	71	66
(44) All-Sky Solar Radiation	RadAvg		679	787	1169	1386	1471	1442	1470	1356	1165	965	775	663
(45)	RadStd		98	171	104	147	134	143	183	177	169	138	109	112

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page