

GUSHI, China

WMO: 582080

Lat: 32.1717N

Lon: 115.6238E

Elev: 44

StdP: 100.80

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.2	-2.9	-13.3	1.2	2.0	-10.7	1.5	1.7	6.8	5.8	6.0	4.7	1.5	200	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.4	35.1	27.3	34.0	26.9	32.7	26.1	28.4	33.2	27.9	32.5	27.3	31.4	2.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	23.1	31.4	26.6	22.3	30.8	26.1	21.6	30.2	92.5	33.3	89.8	32.6	87.0	31.5	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.4	5.5	4.8	-6.6	37.0	1.8	1.1	-7.9	37.8	-9.0	38.4	-10.0	39.0	-11.4	39.8		
			-7.7	29.3	1.7	0.5	-8.9	29.7	-9.9	30.0	-10.9	30.4	-12.2	30.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	2.9	5.6	11.2	17.1	22.1	25.4	28.3	27.4	23.3	17.9	11.2	5.1
	DBStd	9.33	3.33	3.82	4.34	4.07	3.14	2.53	2.60	2.89	3.05	3.39	4.01	3.19
	HDD10.0	573	220	129	37	2	0	0	0	0	0	0	31	153
	HDD18.3	1808	477	356	226	69	6	0	0	0	2	49	214	409
	CDD10.0	2955	1	7	73	215	376	462	568	539	399	244	68	3
	CDD18.3	1147	0	0	3	32	123	212	309	281	151	36	1	0
	CDH23.3	11015	0	1	31	269	929	1864	3622	3019	1073	197	11	0
	CDH26.7	4283	0	0	4	72	288	634	1653	1262	329	39	1	0
Wind	WSAvg	2.3	2.3	2.6	2.8	2.6	2.4	2.2	2.1	2.1	2.1	2.0	2.1	2.2
Precipitation	PrecAvg	1081	28	42	68	91	109	147	220	124	103	70	57	23
	PrecMax	1501	107	114	191	283	268	446	636	361	246	260	184	74
	PrecMin	544	0	0	7	15	17	22	58	4	1	0	2	0
	PrecStd	247	21	30	40	60	62	110	122	84	64	63	48	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	19.8	26.5	31.3	33.6	34.7	36.8	36.8	34.3	30.1	24.9	17.6
		MCWB	8.9	12.1	17.2	19.7	21.1	25.5	28.1	26.6	25.2	19.8	15.3	9.6
	2%	DB	12.5	16.5	23.3	28.7	31.6	32.9	35.5	34.8	31.8	27.5	22.1	14.2
		MCWB	6.8	10.1	14.6	19.0	21.3	25.1	27.8	27.6	23.8	19.0	14.1	7.8
	5%	DB	10.1	14.0	20.7	26.4	29.8	31.5	34.4	33.5	30.0	25.5	19.7	12.1
		MCWB	5.8	8.9	13.6	18.0	20.8	24.5	27.6	27.2	23.0	17.6	13.2	7.3
	10%	DB	8.2	11.8	18.4	24.2	28.1	30.2	33.1	32.1	28.4	23.7	17.5	10.3
		MCWB	4.7	7.6	12.3	16.8	20.4	23.9	27.2	26.7	22.2	17.3	12.3	6.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	14.0	19.1	22.6	24.8	27.5	29.2	29.1	27.0	22.6	17.6	11.1
		MCDB	13.9	18.0	24.0	28.0	29.6	32.0	34.0	34.0	32.2	25.9	21.2	13.7
	2%	WB	7.9	11.3	16.2	20.7	23.6	26.6	28.6	28.3	25.9	20.6	15.9	9.6
		MCDB	11.2	15.1	21.5	25.9	27.8	31.0	33.6	32.8	29.8	24.3	19.2	12.8
	5%	WB	6.4	9.6	14.6	19.3	22.7	25.8	28.1	27.7	24.9	19.5	14.5	8.3
		MCDB	9.4	12.7	19.4	24.4	26.9	29.6	33.1	31.9	28.0	23.3	17.9	11.1
	10%	WB	5.1	8.3	13.1	17.9	21.6	25.0	27.6	27.2	23.8	18.5	13.2	7.1
		MCDB	7.6	11.1	17.0	22.4	26.0	28.7	32.2	31.0	26.7	22.2	16.7	9.7
Mean Daily Temperature Range	5% DB	MDBR	6.8	7.0	8.3	8.9	8.2	6.8	6.4	6.3	7.2	8.0	8.3	7.3
		MCDBR	11.2	11.8	12.5	12.8	11.3	9.1	8.4	8.3	9.6	11.5	12.5	11.8
		MCWBR	6.6	6.5	5.9	5.3	4.1	3.5	2.9	2.8	3.2	4.1	5.5	6.4
	5% WB	MCDBR	9.8	9.9	11.0	10.4	8.5	7.6	7.8	7.5	7.5	8.5	9.1	9.2
		MCWBR	6.2	6.0	5.9	5.5	4.0	3.4	3.2	3.0	3.3	3.9	4.7	5.6
Clear-Sky Solar Irradiance	taub	0.632	0.688	0.702	0.697	0.698	0.759	0.709	0.734	0.718	0.711	0.664	0.623	
	taud	1.560	1.497	1.494	1.549	1.586	1.509	1.635	1.575	1.568	1.520	1.557	1.594	
	Ebn at Noon	553	576	617	650	656	616	644	618	600	551	524	530	
	Edh at Noon	226	265	284	278	270	291	255	268	260	254	225	209	
All-Sky Solar Radiation	RadAvg	2.14	2.48	3.69	4.37	4.64	4.55	4.63	4.28	3.67	3.04	2.44	2.09	
	RadStd	0.31	0.54	0.33	0.46	0.42	0.45	0.58	0.56	0.53	0.43	0.34	0.35	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page