

BENGBU, ChinaWMO: **582210**Lat: **32.8520N**Lon: **117.3207E**Elev: **92**StdP: **14.65**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.5	26.0	3.9	6.7	32.9	8.7	8.6	33.5	17.1	38.2	15.6	39.0	4.0	340	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	96.1	79.9	93.9	79.2	91.5	77.9	83.1	91.4	82.1	90.0	81.0	88.6	7.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.0	161.7	88.2	79.9	155.9	87.4	78.9	150.6	86.4	47.3	91.9	46.1	90.2	45.0	88.8	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.1	14.0	12.2	DB	18.7	99.4	3.0	2.2	16.6	101.0	14.8	102.3	13.1	103.5	10.9	105.1	(4)
(5)			WB	16.2	84.3	3.1	1.6	14.0	85.5	12.2	86.4	10.5	87.2	8.2	88.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.4	36.8	41.4	50.4	61.7	71.2	78.2	83.2	81.5	73.9	64.5	52.0	40.7
	DBStd	17.12	5.79	6.94	7.36	6.92	5.87	5.04	4.98	5.10	5.05	5.90	7.36	5.90
	HDD50	1104	409	252	85	4	0	0	0	0	0	0	61	293
	HDD65	3373	873	660	454	143	14	0	0	0	2	80	394	753
	CDD50	5272	1	12	98	354	658	847	1031	978	718	450	120	5
	CDD65	2067	0	0	2	43	207	397	566	513	271	65	3	0
	CDH74	20457	0	1	25	357	1684	3850	6755	5612	1834	323	16	0
	CDH80	8323	0	0	2	84	568	1570	3162	2368	514	54	1	0
Wind	WSAvg	6.0	5.7	6.3	7.0	6.7	6.4	6.3	5.9	5.8	5.6	5.3	5.5	5.5
Precipitation	PrecAvg	38.1	1.1	1.5	2.4	2.2	3.2	5.8	8.4	5.6	3.2	1.9	1.7	1.0
	PrecMax	58.1	3.7	3.4	8.1	5.7	8.6	15.4	18.6	11.3	7.2	8.8	5.3	3.1
	PrecMin	24.2	0.0	0.3	0.2	0.3	0.2	1.3	3.4	1.4	0.0	0.0	0.0	0.0
	PrecStd	8.4	1.0	0.9	1.7	1.3	2.1	3.7	4.3	2.5	2.1	2.0	1.4	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.8	67.0	77.4	87.6	93.6	97.3	99.1	98.6	93.4	84.9	76.2	62.1
		MCWB	47.6	53.8	61.1	69.4	69.5	74.5	81.4	81.1	78.4	67.0	58.7	49.8
	2%	DB	53.3	60.7	71.6	82.1	89.5	93.8	96.8	94.8	88.3	80.9	70.3	56.6
		MCWB	44.2	49.5	58.2	66.4	68.5	73.9	81.4	81.6	75.5	65.7	57.3	47.6
	5%	DB	49.4	56.2	67.2	78.0	86.1	90.9	94.5	92.4	85.2	77.5	66.5	53.0
		MCWB	42.0	47.0	55.7	63.6	67.4	73.0	81.2	80.7	73.8	63.9	55.9	45.6
	10%	DB	45.9	52.2	62.7	74.1	82.8	88.3	92.0	89.7	82.6	74.4	63.1	49.8
		MCWB	40.3	45.0	52.2	61.7	66.9	72.9	80.4	79.9	71.7	62.7	54.3	44.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	57.2	66.0	72.9	75.2	80.7	84.9	84.4	81.5	72.7	63.9	52.9
		MCDB	55.2	63.7	72.4	81.5	83.3	88.3	93.6	92.8	90.1	79.4	68.6	57.0
	2%	WB	46.0	51.8	60.3	69.3	72.9	79.0	83.5	82.9	78.9	69.3	60.9	49.6
		MCDB	50.9	57.4	68.5	78.1	81.6	87.1	92.2	90.6	84.9	75.0	66.9	54.9
	5%	WB	43.3	48.6	56.9	66.0	71.3	77.5	82.6	81.9	76.8	67.2	58.1	47.1
		MCDB	47.8	54.2	64.4	74.8	79.9	85.2	91.1	89.2	82.3	73.4	63.4	51.4
	10%	WB	41.0	46.1	53.9	63.4	69.7	76.1	81.6	80.9	74.7	65.3	55.7	45.0
		MCDB	45.5	51.1	60.9	71.2	78.9	83.8	89.7	88.0	80.1	71.6	61.7	48.8
Mean Daily Temperature Range	5% DB	MDBR	13.1	13.7	15.5	16.3	16.6	14.4	11.5	11.3	13.2	14.7	14.7	13.6
		MCDBR	19.9	20.8	22.5	22.3	22.3	19.1	14.7	14.3	16.2	19.6	20.1	19.3
		MCWBR	12.4	12.2	12.1	10.5	8.0	5.8	4.7	4.6	5.7	7.5	9.7	11.3
	5% WB	MCDBR	17.0	17.1	20.3	19.0	17.8	13.9	13.7	12.5	13.1	14.9	15.2	15.6
		MCWBR	11.5	11.2	12.5	10.9	9.0	5.5	5.4	5.0	6.1	7.4	8.8	10.3
Clear-Sky Solar Irradiance	taub		0.596	0.657	0.672	0.670	0.682	0.776	0.738	0.731	0.691	0.697	0.642	0.599
	taud		1.624	1.549	1.543	1.589	1.606	1.473	1.583	1.582	1.614	1.547	1.594	1.640
	Ebn at Noon		183	189	202	212	211	192	198	196	195	177	170	173
	Edh at Noon		67	79	85	85	84	95	85	84	78	78	68	62
All-Sky Solar Radiation	RadAvg		715	832	1209	1445	1542	1469	1476	1386	1198	1008	777	682
	RadStd		89	161	110	152	145	158	176	190	161	144	102	98