

LUSI, China

WMO: 582650

Lat: 32.0997N

Lon: 121.5446E

Elev: 33

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.1	29.2	12.4	10.3	32.7	16.2	12.5	33.0	20.9	36.7	18.8	36.6	7.0	290	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	93.4	81.4	90.9	80.7	88.7	80.1	83.1	89.6	82.0	88.3	81.1	86.9	8.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.5	164.1	86.8	80.5	158.3	85.9	79.5	153.5	85.0	47.3	90.2	46.0	88.6	45.0	87.2	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	16.6	14.9	23.5	97.1	3.0	1.7	21.4	98.4	19.6	99.4	18.0	100.4	15.8	101.6
			20.7	85.0	3.3	1.2	18.3	85.9	16.4	86.6	14.5	87.3	12.1	88.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.1	39.1	41.6	48.4	57.7	67.1	74.0	82.1	81.7	75.1	66.1	55.5	43.9	(6)
(7)		DBStd	15.81	5.52	5.72	6.16	6.14	5.09	4.74	4.80	3.88	4.29	4.74	6.51	6.32	(7)
(8)		HDD50	923	341	243	104	7	0	0	0	0	0	23	205		(8)
(9)		HDD65	3225	803	656	513	232	34	0	0	0	43	291	653		(9)
(10)		CDD50	4989	3	7	55	239	531	719	995	983	754	500	187	16	(10)
(11)		CDD65	1817	0	0	0	13	100	269	530	518	304	78	5	0	(11)
(12)		CDH74	15511	0	0	5	82	493	1497	5866	5607	1822	134	5	0	(12)
(13)		CDH80	5206	0	0	0	13	116	417	2385	1941	322	12	0	0	(13)
(14)	Wind	WSAvg	7.6	7.5	7.8	8.2	7.8	7.7	7.3	7.4	7.9	7.7	7.1	7.3	7.4	(14)
(15)	Precipitation	PrecAvg	40.8	1.3	1.8	2.4	3.3	4.1	5.9	6.6	5.0	5.1	2.2	2.1	1.2	(15)
(16)		PrecMax	56.1	3.3	3.8	4.9	7.2	11.3	13.2	19.6	17.3	15.5	7.2	4.8	3.9	(16)
(17)		PrecMin	18.6	0.0	0.3	0.6	1.1	1.5	1.1	1.1	0.3	0.2	0.1	0.0	0.0	(17)
(18)		PrecStd	8.8	0.8	1.0	1.1	1.7	2.1	2.9	4.7	3.7	3.6	2.1	1.4	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.3	63.2	72.4	81.7	88.1	92.9	97.1	96.0	91.2	81.0	73.6	62.9	(19)
(20)		0.4%	MCWB	52.7	55.6	60.3	67.5	69.5	78.5	81.7	82.8	80.2	71.3	65.7	57.4	(20)
(21)		2%	DB	52.8	57.5	66.6	75.8	83.1	88.3	94.4	92.1	86.4	77.2	69.8	58.6	(21)
(22)		2%	MCWB	48.7	52.3	57.1	65.1	68.9	76.5	81.6	81.8	78.5	70.1	63.3	53.9	(22)
(23)		5%	DB	49.4	53.4	61.7	71.3	79.3	84.7	92.1	89.8	83.2	75.0	67.2	55.6	(23)
(24)		5%	MCWB	46.0	48.6	54.9	62.4	67.3	75.4	81.3	81.1	76.9	68.5	61.9	51.5	(24)
(25)		10%	DB	46.7	49.5	58.1	67.7	75.9	81.5	89.7	87.7	81.1	73.1	64.6	52.9	(25)
(26)		10%	MCWB	43.8	45.9	52.5	60.7	66.4	74.5	80.9	80.5	75.4	66.6	60.2	49.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.8	58.0	62.5	71.0	75.9	81.0	85.0	84.4	81.9	76.0	69.2	59.6	(27)
(28)		0.4%	MCDWB	57.3	61.5	68.6	77.4	82.1	88.6	91.8	90.7	88.4	78.7	71.6	61.3	(28)
(29)		2%	WB	49.8	52.9	59.1	67.3	72.6	79.2	83.5	83.0	80.0	72.5	65.8	55.3	(29)
(30)		2%	MCDWB	51.9	56.5	63.7	72.5	77.4	85.5	90.2	89.1	84.3	75.3	68.2	57.5	(30)
(31)		5%	WB	46.8	49.3	56.2	64.8	70.5	77.6	82.4	82.1	78.6	70.0	63.1	52.3	(31)
(32)		5%	MCDWB	48.8	52.3	61.0	69.7	75.2	82.5	89.1	87.8	82.1	73.3	65.7	54.9	(32)
(33)		10%	WB	44.1	46.6	53.2	62.0	68.7	75.9	81.4	81.2	76.9	68.2	60.8	49.7	(33)
(34)		10%	MCDWB	46.3	49.1	56.8	66.4	73.2	79.8	87.9	86.3	80.4	71.9	63.6	52.4	(34)
(35)	Mean Daily Temperature Range		MDBR	9.4	9.6	11.4	13.0	12.6	9.4	9.7	8.7	8.6	9.7	10.8	10.5	(35)
(36)		5% DB	MCDBR	14.2	16.8	19.2	20.2	19.0	15.0	13.8	12.0	11.0	11.7	13.2	13.5	(36)
(37)		5% DB	MCWBR	9.9	11.2	11.3	10.9	8.2	5.9	5.0	4.6	4.9	5.9	7.6	9.4	(37)
(38)		5% WB	MCDBR	11.3	14.0	16.5	16.6	14.3	11.9	12.2	10.7	9.8	9.1	9.8	10.4	(38)
(39)	5% WB	MCWBR	9.2	10.8	11.6	11.1	8.5	5.9	5.4	4.9	4.9	6.3	7.9	9.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.569	0.615	0.647	0.654	0.642	0.714	0.705	0.646	0.580	0.585	0.598	0.568	(40)	
(41)		taud	1.697	1.640	1.602	1.641	1.705	1.615	1.675	1.781	1.885	1.776	1.695	1.712	(41)	
(42)		Ebn at Noon	194	201	209	216	220	204	205	215	223	207	184	184	(42)	
(43)		Edh at Noon	62	73	81	81	76	83	78	69	60	62	62	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	723	859	1213	1426	1518	1348	1569	1536	1279	1076	790	685	(44)	
(45)		RadStd	88	149	108	154	153	185	199	231	114	140	97	85	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+200	+137	(46)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page