

LUSI, China

WMO: 582650

Lat: 32.0997N

Lon: 121.5446E

Elev: 10

StdP: 101.20

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.7	-1.5	-10.9	1.5	0.4	-8.8	1.8	0.5	9.3	2.6	8.4	2.6	3.1	290	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	34.1	27.4	32.7	27.1	31.5	26.7	28.4	32.0	27.8	31.3	27.3	30.5	3.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.5	23.4	30.5	26.9	22.6	29.9	26.4	21.9	29.5	92.0	32.3	89.2	31.4	86.8	30.7	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.4	7.4	6.7	-4.7	36.2	1.6	1.0	-5.9	36.9	-6.9	37.4	-7.8	38.0	-9.0	38.7
			-6.3	29.4	1.8	0.7	-7.6	29.9	-8.7	30.3	-9.7	30.7	-11.1	31.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	3.9	5.3	9.1	14.3	19.5	23.3	27.8	27.6	24.0	19.0	13.0	6.6	(6)
(7)		DBStd	8.79	3.07	3.18	3.42	3.41	2.83	2.63	2.67	2.16	2.38	2.63	3.62	3.51	(7)
(8)		HDD10.0	513	189	135	58	4	0	0	0	0	0	13	114		(8)
(9)		HDD18.3	1792	446	364	285	129	19	0	0	0	24	162	363		(9)
(10)		CDD10.0	2772	2	4	31	133	295	399	553	546	419	278	104	9	(10)
(11)		CDD18.3	1009	0	0	0	7	56	149	294	288	169	43	3	0	(11)
(12)		CDH23.3	8617	0	0	3	46	274	832	3259	3115	1012	74	3	0	(12)
(13)	CDH26.7	2892	0	0	0	7	64	232	1325	1078	179	7	0	0	(13)	
(14)	Wind	WSAvg	3.4	3.3	3.5	3.7	3.5	3.4	3.2	3.3	3.5	3.4	3.2	3.3	3.3	(14)
(15)	Precipitation	PrecAvg	1037	33	45	61	84	103	149	168	127	129	55	53	30	(15)
(16)		PrecMax	1424	83	97	125	184	287	336	498	440	393	184	122	98	(16)
(17)		PrecMin	472	0	8	15	28	39	28	28	7	6	2	0	0	(17)
(18)		PrecStd	224	21	25	27	43	53	73	120	94	92	53	35	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.1	17.4	22.4	27.6	31.2	33.9	36.2	35.6	32.9	27.2	23.1	17.1	(19)
(20)			MCWB	11.5	13.1	15.7	19.7	20.8	25.8	27.6	28.2	26.8	21.8	18.7	14.1	(20)
(21)		2%	DB	11.5	14.2	19.2	24.3	28.4	31.3	34.7	33.4	30.2	25.1	21.0	14.8	(21)
(22)			MCWB	9.3	11.3	13.9	18.4	20.5	24.7	27.6	27.6	25.8	21.2	17.4	12.2	(22)
(23)		5%	DB	9.7	11.9	16.5	21.8	26.3	29.3	33.4	32.1	28.4	23.9	19.5	13.1	(23)
(24)			MCWB	7.8	9.2	12.7	16.9	19.6	24.1	27.4	27.3	24.9	20.3	16.6	10.8	(24)
(25)		10%	DB	8.2	9.7	14.5	19.8	24.4	27.5	32.0	31.0	27.3	22.8	18.1	11.6	(25)
(26)			MCWB	6.6	7.7	11.4	15.9	19.1	23.6	27.2	26.9	24.1	19.2	15.6	9.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	14.4	16.9	21.7	24.4	27.2	29.4	29.1	27.7	24.4	20.7	15.4	(27)
(28)			MCDWB	14.0	16.4	20.3	25.2	27.9	31.4	33.2	32.6	31.3	26.0	22.0	16.3	(28)
(29)		2%	WB	9.9	11.6	15.1	19.6	22.5	26.2	28.6	28.4	26.7	22.5	18.8	12.9	(29)
(30)			MCDWB	11.0	13.6	17.6	22.5	25.2	29.7	32.3	31.7	29.1	24.1	20.1	14.2	(30)
(31)		5%	WB	8.2	9.6	13.5	18.2	21.4	25.3	28.0	27.8	25.9	21.1	17.3	11.3	(31)
(32)			MCDWB	9.3	11.3	16.1	21.0	24.0	28.0	31.7	31.0	27.9	23.0	18.7	12.7	(32)
(33)		10%	WB	6.7	8.1	11.8	16.7	20.4	24.4	27.5	27.3	24.9	20.1	16.0	9.9	(33)
(34)			MCDWB	7.9	9.5	13.8	19.1	22.9	26.6	31.0	30.2	26.9	22.2	17.5	11.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.2	5.3	6.4	7.2	7.0	5.2	5.4	4.8	4.8	5.4	6.0	5.8	(35)
(36)			MCDBR	7.9	9.3	10.7	11.2	10.5	8.3	7.6	6.7	6.1	6.5	7.3	7.5	(36)
(37)			MCWBR	5.5	6.2	6.3	6.0	4.6	3.3	2.8	2.5	2.7	3.3	4.2	5.2	(37)
(38)		5% WB	MCDWR	6.3	7.8	9.2	9.2	7.9	6.6	6.8	6.0	5.5	5.1	5.5	5.8	(38)
(39)			MCWBR	5.1	6.0	6.4	6.2	4.7	3.3	3.0	2.7	2.7	3.5	4.4	5.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.569	0.615	0.647	0.654	0.642	0.714	0.705	0.646	0.580	0.585	0.598	0.568	(40)	
(41)		taud	1.697	1.640	1.602	1.641	1.705	1.615	1.675	1.781	1.885	1.776	1.695	1.712	(41)	
(42)		Ebn at Noon	611	635	658	680	695	644	647	679	704	652	581	581	(42)	
(43)		Edh at Noon	197	229	254	254	240	262	245	218	189	196	196	185	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.28	2.71	3.82	4.49	4.79	4.25	4.95	4.84	4.03	3.39	2.49	2.16	(44)	
(45)		RadStd	0.28	0.47	0.34	0.48	0.48	0.58	0.63	0.73	0.36	0.44	0.31	0.27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.35	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+111	+76
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page