

HEFEI, China

WMO: 583210

Lat: 31.9555N

Lon: 117.0574E

Elev: 52

StdP: 100.70

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.2	-2.9	-13.2	1.2	1.6	-10.8	1.5	1.6	7.8	3.5	7.0	4.7	1.8	290	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	35.9	27.8	34.7	27.4	33.3	26.8	29.0	33.7	28.4	32.9	27.7	31.9	3.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.9	24.1	31.9	27.1	23.0	31.2	26.7	22.4	30.7	95.1	33.6	92.2	33.2	89.3	32.4	31.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.2	6.3	5.4	-7.1	37.8	2.1	1.3	-8.6	38.7	-9.9	39.4	-11.1	40.2	-12.6	41.1		
			-8.1	29.9	2.1	0.7	-9.6	30.4	-10.8	30.9	-12.0	31.3	-13.5	31.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	3.2	5.6	10.7	16.8	22.2	25.6	29.0	28.2	23.8	18.2	11.5	5.5
	DBStd	9.45	3.22	3.91	4.15	3.78	3.14	2.64	2.73	2.84	2.83	3.26	3.94	3.28
	HDD10.0	556	211	130	41	2	0	0	0	0	0	27	144	
	HDD18.3	1786	469	355	237	72	5	0	0	1	42	206	399	
	CDD10.0	3021	1	8	64	206	377	468	589	563	414	254	73	3
	CDD18.3	1210	0	0	2	26	123	218	331	304	165	38	2	0
	CDH23.3	12359	0	1	23	212	992	2051	4109	3508	1235	216	11	0
	CDH26.7	5211	0	0	3	47	328	777	2031	1599	383	42	1	0
Wind	WSAvg	2.6	2.5	2.7	2.9	2.9	2.7	2.6	2.6	2.5	2.4	2.3	2.4	2.5
Precipitation	PrecAvg	1059	45	57	83	87	94	166	177	138	71	52	56	34
	PrecMax	1590	99	140	175	188	159	369	441	241	196	252	117	124
	PrecMin	664	13	13	13	11	10	46	34	59	3	2	0	1
	PrecStd	231	26	32	48	42	37	89	107	52	47	51	39	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	20.8	26.1	30.6	33.7	35.1	37.9	37.2	34.3	30.2	25.0	17.7
		MCWB	9.5	14.0	17.4	20.8	22.0	25.5	27.8	28.2	26.3	21.2	16.1	10.3
	2%	DB	12.2	16.7	22.6	28.0	31.9	33.3	36.2	35.3	32.1	27.7	22.0	14.6
		MCWB	7.4	10.7	15.3	19.6	21.8	25.2	28.0	27.8	25.2	19.6	14.9	9.2
	5%	DB	10.2	14.1	20.0	25.8	30.1	32.1	35.1	34.1	30.3	25.8	19.9	12.4
		MCWB	6.4	9.4	13.9	18.7	21.1	24.5	27.9	27.6	24.1	18.2	14.2	8.1
	10%	DB	8.4	11.9	17.8	23.8	28.2	30.8	33.9	32.9	28.9	24.0	17.9	10.8
		MCWB	5.3	8.1	12.4	17.3	20.4	24.1	27.8	27.2	22.9	17.8	13.4	7.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.7	15.2	19.7	22.8	25.6	28.4	29.9	29.7	27.7	23.2	18.7	12.4
		MCDB	13.4	19.4	23.9	27.1	29.6	32.6	34.5	34.3	32.1	27.3	21.4	14.6
	2%	WB	8.6	12.0	16.7	21.3	24.1	27.2	29.2	28.9	26.6	21.5	16.7	10.5
		MCDB	11.0	15.0	21.0	26.0	28.7	31.2	34.0	33.5	30.6	25.1	19.6	13.0
	5%	WB	7.0	10.2	14.8	19.8	23.0	26.3	28.6	28.3	25.7	20.2	15.3	9.1
		MCDB	9.5	12.9	18.7	24.1	27.1	29.8	33.3	32.5	28.9	23.4	18.2	11.6
	10%	WB	5.7	8.6	13.1	18.3	22.0	25.6	28.0	27.6	24.6	19.1	13.9	7.9
		MCDB	7.9	11.2	16.9	22.4	26.1	28.8	32.5	31.6	27.4	22.2	17.2	9.9
Mean Daily Temperature Range	5% DB	MDBR	7.3	7.6	8.8	9.3	9.1	7.4	7.0	7.0	7.8	8.6	8.8	8.1
		MCDBR	11.3	12.3	13.0	13.1	12.0	9.8	8.7	8.6	9.3	11.7	12.4	11.5
		MCWBR	7.1	7.4	7.1	6.5	5.0	4.1	3.5	3.4	3.6	4.8	6.1	6.8
	5% WB	MCDBR	9.9	10.4	11.4	11.3	9.5	7.7	8.3	8.2	7.7	8.8	9.0	9.3
		MCWBR	6.8	7.0	7.2	6.6	4.9	4.0	3.8	3.7	3.7	4.7	5.4	6.1
Clear-Sky Solar Irradiance	taub	0.614	0.671	0.689	0.688	0.688	0.750	0.704	0.719	0.702	0.691	0.645	0.606	
	taud	1.597	1.529	1.518	1.566	1.604	1.526	1.646	1.604	1.598	1.559	1.590	1.625	
	Ebn at Noon	571	591	627	657	663	621	648	629	612	567	541	547	
	Edh at Noon	219	256	277	274	265	286	253	260	252	245	218	203	
All-Sky Solar Radiation	RadAvg	2.18	2.50	3.66	4.38	4.66	4.44	4.77	4.33	3.71	3.12	2.46	2.13	
	RadStd	0.30	0.56	0.32	0.48	0.46	0.49	0.59	0.60	0.51	0.48	0.33	0.35	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page