

WUHUXIAN, China

WMO: 583380

Lat: 31.1198N

Lon: 118.5946E

Elev: 41

StdP: 100.83

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.1	-1.8	-11.0	1.5	2.2	-8.6	1.8	2.1	7.7	5.1	7.1	4.5	1.7	70	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	36.2	27.4	35.1	27.2	33.8	26.8	28.6	33.8	28.0	33.2	27.5	32.3	2.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.3	23.3	31.6	26.7	22.4	30.9	26.2	21.7	30.3	93.3	33.7	90.3	33.3	87.9	32.6	31.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
7.3	6.3	5.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-5.6	37.7	1.9	1.1	-7.0	38.5	-8.1	39.2	-9.2	39.8	-10.6	40.6
			-6.6	29.6	1.8	0.8	-7.9	30.1	-9.0	30.6	-10.0	31.1	-11.4	31.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	4.1	6.2	11.1	17.0	22.2	25.3	29.2	28.6	24.3	18.8	12.5	6.4
	DBStd	9.20	3.19	3.91	4.18	3.81	2.94	2.68	2.80	2.76	2.94	3.06	3.87	3.27
	HDD10.0	477	186	117	36	2	0	0	0	0	0	18	119	
	HDD18.3	1658	442	339	226	68	4	0	0	0	31	177	371	
	CDD10.0	3103	2	12	71	212	377	458	594	576	428	273	94	7
	CDD18.3	1242	0	0	3	28	123	208	336	318	178	46	3	0
	CDH23.3	12497	0	2	29	218	900	1796	4229	3777	1341	191	14	0
	CDH26.7	5367	0	1	5	56	293	652	2146	1764	418	32	1	0
Wind	WSAvg	2.5	2.4	2.8	3.0	2.8	2.6	2.5	2.4	2.6	2.5	2.3	2.2	2.3
Precipitation	PrecAvg	1275	67	76	116	107	132	222	172	139	84	52	62	44
	PrecMax	2182	128	190	305	271	255	770	417	351	313	218	137	123
	PrecMin	858	23	19	35	35	53	62	25	35	3	0	0	1
	PrecStd	285	32	42	64	52	55	147	104	81	63	44	44	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.2	21.4	26.4	31.1	33.8	35.2	37.7	38.2	34.7	29.8	25.4	17.8
		MCWB	10.7	14.5	17.6	20.0	22.1	25.8	27.9	27.6	26.7	21.9	17.1	10.7
	2%	DB	13.0	17.5	22.9	28.1	31.7	33.4	36.6	36.0	32.3	27.3	22.3	14.8
		MCWB	8.9	11.9	15.7	19.2	21.4	25.4	27.6	27.6	25.7	20.2	16.2	10.4
	5%	DB	10.6	14.6	20.2	25.8	29.8	31.9	35.6	34.8	30.7	25.3	20.2	12.9
		MCWB	7.4	10.2	14.1	18.2	20.9	24.5	27.4	27.3	25.0	19.2	15.1	9.6
	10%	DB	8.9	12.1	17.8	23.6	28.0	30.4	34.4	33.4	29.0	23.8	18.3	11.3
		MCWB	6.4	8.8	12.8	17.4	20.4	24.0	27.4	26.9	24.1	18.3	14.5	8.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.6	15.9	19.6	22.7	25.0	27.9	29.9	29.2	28.0	23.7	20.4	13.6
		MCDB	14.6	20.3	23.8	27.2	30.1	33.0	34.8	34.7	32.5	27.3	22.4	14.8
	2%	WB	9.6	12.9	17.0	21.2	23.9	26.8	28.9	28.3	27.0	22.2	17.9	11.6
		MCDB	11.5	16.0	21.6	25.1	28.3	31.4	34.0	33.8	30.6	25.7	20.1	13.2
	5%	WB	8.0	11.0	15.2	19.7	22.9	26.0	28.3	27.8	26.1	20.8	16.5	10.2
		MCDB	9.9	13.4	18.7	23.8	26.6	29.9	33.4	33.0	29.4	23.4	18.8	12.2
	10%	WB	6.6	9.4	13.7	18.4	22.0	25.3	27.7	27.3	25.2	19.8	15.0	8.9
		MCDB	8.6	11.8	17.1	22.4	25.6	28.6	32.7	32.1	28.2	22.3	17.8	10.8
Mean Daily Temperature Range	5% DB	MDBR	6.2	6.6	7.8	8.4	8.3	6.8	7.0	6.7	6.8	7.4	7.7	6.8
		MCDBR	10.4	11.6	12.5	12.7	11.8	9.7	9.1	8.8	8.5	10.0	10.9	10.1
		MCWBR	6.3	6.7	6.3	5.6	4.2	3.4	2.8	2.8	3.0	3.8	5.1	5.8
	5% WB	MCDBR	8.5	9.6	10.6	10.0	8.7	7.5	8.5	8.3	7.4	7.4	7.6	7.2
MCWBR		5.6	6.2	6.1	5.6	4.1	3.3	3.3	3.0	2.9	3.6	4.2	4.8	
Clear-Sky Solar Irradiance	taub	0.612	0.664	0.695	0.698	0.676	0.723	0.675	0.692	0.678	0.661	0.626	0.595	
	taud	1.620	1.553	1.526	1.568	1.645	1.592	1.718	1.666	1.656	1.620	1.638	1.655	
	Ebn at Noon	581	602	627	652	672	639	668	648	632	596	565	566	
	Edh at Noon	216	252	276	274	255	268	235	245	239	232	210	199	
All-Sky Solar Radiation	RadAvg	2.16	2.49	3.53	4.20	4.54	4.19	4.95	4.46	3.73	3.21	2.46	2.16	
	RadStd	0.34	0.56	0.31	0.49	0.50	0.54	0.61	0.62	0.41	0.50	0.34	0.37	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page