

LIYANG, China

WMO: 583450

Lat: 31.4309N

Lon: 119.5000E

Elev: 26

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.2	28.7	10.1	9.2	35.0	14.4	11.4	36.0	15.0	43.1	13.2	42.0	2.5	20	0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	96.9	80.9	94.7	80.6	92.5	80.0	83.3	91.7	82.3	90.6	81.4	89.5	5.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.2	162.1	88.0	80.2	156.7	87.1	79.3	152.2	86.4	47.4	92.0	46.3	90.7	45.3	89.7	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.8	11.9	10.3	DB	22.6	99.9	2.5	1.9	20.9	101.2	19.4	102.3	18.1	103.4	16.3	104.7
			WB	20.5	84.8	3.0	1.5	18.4	85.9	16.6	86.8	15.0	87.7	12.8	88.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.6	39.0	42.6	51.1	61.5	71.2	77.3	84.5	83.5	75.5	65.8	54.4	43.3	(6)
(7)		DBStd	16.60	5.68	6.50	7.06	6.65	5.22	4.86	4.99	4.76	5.06	5.19	6.76	5.74	(7)
(8)		HDD50	885	343	220	71	3	0	0	0	0	0	31	217		(8)
(9)		HDD65	3066	806	626	434	143	9	0	0	0	53	323	672		(9)
(10)		CDD50	5478	2	14	105	349	656	819	1070	1037	766	488	162	10	(10)
(11)		CDD65	2184	0	0	3	38	200	369	605	572	316	76	5	0	(11)
(12)		CDH74	22059	0	2	31	308	1432	3148	7711	6854	2281	275	17	0	(12)
(13)		CDH80	9370	0	0	5	79	452	1111	3897	3133	655	37	1	0	(13)
(14)	Wind	WSAvg	4.5	4.3	5.0	5.3	4.9	4.7	4.6	4.3	4.7	4.3	3.9	3.8	4.0	(14)
(15)	Precipitation	PrecAvg	45.0	1.5	2.4	3.4	4.4	4.3	6.8	6.2	5.0	4.6	2.9	2.4	1.3	(15)
(16)		PrecMax	60.7	3.9	4.7	6.4	8.0	9.6	15.4	18.0	17.4	11.1	9.8	7.0	4.4	(16)
(17)		PrecMin	24.6	0.3	0.4	1.1	1.2	1.3	1.8	1.1	0.5	1.2	0.0	0.1	0.0	(17)
(18)		PrecStd	8.1	0.9	1.3	1.5	1.9	2.0	2.9	4.6	3.8	2.7	2.5	1.7	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.6	67.4	77.7	87.8	93.1	95.3	99.8	100.0	94.0	84.2	76.4	62.9	(19)
(20)		MCWB	50.1	55.3	61.4	67.7	70.6	79.8	81.1	81.1	79.7	71.8	63.3	52.3		(20)
(21)		2%	DB	54.5	60.9	71.3	81.7	88.4	91.9	97.6	96.3	89.3	79.8	71.4	58.1	(21)
(22)		MCWB	47.1	52.4	59.0	66.2	69.8	77.1	81.0	81.3	78.7	68.5	61.8	51.6		(22)
(23)		5%	DB	50.6	56.5	66.9	77.0	84.9	89.1	95.7	93.9	86.4	76.9	67.9	54.9	(23)
(24)		MCWB	45.2	49.0	56.6	64.0	69.0	75.7	81.0	81.1	77.1	66.5	59.8	49.2		(24)
(25)		10%	DB	47.5	52.5	62.6	72.9	81.6	86.2	93.6	91.5	83.7	74.3	64.7	52.2	(25)
(26)		MCWB	43.5	47.1	54.2	62.2	67.9	75.0	80.8	80.7	75.2	65.3	58.4	47.4		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	58.6	64.9	72.7	77.1	81.7	85.0	84.5	82.4	75.1	68.5	57.2	(27)
(28)		MCDWB	57.7	65.0	72.6	79.8	87.4	90.5	93.2	93.2	90.0	79.6	71.5	59.3		(28)
(29)		2%	WB	48.9	53.8	61.2	69.4	74.5	80.0	83.6	83.1	80.7	71.9	64.5	53.2	(29)
(30)		MCDWB	51.9	59.4	68.5	77.1	81.4	88.5	92.1	91.6	86.7	76.9	68.3	56.2		(30)
(31)		5%	WB	46.3	50.8	58.4	66.9	72.6	78.6	82.6	82.2	79.1	69.7	61.9	50.5	(31)
(32)		MCDWB	49.5	54.5	64.5	73.8	78.9	85.8	91.0	90.5	84.5	74.1	65.4	53.2		(32)
(33)		10%	WB	43.8	47.9	55.6	64.3	70.9	77.2	81.8	81.3	77.4	67.7	59.3	48.2	(33)
(34)		MCDWB	47.2	51.7	61.0	71.1	77.0	83.1	90.1	89.1	82.3	72.0	63.7	51.5		(34)
(35)	Mean Daily Temperature Range	MDBR	11.3	11.8	13.9	15.3	15.1	11.9	12.0	11.4	11.9	13.4	14.0	12.8		(35)
(36)		5% DB	18.6	20.8	22.3	23.3	21.8	17.0	15.3	15.0	14.2	17.1	19.2	18.2		(36)
(37)		MCWBR	11.6	12.3	11.8	10.7	7.9	6.2	4.7	4.7	5.2	7.0	9.3	10.8		(37)
(38)		5% WB	15.1	16.7	18.8	18.3	15.1	13.4	13.8	13.3	12.7	12.8	13.7	12.9		(38)
(39)		MCWBR	10.4	11.3	11.4	10.5	7.7	5.9	5.3	5.1	5.4	6.9	8.2	9.2		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.620	0.671	0.699	0.704	0.689	0.751	0.706	0.704	0.679	0.670	0.644	0.609		(40)
(41)		taud	1.611	1.541	1.520	1.559	1.623	1.546	1.659	1.647	1.662	1.613	1.621	1.643		(41)
(42)		Ebn at Noon	181	189	198	205	210	197	205	203	200	187	174	175		(42)
(43)		Edh at Noon	69	81	88	88	83	89	79	79	75	74	68	64		(43)
(44)	All-Sky Solar Radiation	RadAvg	696	805	1144	1361	1462	1331	1570	1455	1206	1032	780	683		(44)
(45)		RadStd	98	162	100	156	155	183	188	200	127	155	104	109		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.58	N/A	N/A	N/A	N/A	-0.65	N/A	N/A	N/A	N/A	(46)
(47)	Regional (8 neighbors)	+0.56	N/A	N/A	+0.94	N/A	N/A	N/A	N/A	+153	N/A	(47)

Nomenclature: See separate page