

HUANG SHAN, China

WMO: 584370

Lat: 30.1347N

Lon: 118.1642E

Elev: 6024

StdP: 11.77

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.9	13.4	-26.9	1.5	27.8	-20.0	2.3	29.2	33.8	15.9	30.6	19.0	18.4	340	0.650

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.0	73.1	67.0	71.1	65.7	69.3	64.8	68.3	71.4	67.2	69.8	66.1	68.2	4.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.4	126.3	69.9	66.4	121.9	68.5	65.5	118.1	67.4	36.7	71.7	35.7	70.1	34.7	68.3	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
30.7	27.2	24.4	4.3	77.2	4.5	2.3	1.0	78.8	-1.6	80.2	-4.1	81.4	-7.4	83.1		
			2.6	70.1	4.1	1.5	-0.3	71.1	-2.8	72.0	-5.1	72.8	-8.1	73.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	28.8	32.2	38.6	47.8	55.4	60.4	65.0	64.4	58.2	50.5	42.0	32.0	(6)
(7)		DBStd	14.16	8.25	8.95	8.34	6.85	4.84	3.70	3.28	3.57	5.79	6.19	7.82	8.52	(7)
(8)		HDD50	2532	658	498	359	117	12	0	0	7	70	252	559		(8)
(9)		HDD65	6283	1123	917	819	517	297	141	40	55	209	451	690	1024	(9)
(10)		CDD50	1808	0	0	5	49	181	313	465	445	254	84	12	0	(10)
(11)		CDD65	85	0	0	0	0	0	4	40	35	6	0	0	0	(11)
(12)		CDH74	33	0	0	0	0	0	0	17	16	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	11.7	12.2	12.5	12.6	12.5	11.3	11.4	12.0	10.6	10.2	10.6	11.4	12.6	(14)
(15)	Precipitation	PrecAvg	91.2	2.6	4.6	7.2	9.4	11.6	14.8	12.2	11.1	7.7	4.5	3.6	2.1	(15)
(16)		PrecMax	131.0	6.3	14.6	12.9	21.7	26.7	25.8	30.3	28.9	20.0	11.7	8.1	8.7	(16)
(17)		PrecMin	61.0	0.0	1.2	2.7	3.5	2.7	5.8	2.2	2.3	1.6	0.0	0.1	0.0	(17)
(18)		PrecStd	15.8	1.4	2.7	2.7	3.7	5.0	4.6	6.1	6.3	4.1	3.0	2.4	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.7	52.0	58.0	64.5	69.5	72.0	76.2	75.9	72.1	65.9	58.9	50.4	(19)
(20)		MCWB	45.1	48.5	50.1	52.4	58.6	62.6	68.7	68.4	65.4	55.1	49.3	42.7	(20)	
(21)		2%	DB	45.2	49.0	54.3	60.9	66.5	69.1	73.5	73.1	69.1	62.5	56.2	47.6	(21)
(22)		MCWB	41.4	46.4	48.8	51.3	56.5	61.4	67.6	67.3	64.1	57.1	49.1	41.7	(22)	
(23)		5%	DB	42.4	46.7	51.8	58.2	64.1	66.9	71.4	70.9	67.1	60.2	54.1	45.3	(23)
(24)		MCWB	38.8	44.6	47.6	52.0	56.4	61.5	66.4	66.4	62.8	54.5	46.9	39.2	(24)	
(25)		10%	DB	40.0	44.7	49.5	56.4	62.1	65.2	69.5	69.0	65.1	58.3	51.8	43.2	(25)
(26)		MCWB	36.0	42.3	45.5	52.3	56.9	61.5	65.5	65.6	62.0	53.1	45.2	37.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.6	50.8	55.1	58.5	63.6	67.0	70.0	70.2	67.4	62.6	56.0	48.6	(27)
(28)		MCDWB	48.0	51.1	55.8	59.1	64.7	69.1	73.7	73.6	70.4	63.3	56.7	48.7	(28)	
(29)		2%	WB	43.8	47.7	52.0	56.9	62.1	65.3	68.4	68.4	65.6	60.0	53.3	45.6	(29)
(30)		MCDWB	44.3	48.1	52.6	57.7	63.1	66.5	71.7	71.3	67.8	60.9	54.5	46.0	(30)	
(31)		5%	WB	40.9	45.7	49.6	55.6	60.4	64.2	67.3	67.3	64.4	58.0	51.0	42.9	(31)
(32)		MCDWB	41.4	46.3	50.5	56.4	61.6	65.1	70.1	69.8	65.9	59.0	52.1	43.6	(32)	
(33)		10%	WB	37.9	43.6	47.1	54.0	59.0	63.2	66.3	66.2	63.2	56.0	48.5	39.9	(33)
(34)		MCDWB	38.7	44.3	48.2	55.1	60.4	64.1	68.5	68.2	64.5	57.1	50.0	41.0	(34)	
(35)	Mean Daily Temperature Range		MDBR	8.7	9.1	10.1	9.6	9.0	6.5	6.0	6.3	7.3	8.1	8.6	9.2	(35)
(36)		5% DB	MCDBR	8.9	9.0	10.9	11.6	11.5	9.5	9.3	9.5	9.2	9.4	9.0	9.4	(36)
(37)		MCWBR	7.5	8.3	9.7	9.6	9.7	9.0	7.2	7.0	7.6	8.4	8.3	7.9	(37)	
(38)		5% WB	MCDBR	8.0	8.0	8.4	7.5	7.6	6.0	8.1	8.4	7.6	7.1	6.9	8.8	(38)
(39)		MCWBR	8.3	8.2	8.9	7.6	7.1	6.0	6.7	6.5	6.2	6.3	7.1	8.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.404	0.439	0.471	0.472	0.446	0.463	0.442	0.460	0.449	0.428	0.403	0.384	(40)	
(41)		taud	2.010	1.953	1.907	1.966	2.099	2.102	2.208	2.132	2.106	2.065	2.068	2.072	(41)	
(42)		Ebn at Noon	253	256	258	263	270	264	269	263	261	257	252	253	(42)	
(43)		Edh at Noon	46	54	60	58	51	51	46	49	49	47	43	41	(43)	
(44)	All-Sky Solar Radiation	RadAvg	670	768	1059	1250	1380	1262	1597	1423	1210	1043	796	700	(44)	
(45)		RadStd	118	200	93	153	162	174	198	182	110	157	125	136	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.63	N/A	+3.20	+1.21	+0.77	+0.72	N/A	N/A	N/A	N/A	(46)
(47)	Regional (7 neighbors)	+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+185	N/A	(47)

Nomenclature: See separate page