

HUANG SHAN, China

WMO: 584370

Lat: 30.1347N

Lon: 118.1642E

Elev: 1836

StdP: 81.13

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.3	-10.3	-32.7	0.2	-2.3	-28.9	0.3	-1.6	15.1	-8.9	13.7	-7.2	8.2	340	0.650

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.3	22.9	19.4	21.7	18.7	20.7	18.2	20.2	21.9	19.5	21.0	19.0	20.1	2.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.6	18.0	21.1	19.1	17.4	20.3	18.6	16.9	19.7	67.5	22.1	65.1	21.1	62.8	20.2	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.7	12.2	10.9	-15.4	25.1	2.5	1.3	-17.2	26.0	-18.7	26.8	-20.1	27.5	-21.9	28.4		
			-16.3	21.2	2.3	0.8	-18.0	21.7	-19.3	22.2	-20.6	22.7	-22.3	23.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-1.8	0.1	3.7	8.8	13.0	15.8	18.3	18.0	14.6	10.3	5.6	0.0	(6)
(7)		DBStd	7.87	4.58	4.97	4.64	3.80	2.69	2.06	1.82	1.98	3.22	3.44	4.35	4.73	(7)
(8)		HDD10.0	1407	366	277	199	65	7	0	0	4	39	140	311		(8)
(9)		HDD18.3	3491	624	509	455	287	165	78	22	31	116	251	383	569	(9)
(10)		CDD10.0	1004	0	0	3	27	101	174	258	247	141	47	7	0	(10)
(11)		CDD18.3	47	0	0	0	0	0	2	22	19	3	0	0	0	(11)
(12)		CDH23.3	18	0	0	0	0	0	0	9	9	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.2	5.5	5.6	5.7	5.6	5.0	5.1	5.4	4.7	4.5	4.7	5.1	5.6	(14)
(15)	Precipitation	PrecAvg	2317	66	116	182	238	294	376	310	281	195	115	92	53	(15)
(16)		PrecMax	3327	159	371	327	550	678	655	769	735	507	298	207	221	(16)
(17)		PrecMin	1549	0	31	68	89	68	148	55	58	40	0	2	0	(17)
(18)		PrecStd	401	35	69	68	94	126	117	156	161	105	77	62	49	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.3	11.1	14.5	18.0	20.8	22.2	24.6	24.4	22.3	18.9	14.9	10.2	(19)
MCWB			7.3	9.2	10.1	11.3	14.8	17.0	20.4	20.2	18.5	12.8	9.6	5.9	(20)	
2%		DB	7.3	9.4	12.4	16.1	19.2	20.6	23.1	22.8	20.6	16.9	13.4	8.6	(21)	
		MCWB	5.2	8.0	9.3	10.7	13.6	16.3	19.8	19.6	17.8	13.9	9.5	5.4	(22)	
5%		DB	5.8	8.2	11.0	14.6	17.8	19.4	21.9	21.6	19.5	15.7	12.3	7.4	(23)	
		MCWB	3.8	7.0	8.7	11.1	13.6	16.4	19.1	19.1	17.1	12.5	8.3	4.0	(24)	
10%		DB	4.4	7.0	9.7	13.6	16.7	18.4	20.9	20.6	18.4	14.6	11.0	6.2	(25)	
		MCWB	2.2	5.7	7.5	11.3	13.8	16.4	18.6	18.6	16.7	11.7	7.3	2.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	10.4	12.8	14.7	17.6	19.4	21.1	21.2	19.7	17.0	13.3	9.2	(27)
MCDWB			8.9	10.6	13.2	15.0	18.2	20.6	23.1	23.1	21.4	17.4	13.7	9.3	(28)	
2%		WB	6.5	8.7	11.1	13.8	16.7	18.5	20.2	20.2	18.7	15.5	11.9	7.6	(29)	
		MCDWB	6.8	9.0	11.5	14.3	17.3	19.2	22.1	21.8	19.9	16.0	12.5	7.8	(30)	
5%		WB	4.9	7.6	9.8	13.1	15.8	17.9	19.6	19.6	18.0	14.4	10.6	6.1	(31)	
		MCDWB	5.2	7.9	10.3	13.6	16.5	18.4	21.2	21.0	18.8	15.0	11.2	6.4	(32)	
10%		WB	3.3	6.4	8.4	12.2	15.0	17.4	19.1	19.0	17.3	13.3	9.2	4.4	(33)	
		MCDWB	3.7	6.9	9.0	12.9	15.8	17.8	20.3	20.1	18.0	14.0	10.0	5.0	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.8	5.1	5.6	5.3	5.0	3.6	3.3	3.5	4.1	4.5	4.8	5.1	(35)
MCDBR			4.9	5.0	6.0	6.4	6.4	5.3	5.2	5.3	5.1	5.2	5.0	5.2	(36)	
MCWBR			4.2	4.6	5.4	5.3	5.4	5.0	4.0	3.9	4.2	4.6	4.6	4.4	(37)	
5% WB		MCDWB	4.5	4.5	4.7	4.2	4.2	3.3	4.5	4.7	4.2	3.9	3.9	4.9	(38)	
		MCWBR	4.6	4.6	5.0	4.2	4.0	3.3	3.7	3.6	3.5	3.5	3.9	5.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.404	0.439	0.471	0.472	0.446	0.463	0.442	0.460	0.449	0.428	0.403	0.384	(40)	
(41)		taud	2.010	1.953	1.907	1.966	2.099	2.102	2.208	2.132	2.106	2.065	2.068	2.072	(41)	
(42)		Ebn at Noon	798	808	813	828	850	831	847	829	824	810	794	798	(42)	
(43)		Edh at Noon	145	169	189	184	162	161	144	154	153	148	136	130	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.11	2.42	3.34	3.94	4.35	3.98	5.04	4.49	3.81	3.29	2.51	2.21	(44)	
(45)		RadStd	0.37	0.63	0.29	0.48	0.51	0.55	0.62	0.57	0.35	0.49	0.39	0.43	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.35	N/A	+1.78	+0.67	+0.43	+0.40	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+103	N/A

Nomenclature: See separate page