

SHENGSI, China

WMO: 584720

Lat: 30.7316N

Lon: 122.4493E

Elev: 60

StdP: 100.61

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.3	0.9	-9.8	1.6	2.0	-7.7	2.0	2.5	15.8	5.6	14.5	5.6	8.6	340	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.9	31.7	26.5	30.6	26.3	29.7	26.0	27.4	30.0	26.9	29.3	26.5	28.8	4.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.4	28.9	26.2	21.8	28.4	25.8	21.3	28.1	87.4	30.1	85.3	29.5	83.4	28.9	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.4	13.7	12.4	DB	-1.8	33.8	2.1	1.4	-3.3	34.8	-4.5	35.6	-5.6	36.4	-7.1	37.4	(4)
			WB	-4.3	28.2	1.9	0.7	-5.6	28.7	-6.7	29.1	-7.8	29.5	-9.1	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	6.1	6.8	9.9	14.4	19.1	22.7	26.9	27.3	24.5	20.3	15.2	9.1
	DBStd	7.85	3.23	3.09	3.00	2.84	2.18	2.28	2.04	1.56	2.04	2.25	3.27	3.59
	HDD10.0	328	127	97	39	2	0	0	0	0	0	0	4	59
	HDD18.3	1500	379	322	262	123	17	0	0	0	0	8	103	286
	CDD10.0	2849	6	8	35	133	282	380	524	538	434	319	158	32
	CDD18.3	980	0	0	0	4	41	130	266	279	184	69	7	0
	CDH23.3	7080	0	0	1	9	49	499	2574	2826	1041	81	1	0
	CDH26.7	1671	0	0	0	1	2	84	695	741	145	3	0	0
Wind	WSAvg	6.5	6.9	6.7	6.7	6.5	6.1	5.4	6.4	6.3	6.6	6.7	6.5	6.8
Precipitation	PrecAvg	987	46	63	86	106	107	130	75	83	127	67	56	40
	PrecMax	1398	121	159	199	228	202	304	273	308	328	216	131	137
	PrecMin	602	4	17	14	38	38	22	0	2	15	0	0	0
	PrecStd	194	25	38	47	44	38	63	62	69	79	59	37	34
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	17.9	20.2	24.6	26.6	31.0	33.4	33.4	31.0	26.7	23.0	18.2
		MCWB	14.6	13.3	14.4	18.7	20.7	25.9	26.6	27.0	26.5	23.8	19.4	16.4
	2%	DB	13.8	14.8	17.3	21.5	24.7	28.9	32.0	31.6	29.4	25.2	21.6	16.6
		MCWB	12.0	12.7	13.6	17.3	19.7	25.0	26.4	26.7	25.7	22.5	19.1	14.4
	5%	DB	12.2	12.9	15.7	19.8	23.3	27.3	30.8	30.6	28.3	24.1	20.5	15.2
		MCWB	10.4	11.1	13.1	16.9	19.6	24.2	26.2	26.5	25.1	21.3	18.0	12.9
	10%	DB	10.5	11.1	14.2	18.4	22.2	26.0	29.8	29.7	27.2	23.2	19.4	13.9
		MCWB	8.4	9.1	11.9	15.9	19.1	23.5	26.0	26.2	24.6	20.3	17.0	11.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.0	14.9	16.4	20.1	22.6	26.4	28.1	28.1	27.1	25.0	20.7	17.3
		MCDB	16.3	17.1	18.0	22.2	24.6	29.7	31.4	31.0	29.8	26.2	21.9	17.8
	2%	WB	12.5	13.1	14.6	18.7	21.6	25.5	27.3	27.5	26.3	23.4	19.8	15.0
		MCDB	13.5	14.4	16.0	20.4	23.1	28.2	30.1	30.1	28.4	24.6	21.1	16.1
	5%	WB	10.5	11.3	13.5	17.6	20.9	24.6	26.8	27.1	25.7	22.1	18.7	13.5
		MCDB	11.8	12.6	15.1	19.1	22.3	26.7	29.4	29.4	27.6	23.5	19.9	14.8
	10%	WB	8.8	9.6	12.2	16.4	20.1	23.9	26.4	26.7	25.2	20.9	17.5	12.0
		MCDB	10.1	10.8	14.0	18.0	21.4	25.6	28.8	28.9	27.0	22.8	19.0	13.6
Mean Daily Temperature Range	5% DB	MDBR	3.7	4.0	4.4	4.7	4.4	3.7	4.1	3.9	3.4	3.4	3.6	3.7
		MCDBR	5.4	6.7	6.8	6.6	5.9	5.6	5.9	5.2	4.4	4.1	4.2	4.7
		MCWBR	4.7	5.3	4.6	4.3	3.7	2.8	2.6	2.2	2.3	2.8	3.1	4.3
	5% WB	MCDBR	5.1	6.3	6.1	5.7	4.8	5.1	5.0	4.6	4.0	3.7	3.7	4.3
		MCWBR	4.9	5.5	4.8	4.2	3.5	2.8	2.4	2.2	2.3	3.2	3.3	4.4
Clear-Sky Solar Irradiance	taub	0.554	0.594	0.634	0.640	0.621	0.663	0.620	0.594	0.558	0.536	0.552	0.538	
	taud	1.762	1.706	1.656	1.701	1.786	1.762	1.884	1.947	1.984	1.926	1.823	1.793	
	Ebn at Noon	639	662	674	694	711	679	707	720	728	705	637	626	
	Edh at Noon	188	217	243	240	222	226	200	186	173	171	175	174	
All-Sky Solar Radiation	RadAvg	2.06	2.55	3.60	4.25	4.65	4.13	5.57	5.33	4.21	3.45	2.39	2.02	
	RadStd	0.26	0.50	0.29	0.45	0.49	0.55	0.65	0.60	0.43	0.43	0.31	0.31	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page