

SHENG SHANG, China

WMO: 584730

Lat: 30.722N

Lon: 122.818E

Elev: 646

StdP: 14.36

Time Zone: 8.00 (E08)

Period: 82-90

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	31.5	34.0	16.0	12.6	34.9	19.1	14.7	36.4	40.5	40.5	38.0	38.6	21.9	340	0.668

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	84.3	79.2	82.8	78.7	81.5	78.1	80.0	82.5	79.2	81.5	78.7	80.8	10.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.2	155.3	81.5	78.6	152.1	80.7	78.1	149.3	80.2	44.3	82.9	43.5	82.1	42.9	80.9	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
40.1	35.6	32.0	DB	28.4	87.8	2.9	1.9	26.3	89.2	24.6	90.3	23.0	91.3	20.9	92.7	
			WB	24.7	81.8	2.3	1.4	23.0	82.8	21.6	83.5	20.3	84.3	18.7	85.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.1	42.8	41.9	46.5	53.6	62.2	70.1	77.2	79.0	73.5	66.7	58.4	47.8
	DBStd	13.61	5.17	4.63	4.93	4.35	4.01	3.76	3.06	2.32	3.61	3.80	6.02	6.32
	HDD50	731	230	228	133	14	0	0	0	0	0	0	9	117
	HDD65	3126	689	646	574	342	104	4	0	0	0	27	207	533
	CDD50	4410	6	2	24	122	379	602	843	900	705	517	262	48
	CDD65	1330	0	0	0	0	18	156	378	435	255	78	10	0
	CDH74	7131	0	0	0	0	2	241	2438	3520	884	42	4	0
	CDH80	702	0	0	0	0	0	10	238	415	37	1	1	0
Wind	WSAvg	16.1	17.1	17.9	17.1	16.2	15.7	14.8	16.9	14.7	14.8	15.2	16.4	16.5
Precipitation	PrecAvg	47.8	2.6	2.8	4.1	3.7	4.3	7.5	4.0	5.7	4.6	3.1	2.9	2.5
	PrecMax	60.3	8.4	5.9	9.7	7.7	9.1	15.6	13.2	14.6	10.4	9.9	7.4	7.2
	PrecMin	26.3	0.6	0.6	0.9	1.0	1.0	0.4	0.0	0.3	0.6	0.0	0.6	0.0
	PrecStd	8.2	1.5	1.5	2.6	1.4	1.9	3.7	3.1	3.8	2.8	2.6	2.0	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.4	56.6	62.5	66.0	72.6	81.1	87.1	87.1	82.9	77.7	70.7	64.6
		MCWB	55.1	55.1	56.9	58.5	68.6	75.5	79.1	80.4	78.1	72.3	66.9	59.1
	2%	DB	55.0	53.0	58.8	63.6	70.1	78.2	83.9	84.9	81.0	74.8	68.7	61.4
		MCWB	53.4	50.6	56.3	59.1	67.0	75.5	79.1	79.5	77.1	72.0	66.2	56.5
	5%	DB	52.6	50.8	55.2	61.7	68.8	76.6	82.4	83.4	79.7	72.9	67.4	58.4
		MCWB	50.1	48.9	52.7	59.2	66.3	75.0	78.7	79.0	76.5	69.3	64.7	54.2
	10%	DB	50.4	48.7	52.9	60.0	67.6	75.2	80.9	82.1	78.6	71.4	65.8	55.9
		MCWB	47.2	46.4	50.5	57.8	65.4	74.0	78.0	78.5	76.0	66.8	62.3	52.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.2	55.2	59.7	62.8	70.4	77.5	80.8	81.9	79.2	75.2	68.5	60.9
		MCDB	56.6	56.4	60.8	63.5	71.5	79.0	83.8	85.6	81.0	76.6	69.8	63.8
	2%	WB	53.7	51.5	56.5	61.1	68.7	76.3	79.9	80.3	78.3	73.5	67.1	57.4
		MCDB	54.7	52.1	57.8	62.2	69.3	77.4	82.3	83.0	79.9	74.3	68.4	60.1
	5%	WB	50.8	49.3	53.6	59.8	67.5	75.3	79.2	79.6	77.6	70.7	65.7	55.0
		MCDB	52.5	50.5	54.9	61.0	68.2	76.3	81.2	82.1	79.2	71.9	67.1	57.7
	10%	WB	47.7	47.0	51.2	58.4	66.4	74.2	78.6	79.0	76.5	68.0	63.5	53.0
		MCDB	49.9	48.2	52.5	59.6	67.2	75.1	80.4	81.3	78.1	70.7	65.3	56.0
Mean Daily Temperature Range	5% DB	MDBR	5.4	4.8	5.9	6.1	5.9	5.1	5.2	5.0	4.8	4.6	5.4	5.9
		MCDBR	7.9	8.5	10.3	8.6	7.8	6.8	7.1	6.2	6.3	6.3	6.3	9.4
		MCWBR	8.0	7.8	7.3	6.7	6.0	4.3	4.5	3.1	4.3	4.9	5.9	7.7
	5% WB	MCDBR	7.3	8.1	9.3	7.5	6.1	5.9	6.8	5.7	4.8	4.6	5.8	8.7
MCWBR		8.1	7.8	7.7	6.6	5.7	3.7	4.5	3.6	3.3	4.5	6.2	8.1	
Clear-Sky Solar Irradiance	taub		0.528	0.566	0.606	0.611	0.593	0.634	0.594	0.564	0.530	0.507	0.523	0.512
	taud		1.811	1.756	1.703	1.750	1.838	1.819	1.944	2.023	2.057	2.000	1.884	1.843
	Ebn at Noon		211	218	221	227	232	222	230	236	239	233	211	207
	Edh at Noon		56	65	74	73	67	68	60	55	51	50	52	52
All-Sky Solar Radiation	RadAvg		637	807	1151	1359	1485	1322	1801	1735	1369	1113	759	621
	RadStd		86	160	95	146	161	179	212	187	139	137	100	97

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+135	N/A

Nomenclature: See separate page