

LU SHAN, China

WMO: 585060

Lat: 29.585N

Lon: 115.989E

Elev: 3822

StdP: 12.78

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.6	19.6	-7.7	4.2	33.1	-1.4	5.9	33.1	27.5	30.7	24.3	30.0	9.8	40	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.2	82.4	73.4	80.6	72.8	78.9	71.9	75.1	79.9	73.8	78.7	72.8	77.4	5.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.8	145.5	77.9	72.4	138.8	76.7	71.3	133.6	75.6	41.8	80.0	40.4	78.9	39.3	77.7	81.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
27.9	23.9	20.7	DB	12.4	85.3	4.0	1.7	9.5	86.5	7.2	87.5	4.9	88.5	1.9	89.7
			WB	10.6	77.6	3.6	1.5	8.0	78.7	5.9	79.6	3.9	80.4	1.3	81.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.8	33.8	37.3	45.2	55.1	62.8	68.1	73.5	71.9	65.5	57.0	47.9	37.8
	DBStd	15.24	8.80	9.62	9.14	7.59	5.35	4.55	4.09	4.48	6.09	6.45	8.28	8.28
	HDD50	1648	505	369	201	38	1	0	0	0	0	16	134	384
	HDD65	4474	967	776	613	303	106	21	3	5	69	256	513	842
	CDD50	3388	4	13	53	191	398	544	729	679	466	233	71	7
	CDD65	737	0	0	1	6	37	115	266	219	84	8	1	0
	CDH74	2243	0	0	0	6	54	238	1045	726	167	7	0	0
	CDH80	211	0	0	0	0	1	10	116	77	7	0	0	0
(14) Wind	WSAvg	8.0	6.6	7.7	8.3	8.7	8.1	8.0	9.2	8.1	8.7	8.4	7.4	6.9
(15) Precipitation	PrecAvg	77.4	2.4	3.9	5.9	8.7	10.5	11.5	8.8	8.8	6.3	4.3	3.6	2.1
	PrecMax	119.5	5.7	8.3	10.1	16.7	21.5	22.6	19.8	43.3	14.3	11.2	8.3	7.2
	PrecMin	46.5	0.0	1.1	2.4	4.3	4.3	3.6	2.4	0.5	0.5	0.0	0.0	0.0
	PrecStd	16.5	1.2	1.8	1.9	3.4	4.3	4.5	4.6	8.3	3.9	3.0	2.2	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.5	62.1	68.3	74.2	78.6	81.5	85.0	84.6	81.1	74.7	68.4	58.7
		MCWB	50.9	54.3	58.6	61.7	66.1	72.4	74.2	73.9	72.6	66.7	58.4	47.8
	2%	DB	53.4	58.2	64.4	70.3	75.3	79.0	82.8	82.2	78.2	70.8	64.7	55.0
		MCWB	46.8	52.2	54.3	60.2	64.6	71.0	73.6	73.6	71.5	63.2	55.4	46.9
	5%	DB	49.6	55.1	60.7	67.6	72.9	76.7	81.1	80.1	75.9	67.9	61.6	52.0
		MCWB	43.1	49.9	53.7	58.6	63.8	69.7	73.1	73.0	69.9	60.8	53.0	44.1
	10%	DB	46.4	51.5	57.7	64.9	70.7	74.6	79.4	78.0	73.6	65.5	58.6	48.9
		MCWB	40.2	46.6	51.2	57.9	63.0	68.7	72.4	72.1	68.4	58.9	51.1	41.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.4	57.1	62.7	66.5	71.3	74.9	77.2	77.1	74.3	69.4	62.8	54.2
		MCDB	56.8	60.1	66.3	69.9	74.1	78.8	81.5	80.6	78.5	73.1	66.2	55.7
	2%	WB	49.0	53.9	58.7	64.2	69.2	72.8	75.3	75.2	72.5	65.6	59.1	50.3
		MCDB	51.5	57.1	61.4	67.2	71.8	76.8	80.5	79.5	76.8	68.4	61.4	52.7
	5%	WB	45.3	51.1	55.8	62.4	67.3	71.4	74.0	73.7	71.0	63.0	56.5	46.5
		MCDB	48.3	53.8	58.6	64.4	69.8	75.0	79.2	78.6	74.8	66.2	59.4	49.5
	10%	WB	41.3	47.8	52.9	60.6	65.6	70.1	72.9	72.6	69.4	60.8	53.4	42.7
		MCDB	44.7	50.5	56.0	63.0	68.3	73.3	77.9	77.1	72.7	63.8	56.6	46.4
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	10.0	11.0	11.1	10.2	8.3	8.2	8.0	9.1	9.8	10.2	10.1
		MCDBR	12.6	13.5	13.7	13.6	12.6	10.8	10.5	10.5	10.9	11.4	12.2	12.6
		MCWBR	9.3	10.2	10.1	10.0	10.3	8.2	7.0	7.5	8.2	8.7	8.8	9.6
	5% WB	MCDBR	11.8	13.1	12.2	10.8	9.9	9.4	9.9	9.6	10.2	10.6	10.2	11.7
		MCWBR	10.1	10.4	10.7	9.0	8.4	7.4	7.1	7.5	7.9	8.0	7.8	9.9
(40) Clear-Sky Solar Irradiance	taub		0.501	0.541	0.575	0.571	0.533	0.540	0.506	0.537	0.531	0.528	0.492	0.475
	taud		1.792	1.738	1.699	1.759	1.905	1.939	2.072	1.959	1.917	1.824	1.854	1.857
	Ebn at Noon		221	226	230	237	247	244	252	243	239	226	222	221
	Edh at Noon		58	67	74	72	62	60	53	58	59	61	54	52
(44) All-Sky Solar Radiation	RadAvg		646	737	1003	1218	1358	1307	1656	1485	1299	1052	811	687
	RadStd		110	195	78	133	146	144	171	153	118	134	120	133

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.45	N/A	N/A	+0.90	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.49	N/A	N/A	N/A	N/A	N/A	N/A	+203	N/A

Nomenclature: See separate page