

LU SHAN, China

WMO: 585060

Lat: 29.585N

Lon: 115.989E

Elev: 1165

StdP: 88.09

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -8.6	(c) -6.9	(d) -22.0	(e) 0.6	(f) 0.6	(g) -18.5	(h) 0.8	(i) 0.6	(j) 12.3	(k) -0.7	(l) 10.8	(m) -1.1	(n) 4.4	(o) 40	(p) 0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.6	28.0	23.0	27.0	22.6	26.0	22.2	24.0	26.6	23.2	25.9	22.7	25.2	2.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	20.8	25.5	22.5	19.8	24.8	21.9	19.1	24.2	79.2	26.7	76.1	26.1	73.6	25.4	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.5	10.7	9.3	-10.9	29.6	2.2	0.9	-12.5	30.3	-13.8	30.8	-15.1	31.4	-16.7	32.1
			-11.9	25.4	2.0	0.8	-13.3	26.0	-14.5	26.4	-15.6	26.9	-17.1	27.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.6	1.0	2.9	7.4	12.8	17.1	20.1	23.1	22.2	18.6	13.9	8.8	3.2
	DBStd	8.47	4.89	5.34	5.08	4.22	2.97	2.53	2.27	2.49	3.38	3.58	4.60	4.60
	HDD10.0	916	281	205	112	21	1	0	0	0	0	9	74	213
	HDD18.3	2486	537	431	341	168	59	12	2	3	38	142	285	468
	CDD10.0	1882	2	7	29	106	221	302	405	377	259	129	39	4
	CDD18.3	409	0	0	1	3	21	64	148	122	47	4	1	0
	CDH23.3	1246	0	0	0	3	30	132	581	403	93	4	0	0
	CDH26.7	117	0	0	0	0	1	6	64	43	4	0	0	0
Wind	WSAvg	3.6	3.0	3.4	3.7	3.9	3.6	3.6	4.1	3.6	3.9	3.8	3.3	3.1
Precipitation	PrecAvg	1965	61	100	149	221	266	292	224	223	160	108	91	53
	PrecMax	3035	144	210	257	425	546	574	503	1100	364	285	212	182
	PrecMin	1182	0	29	62	110	108	92	60	12	13	0	0	0
	PrecStd	419	30	45	48	86	108	115	118	210	100	77	57	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.2	16.7	20.2	23.4	25.9	27.5	29.4	29.2	27.3	23.7	20.2	14.9
		MCWB	10.5	12.4	14.8	16.5	18.9	22.4	23.5	23.3	22.5	19.3	14.6	8.8
	2%	DB	11.9	14.6	18.0	21.3	24.0	26.1	28.2	27.9	25.7	21.5	18.2	12.8
		MCWB	8.2	11.2	12.4	15.7	18.1	21.7	23.1	23.1	21.9	17.3	13.0	8.3
	5%	DB	9.8	12.8	15.9	19.8	22.7	24.8	27.3	26.7	24.4	19.9	16.4	11.1
		MCWB	6.2	9.9	12.0	14.8	17.7	21.0	22.8	22.8	21.1	16.0	11.7	6.7
	10%	DB	8.0	10.8	14.3	18.3	21.5	23.7	26.3	25.6	23.1	18.6	14.8	9.4
		MCWB	4.6	8.1	10.7	14.4	17.2	20.4	22.4	22.3	20.2	15.0	10.6	5.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	13.9	17.0	19.2	21.8	23.8	25.1	25.0	23.5	20.8	17.1	12.4
		MCDB	13.8	15.6	19.1	21.1	23.4	26.0	27.5	27.0	25.8	22.8	19.0	13.2
	2%	WB	9.5	12.2	14.8	17.9	20.7	22.6	24.0	24.0	22.5	18.7	15.1	10.1
		MCDB	10.8	13.9	16.4	19.6	22.1	24.9	27.0	26.4	24.9	20.2	16.3	11.5
	5%	WB	7.4	10.6	13.2	16.9	19.6	21.9	23.3	23.2	21.7	17.2	13.6	8.1
		MCDB	9.1	12.1	14.8	18.0	21.0	23.9	26.2	25.9	23.8	19.0	15.2	9.7
	10%	WB	5.2	8.8	11.6	15.9	18.7	21.2	22.7	22.6	20.8	16.0	11.9	6.0
		MCDB	7.1	10.3	13.3	17.2	20.1	22.9	25.5	25.0	22.6	17.6	13.7	8.0
Mean Daily Temperature Range	5% DB	MDBR	5.4	5.6	6.1	6.2	5.6	4.6	4.6	4.5	5.0	5.5	5.7	5.6
		MCDBR	7.0	7.5	7.6	7.6	7.0	6.0	5.8	5.8	6.1	6.3	6.8	7.0
		MCWBR	5.2	5.7	5.6	5.6	5.7	4.6	3.9	4.2	4.6	4.8	4.9	5.3
	5% WB	MCDBR	6.6	7.3	6.8	6.0	5.5	5.2	5.5	5.4	5.6	5.9	5.7	6.5
		MCWBR	5.6	5.8	5.9	5.0	4.7	4.1	4.0	4.1	4.4	4.4	4.3	5.5
Clear-Sky Solar Irradiance	taub	0.501	0.541	0.575	0.571	0.533	0.540	0.506	0.537	0.531	0.528	0.492	0.475	
	taud	1.792	1.738	1.699	1.759	1.905	1.939	2.072	1.959	1.917	1.824	1.854	1.857	
	Ebn at Noon	696	713	724	748	779	769	794	766	753	714	700	696	
	Edh at Noon	184	211	234	227	197	190	166	184	185	191	171	165	
All-Sky Solar Radiation	RadAvg	2.04	2.32	3.16	3.84	4.28	4.12	5.22	4.68	4.09	3.32	2.56	2.17	
	RadStd	0.35	0.61	0.25	0.42	0.46	0.46	0.54	0.48	0.37	0.42	0.38	0.42	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.25	N/A	N/A	+0.50	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.27	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+113	N/A

Nomenclature: See separate page