

SHENGXIAN, China

WMO: 585560

Lat: 29.5921N

Lon: 120.8111E

Elev: 354

StdP: 14.51

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.4	29.7	11.2	9.9	37.1	15.3	12.1	37.2	19.1	45.7	16.7	44.2	3.2	250	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	97.7	79.0	95.4	78.8	93.1	78.6	81.2	91.9	80.4	90.7	79.7	89.3	5.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.7	151.0	85.8	77.8	146.6	85.1	77.1	143.0	84.6	45.3	92.0	44.4	91.0	43.6	89.6	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.7	14.2	12.1	23.6	100.6	2.6	2.6	21.7	102.5	20.2	104.0	18.8	105.4	16.9	107.3	
			DB												
			WB	21.6	82.9	2.9	1.1	19.5	83.7	17.8	84.4	16.2	85.0	14.1	85.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.8	41.6	45.1	52.9	63.0	71.6	77.0	85.0	83.8	76.1	66.9	56.3	45.5
	DBStd	15.95	6.65	7.64	7.63	7.01	5.11	5.32	4.47	4.27	5.58	5.44	6.72	6.42
	HDD50	697	277	175	55	3	0	0	0	0	0	0	19	168
	HDD65	2710	727	558	382	119	7	0	0	0	0	41	270	606
	CDD50	5748	15	38	146	392	669	810	1084	1049	784	524	209	28
	CDD65	2286	0	1	7	58	211	361	619	584	335	100	10	0
	CDH74	22484	0	10	68	409	1413	2992	7781	6732	2584	445	49	1
	CDH80	9651	0	0	10	98	430	1137	3945	3073	871	80	7	0
Wind	WSAvg	4.9	5.3	5.7	5.5	5.1	4.6	4.0	4.6	4.8	4.8	4.8	4.7	5.0
Precipitation	PrecAvg	50.5	1.9	3.0	4.4	5.1	6.2	7.9	5.4	5.1	5.2	2.7	2.0	1.5
	PrecMax	66.1	4.8	6.9	8.9	9.3	17.8	13.9	13.1	12.7	13.2	7.5	6.9	5.7
	PrecMin	33.5	0.0	0.6	1.3	1.2	2.8	4.2	0.9	0.5	0.0	0.0	0.1	0.0
	PrecStd	8.9	1.2	1.7	2.2	1.9	3.0	2.9	3.1	2.7	3.2	2.2	1.7	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.1	75.4	80.8	87.3	92.5	96.1	100.9	101.1	94.8	86.5	79.9	66.1
		MCWB	59.3	60.0	63.3	67.7	71.8	78.7	78.2	78.4	78.9	73.1	66.4	55.7
	2%	DB	60.5	67.6	74.8	82.6	88.2	92.8	98.1	97.5	91.4	81.9	74.0	62.0
		MCWB	51.7	56.4	60.9	66.5	70.5	78.5	79.1	79.0	77.1	69.5	63.5	54.4
	5%	DB	55.4	62.0	69.8	78.7	84.8	89.6	96.2	94.8	88.2	78.6	69.9	58.6
		MCWB	48.4	53.2	57.5	64.3	69.5	76.9	79.0	78.8	76.3	67.8	62.0	51.8
	10%	DB	51.5	57.0	65.6	74.9	81.6	86.6	94.0	92.3	85.0	75.8	66.7	55.5
		MCWB	45.9	50.0	56.1	63.4	68.5	75.7	79.0	78.7	75.0	66.7	60.4	50.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.8	62.3	67.4	72.9	77.2	81.4	82.9	81.9	81.2	75.6	70.1	61.1
		MCDB	68.1	72.1	77.1	81.7	86.4	90.9	93.7	93.5	91.1	82.3	76.0	63.8
	2%	WB	54.1	58.0	63.0	70.3	75.2	80.0	81.5	80.9	79.2	73.3	66.9	56.7
		MCDB	58.9	65.9	70.4	76.8	82.8	89.1	92.3	91.8	87.3	78.2	70.5	59.5
	5%	WB	50.1	54.4	60.1	68.3	73.4	78.9	80.6	80.1	77.8	70.6	64.2	53.7
		MCDB	53.6	60.7	67.5	74.3	79.4	87.2	91.2	90.2	84.8	75.8	67.8	57.0
	10%	WB	46.7	50.8	57.6	65.7	71.7	77.5	79.9	79.3	76.5	68.7	61.5	50.9
		MCDB	50.3	55.7	63.5	72.2	77.5	84.3	90.0	88.6	82.7	74.0	65.5	54.2
Mean Daily Temperature Range	5% DB	MDBR	11.9	12.9	14.8	16.4	15.7	12.7	14.7	13.8	13.0	14.3	14.0	13.4
		MCDBR	21.0	24.1	24.0	23.5	22.4	18.1	18.5	18.6	17.1	18.6	20.7	20.0
		MCWBR	12.6	13.4	11.6	10.0	8.4	6.0	4.8	4.6	5.3	7.2	9.9	11.5
	5% WB	MCDBR	17.0	20.9	19.2	17.5	15.4	15.2	16.2	15.9	14.5	14.3	13.7	13.5
		MCWBR	11.5	12.7	11.0	9.6	7.7	5.8	5.4	5.0	5.3	7.2	8.1	9.2
Clear-Sky Solar Irradiance	taub		0.599	0.642	0.685	0.693	0.657	0.669	0.622	0.647	0.632	0.606	0.587	0.570
	taud		1.651	1.591	1.548	1.583	1.692	1.710	1.835	1.761	1.761	1.731	1.725	1.712
	Ebn at Noon		192	199	203	209	218	214	224	217	213	206	194	192
	Edh at Noon		68	78	86	86	77	76	67	71	69	67	62	61
All-Sky Solar Radiation	RadAvg		690	803	1091	1306	1398	1264	1761	1508	1179	1051	764	710
	RadStd		119	188	102	157	180	188	193	171	139	167	112	136

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+0.49	N/A	N/A	N/A	N/A	N/A	N/A	+187	+112

Nomenclature: See separate page