

NANCHANG, China

WMO: 586060

Lat: 28.5901N

Lon: 115.9014E

Elev: 164

StdP: 14.61

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.9	32.9	13.1	10.8	39.6	17.8	13.6	40.4	13.4	42.9	11.9	40.7	4.7	20	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	96.7	80.0	95.0	79.9	93.3	79.6	82.7	91.1	81.9	90.3	81.1	89.4	6.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.8	160.7	87.0	79.8	155.7	86.6	79.0	151.3	86.2	46.9	91.2	46.0	90.6	45.1	89.5	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.5	9.3	28.4	99.1	2.7	2.0	26.5	100.5	24.9	101.7	23.4	102.8	21.4	104.3		
(5)			24.9	83.9	2.4	1.3	23.2	84.8	21.8	85.5	20.5	86.3	18.7	87.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.9	43.2	47.3	54.8	65.6	74.4	79.4	85.9	85.2	78.8	69.7	58.3	47.4	(6)
(7)		DBStd	15.92	6.27	7.90	7.84	7.04	5.07	4.87	4.55	4.40	5.72	5.74	7.01	5.77	(7)
(8)		HDD50	530	228	134	38	1	0	0	0	0	0	12	117		(8)
(9)		HDD65	2371	677	497	330	76	2	0	0	0	23	221	545		(9)
(10)		CDD50	6344	16	60	186	471	755	882	1114	1091	863	609	260	37	(10)
(11)		CDD65	2708	0	2	13	95	292	432	649	626	413	167	19	0	(11)
(12)		CDH74	28134	0	12	73	498	1999	4087	8696	8040	3896	770	63	0	(12)
(13)		CDH80	12484	0	1	12	105	567	1500	4625	4024	1477	164	9	0	(13)
(14)	Wind	WSAvg	4.2	4.1	4.3	4.2	4.2	3.9	4.4	4.5	4.6	4.4	4.1	4.1		(14)
(15)	Precipitation	PrecAvg	61.1	2.8	3.8	6.7	8.6	9.4	12.2	5.4	4.2	2.8	2.1	2.5	1.9	(15)
(16)		PrecMax	89.5	13.3	8.9	15.4	19.3	21.1	28.9	18.0	14.1	8.5	7.3	7.5	6.5	(16)
(17)		PrecMin	41.1	0.0	0.7	2.0	3.0	1.8	4.9	0.4	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	11.9	2.2	2.1	2.9	3.5	4.3	5.3	3.8	2.8	2.1	1.5	1.9	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.5	75.8	81.4	87.2	92.1	95.0	99.5	99.0	95.6	89.4	80.3	65.9	(19)
(20)		MCWB	56.9	63.5	68.7	71.4	74.5	80.6	80.6	80.0	79.5	74.9	66.1	55.0		(20)
(21)		2%	DB	59.5	68.0	74.9	83.0	88.6	92.5	97.1	96.5	92.7	84.2	75.1	61.4	(21)
(22)		MCWB	51.5	58.1	63.9	70.2	73.6	79.4	80.0	80.0	78.7	70.3	62.9	53.2		(22)
(23)		5%	DB	55.6	62.7	70.2	79.7	85.8	90.3	95.6	94.8	90.3	80.9	71.6	58.6	(23)
(24)		MCWB	48.6	54.5	60.7	68.6	73.1	78.6	79.9	80.0	78.0	68.5	61.0	50.8		(24)
(25)		10%	DB	52.1	58.3	66.3	76.3	83.0	87.7	93.8	92.8	87.6	78.2	68.1	55.8	(25)
(26)		MCWB	46.0	52.1	59.3	67.2	72.4	77.8	79.7	79.8	76.9	66.5	59.5	48.9		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.9	64.3	70.8	75.1	79.1	82.4	83.7	83.8	82.4	76.9	69.8	59.6	(27)
(28)		MCDWB	62.1	73.0	79.3	82.2	86.6	91.1	91.9	91.5	90.4	83.5	77.2	61.9		(28)
(29)		2%	WB	53.1	60.0	66.5	73.0	77.4	81.1	82.7	82.8	80.9	73.5	66.0	55.6	(29)
(30)		MCDWB	57.8	67.1	72.4	79.5	84.0	88.9	91.3	90.9	88.7	81.8	71.6	59.1		(30)
(31)		5%	WB	49.5	55.9	63.1	71.3	76.2	80.1	81.9	81.9	79.6	71.1	63.6	52.2	(31)
(32)		MCDWB	54.0	61.0	68.2	76.4	82.0	87.4	90.6	90.2	87.3	77.9	68.8	56.6		(32)
(33)		10%	WB	46.8	53.0	60.1	69.2	74.6	79.1	81.2	81.0	78.3	69.4	61.3	49.8	(33)
(34)		MCDWB	51.2	57.3	64.9	74.4	80.1	85.8	89.8	89.3	85.9	75.4	66.7	54.4		(34)
(35)	Mean Daily Temperature Range	MDBR	8.8	9.8	10.7	11.7	11.5	10.2	11.5	11.1	11.1	11.5	11.2	10.3		(35)
(36)		5% DB	MCDBR	15.3	17.7	17.9	17.3	16.0	13.7	13.5	13.1	13.7	15.3	16.4	15.1	(36)
(37)		MCWBR	8.8	9.8	8.9	7.8	5.9	4.5	3.6	3.8	4.5	5.9	7.1	8.0		(37)
(38)		5% WB	MCDBR	13.1	16.5	15.5	14.3	12.4	12.7	12.7	12.4	12.6	13.5	12.8	11.2	(38)
(39)		MCWBR	8.5	10.4	9.4	8.2	6.2	4.9	4.4	4.3	4.8	6.4	6.8	7.3		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.677	0.721	0.774	0.759	0.691	0.675	0.622	0.666	0.678	0.701	0.653	0.634		(40)
(41)		taud	1.521	1.478	1.426	1.494	1.651	1.701	1.833	1.713	1.657	1.558	1.601	1.602		(41)
(42)		Ebn at Noon	175	182	185	196	211	213	224	213	204	185	179	177		(42)
(43)		Edh at Noon	78	88	98	94	81	76	67	75	77	80	71	69		(43)
(44)	All-Sky Solar Radiation	RadAvg	636	737	942	1165	1330	1314	1750	1565	1340	1099	828	714		(44)
(45)		RadStd	124	198	95	140	158	165	153	149	121	149	142	152		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		+0.85	N/A	N/A	+1.26	N/A	-0.54	N/A	-117	+306	+178
(47)	Regional (7 neighbors)	+0.72	N/A	N/A	+0.97	N/A	N/A	N/A	N/A	+297	+184

Nomenclature: See separate page