

NANCHANG, China

WMO: 586060

Lat: 28.5901N

Lon: 115.9014E

Elev: 50

StdP: 100.73

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.6	0.5	-10.5	1.5	4.2	-7.9	1.9	4.7	6.0	6.1	5.3	4.9	2.1	20	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.4	35.9	26.7	35.0	26.6	34.0	26.4	28.2	32.8	27.7	32.4	27.3	31.9	2.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.1	23.0	30.6	26.6	22.2	30.3	26.1	21.6	30.1	91.2	32.9	89.1	32.6	87.1	31.9	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.4	4.7	4.2	-2.0	37.3	1.5	1.1	-3.1	38.1	-4.0	38.7	-4.8	39.4	-5.9	40.2
			-3.9	28.8	1.3	0.7	-4.9	29.3	-5.7	29.7	-6.4	30.1	-7.4	30.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.8	6.2	8.5	12.7	18.7	23.5	26.3	30.0	29.6	26.0	20.9	14.6	8.6	(6)
(7)		DBStd	8.85	3.48	4.39	4.36	3.91	2.82	2.70	2.53	2.45	3.18	3.19	3.89	3.20	(7)
(8)		HDD10.0	294	127	74	21	1	0	0	0	0	0	7	65	(8)	
(9)		HDD18.3	1317	376	276	183	42	1	0	0	0	13	123	303	(9)	
(10)		CDD10.0	3524	9	33	103	262	419	490	619	606	479	338	144	21	(10)
(11)		CDD18.3	1504	0	1	7	53	162	240	361	348	229	93	11	0	(11)
(12)		CDH23.3	15630	0	7	41	277	1111	2271	4831	4467	2164	428	35	0	(12)
(13)		CDH26.7	6936	0	1	7	58	315	833	2569	2236	821	91	5	0	(13)
(14)	Wind	WSAvg	1.9	1.8	1.9	1.9	1.9	1.8	1.8	2.0	2.0	2.0	1.8	1.8	(14)	
(15)	Precipitation	PrecAvg	1553	71	97	169	219	239	311	136	107	70	54	63	48	(15)
(16)		PrecMax	2273	338	227	390	491	537	735	457	357	217	185	191	165	(16)
(17)		PrecMin	1045	0	18	51	75	45	125	11	1	1	0	1	0	(17)
(18)		PrecStd	302	57	53	73	90	109	135	97	71	53	38	47	42	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	18.1	24.3	27.4	30.7	33.4	35.0	37.5	37.2	35.3	31.9	26.8	18.9	(19)	
(20)		MCWB	13.8	17.5	20.4	21.9	23.6	27.0	27.0	26.7	26.4	23.8	19.0	12.8	(20)	
(21)		DB	15.3	20.0	23.8	28.3	31.4	33.6	36.2	35.9	33.7	29.0	24.0	16.3	(21)	
(22)		MCWB	10.8	14.5	17.7	21.2	23.1	26.4	26.7	26.6	25.9	21.3	17.1	11.8	(22)	
(23)		DB	13.1	17.1	21.2	26.5	29.9	32.4	35.3	34.9	32.4	27.2	22.0	14.8	(23)	
(24)		MCWB	9.2	12.5	16.0	20.3	22.8	25.9	26.6	26.7	25.5	20.3	16.1	10.4	(24)	
(25)		DB	11.2	14.6	19.1	24.6	28.3	30.9	34.3	33.8	30.9	25.7	20.0	13.2	(25)	
(26)		MCWB	7.8	11.2	15.1	19.5	22.5	25.5	26.5	26.6	24.9	19.2	15.3	9.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	14.9	17.9	21.6	23.9	26.2	28.0	28.7	28.8	28.0	24.9	21.0	15.4	(27)	
(28)		MCDWB	16.7	22.8	26.3	27.9	30.3	32.8	33.3	33.1	32.4	28.6	25.1	16.6	(28)	
(29)		WB	11.7	15.6	19.2	22.8	25.2	27.3	28.2	28.2	27.2	23.0	18.9	13.1	(29)	
(30)		MCDWB	14.4	19.5	22.4	26.4	28.9	31.6	32.9	32.7	31.5	27.7	22.0	15.1	(30)	
(31)		WB	9.7	13.3	17.3	21.8	24.5	26.7	27.7	27.7	26.4	21.7	17.5	11.2	(31)	
(32)		MCDWB	12.2	16.1	20.1	24.7	27.8	30.8	32.5	32.3	30.7	25.5	20.4	13.7	(32)	
(33)		WB	8.2	11.7	15.6	20.7	23.6	26.2	27.3	27.2	25.7	20.8	16.3	9.9	(33)	
(34)		MCDWB	10.7	14.1	18.3	23.6	26.7	29.9	32.1	31.8	29.9	24.1	19.3	12.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	4.9	5.5	6.0	6.5	6.4	5.7	6.4	6.2	6.1	6.4	6.2	5.7	(35)	
(36)		5% DB	8.5	9.8	9.9	9.6	8.9	7.6	7.5	7.3	7.6	8.5	9.1	8.4	(36)	
(37)		MCWBR	4.9	5.4	4.9	4.4	3.3	2.5	2.0	2.1	2.5	3.3	4.0	4.4	(37)	
(38)		MCDBR	7.3	9.1	8.6	8.0	6.9	7.1	7.1	6.9	7.0	7.5	7.1	6.2	(38)	
(39)		MCWBR	4.7	5.8	5.2	4.6	3.4	2.7	2.4	2.4	2.7	3.6	3.8	4.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.677	0.721	0.774	0.759	0.691	0.675	0.622	0.666	0.678	0.701	0.653	0.634	(40)	
(41)		taud	1.521	1.478	1.426	1.494	1.651	1.701	1.833	1.713	1.657	1.558	1.601	1.602	(41)	
(42)		Ebn at Noon	551	575	584	618	665	672	707	671	642	582	565	557	(42)	
(43)		Edh at Noon	247	278	310	297	255	241	211	236	242	253	225	218	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.00	2.32	2.97	3.67	4.19	4.14	5.52	4.93	4.22	3.46	2.61	2.25	(44)	
(45)		RadStd	0.39	0.62	0.30	0.44	0.50	0.52	0.48	0.47	0.38	0.47	0.45	0.48	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.47	N/A	N/A	+0.70	N/A	-0.30	N/A	-65	+170	+99
(47)	Regional (7 neighbors)	+0.40	N/A	N/A	+0.54	N/A	N/A	N/A	N/A	+165	+102

Nomenclature: See separate page