

QUZHOU, China

WMO: 586330

Lat: 28.9680N

Lon: 118.8938E

Elev: 233

StdP: 14.57

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 29.2	(c) 31.6	(d) 16.4	(e) 12.7	(f) 39.8	(g) 20.2	(h) 15.3	(i) 37.8	(j) 16.9	(k) 44.8	(l) 15.9	(m) 43.5	(n) 4.1	(o) 70	(p) 0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 14.5	(c) 97.9	(d) 78.6	(e) 95.9	(f) 78.6	(g) 93.8	(h) 78.3	(i) 81.4	(j) 90.7	(k) 80.6	(l) 89.9	(m) 79.8	(n) 88.9	(o) 7.5	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.4	154.0	84.3	78.4	148.8	84.1	77.6	144.6	83.9	45.4	90.4	44.5	89.9	43.7	89.2	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 16.0	(b) 14.1	(c) 12.5	(e) 25.5	(f) 100.7	(g) 3.0	(h) 2.2	(i) 23.3	(j) 102.3	(k) 21.5	(l) 103.6	(m) 19.8	(n) 104.9	(o) 17.6	(p) 106.5		
(a) 16.0	(b) 14.1	(c) 12.5	(e) 24.0	(f) 82.6	(g) 2.8	(h) 1.1	(i) 22.0	(j) 83.4	(k) 20.3	(l) 84.0	(m) 18.7	(n) 84.6	(o) 16.7	(p) 85.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.0	43.0	46.8	54.1	64.4	72.9	77.8	85.3	84.4	77.4	68.3	57.5	46.8		
	DBStd	15.62	6.30	7.45	7.35	6.72	4.94	5.22	4.43	4.14	5.80	5.57	6.51	6.11		
	HDD50	560	232	140	39	2	0	0	0	0	0	0	12	135		
	HDD65	2464	681	510	347	91	4	0	0	0	0	29	237	565		
	CDD50	6029	16	50	166	433	709	834	1094	1066	823	567	237	34		
	CDD65	2461	0	1	9	72	248	384	629	601	373	131	13	0		
	CDH74	24885	0	11	77	459	1690	3315	8056	7242	3304	671	59	1		
	CDH80	10943	0	0	12	110	537	1275	4164	3453	1241	144	7	0		
(14) Wind	WSAvg	5.7	5.7	6.1	6.0	5.6	5.5	5.1	5.5	5.8	6.0	6.0	5.4	5.3		
(15) Precipitation	PrecAvg	64.2	2.7	4.5	7.2	8.2	10.3	10.9	5.1	3.5	4.0	3.0	2.6	2.0		
	PrecMax	97.1	6.3	10.1	13.3	16.9	22.3	18.1	16.7	9.9	11.4	10.3	6.5	6.1		
	PrecMin	43.2	0.0	0.6	2.8	2.1	3.0	4.7	0.3	0.2	0.4	0.0	0.0	0.0		
	PrecStd	13.7	1.6	2.4	2.6	3.3	4.2	4.1	4.0	2.1	2.3	2.5	1.8	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.9	75.6	81.3	87.8	93.3	96.0	101.1	100.6	97.1	89.2	80.2	66.9		
		MCWB	57.3	62.0	65.3	68.6	73.2	78.9	78.6	77.5	78.3	73.8	66.8	56.5		
	2%	DB	61.0	67.9	75.2	83.1	89.2	93.2	98.4	97.8	93.1	83.9	74.9	62.4		
		MCWB	53.4	58.7	61.5	67.8	71.4	78.3	78.5	78.7	77.4	70.6	63.3	54.2		
	5%	DB	56.4	62.6	70.0	79.2	85.8	90.3	96.5	95.5	90.0	80.5	71.1	59.3		
		MCWB	49.7	54.8	58.5	66.1	70.7	77.0	78.7	78.8	76.5	68.2	61.9	52.7		
	10%	DB	52.7	58.0	65.9	75.6	82.5	87.2	94.5	93.0	86.9	77.5	67.6	56.5		
		MCWB	47.5	51.6	57.3	65.0	70.0	75.7	78.5	78.4	75.1	66.7	60.9	51.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.7	63.5	69.7	73.8	78.8	81.4	82.6	82.4	80.8	76.2	70.4	60.8		
		MCDB	65.6	71.5	77.9	81.1	84.1	89.1	92.2	91.9	90.9	84.2	74.6	63.1		
	2%	WB	55.0	59.7	64.9	71.6	76.4	80.1	81.5	81.1	79.2	74.0	67.1	57.4		
		MCDB	58.4	66.8	70.9	77.7	82.4	88.2	91.1	90.4	87.8	80.2	70.9	60.1		
	5%	WB	51.2	55.8	61.7	69.7	74.8	79.0	80.8	80.3	78.2	71.8	64.5	54.6		
		MCDB	55.0	60.8	67.3	75.0	80.1	87.1	90.4	89.4	86.2	77.6	68.3	57.3		
	10%	WB	48.4	52.6	59.0	67.7	73.0	77.9	80.0	79.6	77.1	69.7	62.0	51.8		
		MCDB	51.7	56.8	63.6	72.6	78.7	85.0	89.4	88.5	84.6	75.3	66.3	54.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	12.2	13.7	14.6	14.4	12.1	14.5	13.9	13.3	14.1	13.7	13.2		
		MCDBR	20.4	22.4	23.1	22.3	21.9	17.5	18.3	18.1	17.4	18.4	20.8	19.3		
		MCWBR	12.0	12.6	10.8	9.1	7.7	5.3	4.2	4.3	5.1	6.7	9.7	10.7		
	5% WB	MCDBR	15.9	18.8	17.7	16.2	14.3	15.1	16.1	15.3	15.1	13.5	13.1	11.8		
		MCWBR	10.3	11.8	10.1	8.3	6.8	5.6	4.9	4.7	5.0	6.3	7.7	8.1		
(40) Clear-Sky Solar Irradiance	taub		0.660	0.713	0.769	0.764	0.702	0.698	0.646	0.681	0.693	0.675	0.633	0.613		
	taud		1.553	1.486	1.430	1.483	1.623	1.656	1.782	1.689	1.639	1.602	1.643	1.637		
	Ebn at Noon		178	184	186	195	208	208	219	209	200	190	184	181		
	Edh at Noon		75	87	98	95	83	80	70	76	78	76	68	66		
(44) All-Sky Solar Radiation	RadAvg		681	790	1028	1214	1335	1237	1707	1498	1254	1104	814	740		
	RadStd		132	202	105	160	183	184	180	167	109	174	126	151		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+191	+94
(47) Regional (10 neighbors)	+0.59	N/A	N/A	+0.85	N/A	N/A	N/A	N/A	+243	+140

Nomenclature: See separate page