

QUZHOU, China

WMO: 586330

Lat: 28.9680N

Lon: 118.8938E

Elev: 71

StdP: 100.47

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.5	(c) -0.2	(d) -8.6	(e) 1.8	(f) 4.3	(g) -6.6	(h) 2.2	(i) 3.2	(j) 7.5	(k) 7.1	(l) 7.1	(m) 6.4	(n) 1.8	(o) 70	(p) 0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.1	(c) 36.6	(d) 25.9	(e) 35.5	(f) 25.9	(g) 34.3	(h) 25.7	(i) 27.4	(j) 32.6	(k) 27.0	(l) 32.1	(m) 26.6	(n) 31.6	(o) 3.4	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 26.3	(b) 22.0	(c) 29.0	(d) 25.8	(e) 21.3	(f) 28.9	(g) 25.3	(h) 20.7	(i) 28.8	(j) 87.7	(k) 32.4	(l) 85.7	(m) 32.2	(n) 83.8	(o) 31.8	(p) 29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.2	(b) 6.3	(c) 5.6	(e) -3.6	(f) 38.2	(g) 1.7	(h) 1.2	(i) -4.8	(j) 39.1	(k) -5.8	(l) 39.8	(m) -6.8	(n) 40.5	(o) -8.0	(p) 41.4		
(a) 7.2	(b) 6.3	(c) 5.6	(e) -4.5	(f) 28.1	(g) 1.6	(h) 0.6	(i) -5.6	(j) 28.5	(k) -6.5	(l) 28.9	(m) -7.4	(n) 29.2	(o) -8.5	(p) 29.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	6.1	8.2	12.3	18.0	22.7	25.4	29.6	29.1	25.2	20.2	14.2	8.2
	DBStd	8.68	3.50	4.14	4.08	3.73	2.74	2.90	2.46	2.30	3.22	3.09	3.62	3.39
	HDD10.0	311	129	78	22	1	0	0	0	0	0	0	7	75
	HDD18.3	1369	378	283	193	51	2	0	0	0	0	16	132	314
	CDD10.0	3349	9	28	92	241	394	463	608	592	457	315	132	19
	CDD18.3	1367	0	1	5	40	138	213	349	334	207	73	7	0
	CDH23.3	13825	0	6	43	255	939	1842	4476	4023	1836	373	33	1
CDH26.7	6079	0	0	7	61	298	708	2313	1918	689	80	4	0	
Wind	WSAvg	2.5	2.6	2.7	2.7	2.5	2.4	2.3	2.4	2.6	2.7	2.7	2.4	2.4
Precipitation	PrecAvg	1630	69	114	183	208	262	276	130	88	102	76	65	50
	PrecMax	2467	160	257	337	429	567	461	423	252	289	261	166	155
	PrecMin	1098	0	16	71	54	77	120	8	6	11	0	0	0
	PrecStd	347	41	62	65	84	106	104	101	54	58	63	46	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.4	24.2	27.4	31.0	34.0	35.6	38.4	38.1	36.2	31.8	26.8	19.4
		MCWB	14.1	16.7	18.5	20.3	22.9	26.1	25.9	25.3	25.7	23.2	19.3	13.6
	2%	DB	16.1	20.0	24.0	28.4	31.8	34.0	36.9	36.5	33.9	28.8	23.8	16.9
		MCWB	11.9	14.8	16.4	19.9	21.9	25.7	25.9	25.9	25.2	21.4	17.4	12.3
	5%	DB	13.6	17.0	21.1	26.2	29.9	32.4	35.8	35.3	32.2	26.9	21.7	15.2
		MCWB	9.9	12.6	14.7	19.0	21.5	25.0	25.9	26.0	24.7	20.1	16.6	11.5
	10%	DB	11.5	14.4	18.8	24.2	28.1	30.7	34.7	33.9	30.5	25.3	19.8	13.6
		MCWB	8.6	10.9	14.0	18.3	21.1	24.3	25.9	25.8	24.0	19.3	16.1	10.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	17.5	20.9	23.2	26.0	27.5	28.1	28.0	27.1	24.6	21.4	16.0
		MCDB	18.7	21.9	25.5	27.3	29.0	31.7	33.4	33.3	32.7	29.0	23.7	17.3
	2%	WB	12.8	15.4	18.3	22.0	24.7	26.7	27.5	27.3	26.2	23.4	19.5	14.1
		MCDB	14.6	19.3	21.6	25.4	28.0	31.2	32.8	32.4	31.0	26.8	21.6	15.6
	5%	WB	10.7	13.2	16.5	21.0	23.8	26.1	27.1	26.8	25.6	22.1	18.1	12.6
		MCDB	12.8	16.0	19.6	23.9	26.7	30.6	32.4	31.9	30.1	25.3	20.2	14.1
	10%	WB	9.1	11.5	15.0	19.8	22.8	25.5	26.7	26.5	25.0	20.9	16.7	11.0
		MCDB	11.0	13.8	17.6	22.6	26.0	29.4	31.9	31.4	29.2	24.1	19.1	12.6
Mean Daily Temperature Range	5% DB	MDBR	6.2	6.8	7.6	8.1	8.0	6.7	8.1	7.7	7.4	7.8	7.6	7.3
		MCDBR	11.3	12.4	12.9	12.4	12.2	9.7	10.2	10.1	9.7	10.2	11.6	10.7
		MCWBR	6.6	7.0	6.0	5.0	4.3	3.0	2.3	2.4	2.9	3.7	5.4	6.0
	5% WB	MCDBR	8.8	10.4	9.8	9.0	8.0	8.4	8.9	8.5	8.4	7.5	7.3	6.6
		MCWBR	5.7	6.5	5.6	4.6	3.8	3.1	2.7	2.6	2.8	3.5	4.3	4.5
Clear-Sky Solar Irradiance	taub		0.660	0.713	0.769	0.764	0.702	0.698	0.646	0.681	0.693	0.675	0.633	0.613
	taud		1.553	1.486	1.430	1.483	1.623	1.656	1.782	1.689	1.639	1.602	1.643	1.637
	Ebn at Noon		561	579	586	614	657	657	691	660	630	598	579	571
	Edh at Noon		238	275	308	301	262	252	222	241	246	241	215	209
All-Sky Solar Radiation	RadAvg		2.15	2.49	3.24	3.83	4.21	3.90	5.38	4.72	3.95	3.48	2.56	2.33
	RadStd		0.42	0.64	0.33	0.50	0.58	0.58	0.57	0.53	0.34	0.55	0.40	0.48

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+106	+52
Regional (10 neighbors)	+0.33	N/A	N/A	+0.47	N/A	N/A	N/A	N/A	+135	+78

Nomenclature: See separate page