

KUOCANG SHAN, China

WMO: 586530

Lat: 28.810N

Lon: 120.921E

Elev: 4511

StdP: 12.45

Time Zone: 8.00 (E08)

Period: 86-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.3	17.3	-8.8	4.0	30.7	-2.0	5.8	31.2	36.5	37.9	33.8	30.2	17.7	0	0.637

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	79.4	71.1	77.5	70.2	75.5	69.1	72.5	77.2	71.3	75.8	70.2	74.2	4.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.1	136.0	75.1	69.9	130.5	74.0	68.9	125.8	72.7	39.5	77.5	38.4	76.0	37.3	74.6	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
34.4	30.1	26.8	DB	7.3	83.2	2.8	2.1	5.3	84.7	3.6	85.9	2.1	87.1	0.1	88.6	
			WB	6.2	75.9	2.5	1.1	4.4	76.7	3.0	77.4	1.6	78.0	-0.2	78.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.1	32.3	33.9	40.3	50.4	57.9	64.3	70.6	68.2	60.9	51.8	44.2	37.1
	DBStd	14.77	8.23	9.35	8.98	8.30	6.74	5.21	4.36	3.90	5.34	5.90	8.84	8.62
	HDD50	2102	549	458	321	94	14	1	0	0	1	49	212	403
	HDD65	5461	1012	871	767	438	234	75	9	13	143	411	624	864
	CDD50	2495	1	7	19	106	258	428	640	563	327	104	38	4
	CDD65	382	0	0	0	1	13	53	184	111	19	1	0	0
	CDH74	738	0	0	0	0	14	67	466	176	14	0	1	0
	CDH80	39	0	0	0	0	0	1	35	2	1	0	0	0
Wind	WSAvg	12.4	13.2	13.3	13.2	12.2	12.0	12.0	12.5	10.9	12.4	12.1	12.5	12.8
Precipitation	PrecAvg	82.6	2.7	3.5	5.1	6.4	8.7	11.1	8.9	13.7	11.6	5.0	3.9	2.2
	PrecMax	129.4	5.9	8.0	8.8	10.7	16.9	18.1	21.5	39.2	30.0	13.5	9.8	6.1
	PrecMin	53.0	0.4	1.0	2.3	1.8	3.9	6.4	2.2	2.4	0.9	0.1	0.4	0.0
	PrecStd	17.0	1.7	1.7	1.8	2.4	2.9	2.9	4.7	9.5	8.5	3.9	2.5	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	59.9	64.8	70.2	75.9	79.0	83.3	79.9	76.0	69.3	66.2	57.1
		MCWB	48.2	48.5	57.6	61.6	67.4	71.0	72.0	71.7	69.0	64.3	61.3	48.1
	2%	DB	50.8	55.5	60.3	67.2	71.9	76.0	80.7	78.0	72.4	65.2	61.5	54.0
		MCWB	47.2	49.0	55.1	60.3	64.9	69.7	71.5	70.9	67.7	59.1	57.8	47.2
	5%	DB	48.0	51.8	56.8	64.7	69.3	73.4	78.7	76.1	69.4	62.8	58.4	51.5
		MCWB	45.1	47.6	53.6	59.2	62.4	68.3	70.7	69.8	66.3	57.6	54.1	45.8
	10%	DB	44.7	48.3	53.9	61.6	67.0	71.2	76.7	74.0	67.4	60.0	55.7	49.2
		MCWB	42.5	45.1	51.4	57.2	60.6	67.1	69.8	68.6	65.3	55.5	52.2	43.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.4	53.2	58.6	64.7	68.8	72.8	74.7	72.9	70.8	65.7	62.4	52.7
		MCDB	51.7	55.6	62.4	68.5	73.0	76.3	79.7	77.6	73.6	67.8	64.2	54.5
	2%	WB	48.6	51.4	56.7	62.3	66.7	70.5	73.1	71.7	69.0	62.3	59.5	50.4
		MCDB	50.0	53.9	59.3	65.3	70.6	74.1	78.0	76.1	71.2	63.8	61.6	51.8
	5%	WB	46.1	48.9	54.2	60.3	64.9	69.1	71.9	70.7	67.5	59.2	56.3	47.8
		MCDB	47.7	50.6	56.1	63.1	67.7	72.6	76.9	74.6	68.8	61.0	57.6	49.5
	10%	WB	43.2	46.2	51.9	58.4	63.1	67.8	70.8	69.6	66.2	56.8	54.0	45.3
		MCDB	44.7	48.1	53.8	60.7	65.3	70.7	75.4	73.0	67.0	58.7	55.1	48.6
Mean Daily Temperature Range		MDBR	10.7	10.2	10.7	10.5	9.5	8.2	8.9	8.2	7.7	9.6	10.7	11.2
		MCDBR	14.1	11.7	11.8	12.1	11.4	10.8	11.9	11.4	9.9	11.6	12.5	12.5
		MCWBR	11.6	8.0	8.8	8.6	9.3	8.5	9.9	7.9	8.4	10.6	10.8	8.8
	5% WB	MCDDBR	13.0	11.2	11.0	10.9	9.6	9.7	10.8	10.2	8.0	10.7	11.6	10.2
		MCWBR	11.5	9.3	8.8	8.3	7.8	7.8	9.6	7.7	7.1	9.8	9.8	8.7
Clear-Sky Solar Irradiance	taub	0.447	0.484	0.519	0.527	0.499	0.503	0.473	0.489	0.474	0.454	0.436	0.424	
	taud	1.934	1.870	1.821	1.858	1.996	2.045	2.162	2.097	2.089	2.039	2.030	2.005	
	Ebn at Noon	241	245	246	249	256	253	261	256	255	251	244	242	
	Edh at Noon	51	59	66	65	57	54	48	51	50	49	46	45	
All-Sky Solar Radiation	RadAvg	718	825	1091	1284	1357	1297	1803	1551	1249	1113	794	742	
	RadStd	130	193	110	150	184	176	183	161	134	177	114	130	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	+184	+104

Nomenclature: See separate page