

KUOCANG SHAN, China

WMO: 586530

Lat: 28.810N

Lon: 120.921E

Elev: 1375

StdP: 85.86

Time Zone: 8.00 (E08)

Period: 86-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.8	-8.2	-22.7	0.6	-0.7	-18.9	0.8	-0.4	16.3	3.3	15.1	-1.0	7.9	0	0.637

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.0	26.3	21.7	25.3	21.2	24.2	20.6	22.5	25.1	21.8	24.3	21.2	23.4	2.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.7	19.4	24.0	21.1	18.6	23.3	20.5	18.0	22.6	74.0	25.3	71.3	24.4	68.9	23.6	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	15.4	13.5	12.0	DB	-13.7	28.4	1.5	1.2	-14.9	29.3	-15.8	30.0	-16.6	30.6	-17.7	31.5
(5)				WB	-14.3	24.4	1.4	0.6	-15.3	24.8	-16.1	25.2	-16.9	25.6	-17.9	26.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	0.2	1.1	4.6	10.2	14.4	17.9	21.5	20.1	16.0	11.0	6.8	2.8
	DBStd	8.21	4.57	5.19	4.99	4.61	3.74	2.89	2.42	2.17	2.97	3.28	4.91	4.79
	HDD10.0	1168	305	254	178	52	8	1	0	0	1	27	118	224
	HDD18.3	3034	562	484	426	243	130	42	5	7	79	228	347	480
	CDD10.0	1386	1	4	11	59	143	238	356	313	182	58	21	2
	CDD18.3	212	0	0	0	1	7	29	102	62	11	1	0	0
	CDH23.3	410	0	0	0	0	8	37	259	98	8	0	1	0
	CDH26.7	22	0	0	0	0	0	1	19	1	1	0	0	0
Wind	WSAvg	5.6	5.9	6.0	5.9	5.5	5.4	5.4	5.6	4.9	5.5	5.4	5.6	5.7
Precipitation	PrecAvg	2097	69	88	129	162	221	283	225	347	295	127	99	56
	PrecMax	3288	151	204	224	272	429	460	546	995	761	344	248	154
	PrecMin	1347	11	26	58	45	100	163	57	60	22	2	9	1
	PrecStd	432	42	44	45	60	74	73	119	241	215	100	64	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	15.5	18.2	21.2	24.4	26.1	28.5	26.6	24.4	20.7	19.0	13.9
		MCWB	9.0	9.2	14.2	16.5	19.7	21.7	22.2	22.1	20.5	17.9	16.3	8.9
	2%	DB	10.5	13.1	15.7	19.6	22.1	24.4	27.0	25.6	22.5	18.5	16.4	12.2
		MCWB	8.5	9.4	12.8	15.7	18.3	20.9	22.0	21.6	19.8	15.1	14.3	8.5
	5%	DB	8.9	11.0	13.8	18.2	20.7	23.0	25.9	24.5	20.8	17.1	14.6	10.8
		MCWB	7.3	8.6	12.0	15.1	16.9	20.2	21.5	21.0	19.0	14.2	12.3	7.7
	10%	DB	7.1	9.0	12.2	16.4	19.4	21.8	24.9	23.3	19.7	15.6	13.2	9.5
		MCWB	5.8	7.3	10.8	14.0	15.9	19.5	21.0	20.3	18.5	13.1	11.2	6.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	11.8	14.8	18.2	20.4	22.6	23.7	22.7	21.6	18.7	16.9	11.5
		MCDB	11.0	13.1	16.9	20.3	22.8	24.6	26.5	25.3	23.1	19.9	17.9	12.5
	2%	WB	9.2	10.8	13.7	16.8	19.3	21.4	22.9	22.1	20.6	16.8	15.3	10.2
		MCDB	10.0	12.1	15.2	18.5	21.4	23.4	25.6	24.5	21.8	17.7	16.5	11.0
	5%	WB	7.8	9.4	12.4	15.7	18.3	20.6	22.2	21.5	19.7	15.1	13.5	8.8
		MCDB	8.7	10.3	13.4	17.3	19.8	22.5	25.0	23.7	20.4	16.1	14.2	9.7
	10%	WB	6.2	7.9	11.1	14.7	17.3	19.9	21.5	20.9	19.0	13.8	12.2	7.4
		MCDB	7.1	9.0	12.1	15.9	18.5	21.5	24.1	22.8	19.4	14.8	12.8	9.2
Mean Daily Temperature Range	5% DB	MDBR	5.9	5.7	6.0	5.8	5.3	4.6	5.0	4.5	4.3	5.3	5.9	6.2
		MCDBR	7.8	6.5	6.5	6.7	6.3	6.0	6.6	6.3	5.5	6.4	7.0	6.9
		MCWBR	6.4	4.5	4.9	4.8	5.2	4.7	5.5	4.4	4.7	5.9	6.0	4.9
	5% WB	MCDBR	7.2	6.2	6.1	6.1	5.3	5.4	6.0	5.7	4.5	5.9	6.4	5.7
		MCWBR	6.4	5.2	4.9	4.6	4.3	4.3	5.3	4.3	3.9	5.4	5.5	4.8
Clear-Sky Solar Irradiance	taub	0.447	0.484	0.519	0.527	0.499	0.503	0.473	0.489	0.474	0.454	0.436	0.424	
	taud	1.934	1.870	1.821	1.858	1.996	2.045	2.162	2.097	2.089	2.039	2.030	2.005	
	Ebn at Noon	760	771	775	785	807	799	822	806	805	792	769	763	
	Edh at Noon	160	186	207	206	180	171	152	160	157	154	144	143	
All-Sky Solar Radiation	RadAvg	2.26	2.60	3.44	4.05	4.28	4.09	5.68	4.89	3.94	3.51	2.50	2.34	
	RadStd	0.41	0.61	0.35	0.47	0.58	0.56	0.58	0.51	0.42	0.56	0.36	0.41	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+102	+58

Nomenclature: See separate page