

LINHAI, China

WMO: 586600

Lat: 28.850N

Lon: 121.133E

Elev: 30

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.9	(c) 33.1	(d) 9.2	(e) 8.8	(f) 40.3	(g) 14.2	(h) 11.3	(i) 40.5	(j) 12.8	(k) 42.9	(l) 11.2	(m) 42.5	(n) 1.6	(o) 290	(p) 0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 14.4	(c) 97.2	(d) 80.6	(e) 94.6	(f) 80.2	(g) 92.3	(h) 79.6	(i) 82.3	(j) 93.3	(k) 81.3	(l) 91.3	(m) 80.5	(n) 89.5	(o) 4.7	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.4	152.9	88.1	78.7	148.9	86.6	78.0	145.7	85.7	46.3	93.6	45.2	91.7	44.2	89.6	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.1	9.2	7.6	27.5	101.0	2.2	2.7	26.0	103.0	24.7	104.6	23.5	106.1	21.9	108.0
			23.9	84.4	2.6	1.2	22.1	85.3	20.6	85.9	19.1	86.6	17.2	87.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.9	45.4	48.7	54.7	63.8	72.2	78.2	85.4	84.1	78.0	69.9	59.7	49.4
	DBStd	14.75	6.12	7.31	6.76	6.98	4.77	5.45	3.89	3.29	5.05	5.16	6.52	5.97
	HDD50	391	170	101	28	2	0	0	0	0	0	0	6	84
	HDD65	2176	607	458	324	103	4	0	0	0	0	15	183	482
	CDD50	6195	28	66	175	416	689	847	1098	1057	839	617	296	67
	CDD65	2505	0	3	6	67	228	397	633	592	389	167	23	0
	CDH74	23782	0	21	47	379	1335	3362	7805	6761	3203	791	78	0
	CDH80	9511	0	2	6	90	355	1238	3803	2841	1025	142	9	0
(14) Wind	WSAvg	2.8	2.6	2.8	2.9	2.9	2.6	2.3	3.1	3.3	3.3	2.7	2.6	2.5
(15) Precipitation	PrecAvg	66.5	2.8	2.7	5.2	5.3	6.4	9.4	7.5	11.8	8.1	3.8	2.9	2.0
	PrecMax	88.0	7.5	6.0	12.2	11.1	11.7	16.9	13.1	17.2	15.7	10.3	8.3	5.5
	PrecMin	46.3	1.3	0.7	1.8	2.6	2.9	2.2	3.2	4.6	3.1	0.7	0.6	0.3
	PrecStd	9.0	1.3	1.3	2.6	2.2	3.0	3.9	2.8	3.9	3.4	3.1	1.9	1.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.9	77.3	79.1	87.1	90.5	97.2	101.7	98.8	94.2	86.9	81.0	68.6
		MCWB	62.4	64.7	65.0	69.3	73.7	80.2	79.6	81.2	80.3	73.1	69.5	58.6
	2%	DB	62.5	69.2	73.8	82.2	86.6	93.3	98.6	95.7	91.0	83.5	75.8	64.1
		MCWB	55.2	59.9	61.5	68.5	71.4	79.3	80.0	80.6	78.7	70.7	65.7	57.0
	5%	DB	58.1	64.0	69.3	78.2	83.9	90.0	95.9	93.2	88.4	80.9	72.4	61.4
		MCWB	51.5	57.0	59.2	66.4	70.4	78.2	80.6	79.9	77.1	69.0	64.4	54.9
	10%	DB	54.8	59.3	65.5	74.5	81.0	86.8	93.4	91.0	85.8	78.3	69.3	58.8
		MCWB	49.4	52.9	57.6	64.4	70.1	76.9	80.2	79.4	75.2	67.8	62.4	53.2
	0.4%	WB	64.1	65.8	67.3	74.1	77.8	82.4	83.7	83.5	82.6	76.2	71.9	62.1
		MCDB	67.2	75.0	74.8	82.4	85.4	93.1	95.3	94.1	91.9	82.9	77.6	64.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	56.7	61.6	63.8	71.3	75.8	80.6	82.5	81.9	80.3	74.5	68.8	59.3
		MCDB	60.0	68.1	70.2	78.3	82.5	89.9	94.0	92.2	88.3	80.1	73.6	62.5
	5%	WB	53.2	57.9	61.5	69.0	74.1	79.5	81.6	80.9	78.9	72.5	66.3	56.7
		MCDB	56.9	63.0	67.2	75.2	79.7	87.7	92.2	90.2	85.0	77.7	70.5	60.1
	10%	WB	50.1	54.1	59.0	66.6	72.5	78.4	80.8	80.1	77.6	70.5	63.7	54.1
		MCDB	53.7	58.7	64.4	72.7	77.6	85.3	90.4	88.3	83.4	76.3	67.9	57.6
(35) Mean Daily Temperature Range	5% DB	MDBR	12.4	13.7	14.3	15.8	14.8	12.5	14.4	12.8	12.3	14.1	13.9	13.9
		MCDBR	19.5	22.7	22.7	22.0	20.7	17.6	18.9	17.1	15.4	17.9	19.2	19.2
		MCWBR	11.8	12.6	11.5	10.2	8.3	6.5	5.5	5.5	4.9	6.6	9.2	10.9
	5% WB	MCDBR	15.8	20.2	18.9	18.0	14.9	15.0	16.6	15.0	13.8	13.2	13.6	12.8
		MCWBR	11.2	12.3	11.4	9.7	7.6	6.3	6.1	5.5	5.1	6.8	7.8	8.8
(40) Clear-Sky Solar Irradiance	taub		0.593	0.644	0.689	0.700	0.661	0.657	0.612	0.633	0.615	0.596	0.577	0.562
	taud		1.671	1.604	1.553	1.586	1.704	1.749	1.868	1.801	1.813	1.768	1.763	1.742
	Ebn at Noon		196	200	203	208	217	217	227	220	218	210	200	196
	Edh at Noon		67	77	86	86	76	73	64	69	66	65	60	60
(44) All-Sky Solar Radiation	RadAvg		721	825	1098	1290	1367	1304	1820	1572	1264	1122	795	742
(45) RadStd			127	192	108	150	183	175	183	162	137	174	113	128

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+184	+106

Nomenclature: See separate page