

DACHEN DAO, China

WMO: 586660

Lat: 28.4514N

Lon: 121.9034E

Elev: 276

StdP: 14.55

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.6	36.6	18.4	14.0	38.1	22.0	16.7	39.6	37.0	44.0	34.4	42.4	22.0	0	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.4	86.4	80.8	85.3	80.3	84.2	79.8	81.7	84.8	80.9	84.0	80.3	83.2	9.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.8	161.4	83.9	80.0	157.3	83.1	79.4	154.1	82.5	45.8	85.1	45.0	84.4	44.3	83.5	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.3	31.8	28.8	DB	31.6	88.4	3.0	1.7	29.5	89.6	27.8	90.6	26.1	91.5	23.9	92.8	(4)
(5)			WB	27.2	82.6	3.1	1.0	24.9	83.3	23.1	83.9	21.4	84.5	19.1	85.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.8	45.7	46.4	51.3	59.0	67.6	73.8	80.2	81.4	77.0	69.8	61.0	50.8		
	DBStd	13.31	5.68	5.38	4.99	4.73	3.65	3.54	2.48	2.10	3.58	3.99	5.38	6.00		
	HDD50	395	158	124	44	2	0	0	0	0	0	0	3	64		
	HDD65	2332	600	520	425	184	17	0	0	0	0	8	138	440		
	CDD50	5423	23	24	84	273	545	714	937	975	810	615	334	89		
	CDD65	1887	0	0	0	6	97	264	472	510	360	159	19	0		
	CDH74	13545	0	0	0	0	58	1022	4483	5340	2403	236	3	0		
	CDH80	2427	0	0	0	0	1	33	819	1267	301	6	0	0		
(14) Wind	WSAvg	14.5	16.6	15.8	13.7	12.0	10.9	12.5	14.6	13.7	15.0	16.4	15.7	17.0		
(15) Precipitation	PrecAvg	52.2	2.3	2.9	4.5	5.4	7.0	7.4	3.5	4.8	6.2	3.2	3.4	2.1		
	PrecMax	71.7	5.2	6.3	9.6	9.8	16.1	19.1	15.4	17.0	17.3	12.8	12.1	6.9		
	PrecMin	33.4	0.0	0.1	1.5	1.7	2.0	1.5	0.4	0.2	0.1	0.1	0.1	0.0		
	PrecStd	9.2	1.3	1.6	2.2	2.3	3.0	3.7	3.2	3.8	4.2	2.9	2.8	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.9	63.4	65.6	71.4	77.4	82.6	87.3	88.2	86.2	81.0	73.9	66.4		
		MCWB	60.5	60.1	59.9	67.4	72.0	78.8	81.1	81.4	80.2	76.5	70.5	63.6		
	2%	DB	59.0	59.3	62.6	69.1	75.5	80.9	85.9	86.9	84.4	78.3	71.5	62.8		
		MCWB	56.6	56.6	58.8	66.0	71.8	78.0	80.8	81.0	79.2	74.3	68.9	60.1		
	5%	DB	55.8	56.5	60.5	67.3	74.1	79.7	84.8	85.8	83.1	76.6	69.8	60.5		
		MCWB	53.2	53.8	57.3	64.8	71.0	77.3	80.3	80.6	78.4	72.8	66.9	57.8		
	10%	DB	53.0	53.8	58.4	65.8	72.8	78.5	83.7	84.7	81.7	75.0	68.0	58.7		
		MCWB	50.4	51.3	55.7	63.5	70.1	76.6	79.9	80.0	77.6	70.8	64.8	55.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.6	61.4	62.2	69.6	74.9	79.6	82.6	83.1	81.1	77.8	71.8	64.8		
		MCDB	62.4	62.2	63.8	70.4	76.0	81.5	85.4	86.2	84.4	79.5	72.8	65.6		
	2%	WB	56.9	57.1	60.0	67.4	73.3	78.5	81.6	81.9	80.1	75.8	69.7	61.0		
		MCDB	58.5	59.0	61.6	68.2	74.5	79.9	84.4	85.2	83.1	77.5	71.1	62.1		
	5%	WB	53.7	54.4	57.9	65.7	72.1	77.8	80.9	81.2	79.2	73.8	67.7	58.5		
		MCDB	55.4	56.2	59.6	66.7	73.4	79.1	83.6	84.4	82.0	75.9	69.3	60.1		
	10%	WB	50.9	51.7	56.2	64.0	70.8	77.0	80.2	80.6	78.5	71.9	65.7	56.1		
		MCDB	52.5	53.3	58.0	65.4	72.1	78.3	82.8	83.7	81.1	74.3	67.4	58.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.0	6.1	6.6	6.6	6.1	5.0	5.0	5.4	5.2	5.3	5.6	6.3		
		MCDBR	9.7	10.7	9.7	8.3	7.8	5.6	6.3	6.7	6.1	6.5	6.8	8.0		
	5% WB	MCWBR	8.1	8.8	7.5	6.2	5.4	3.5	3.5	3.6	3.7	4.5	5.8	6.7		
		MCWBR	9.0	10.2	8.9	7.2	6.6	5.2	6.0	6.1	5.7	5.9	6.1	7.4		
(40) Clear-Sky Solar Irradiance	taub		0.558	0.604	0.651	0.657	0.616	0.605	0.558	0.571	0.554	0.541	0.541	0.536		
		taud	1.780	1.712	1.649	1.694	1.834	1.909	2.048	2.005	2.010	1.943	1.887	1.837		
	Ebn at Noon		208	212	213	218	228	229	239	235	234	226	212	207		
		Edh at Noon	60	70	79	77	67	62	54	56	54	55	54	55		
(44) All-Sky Solar Radiation	RadAvg		698	797	1086	1274	1372	1371	1939	1729	1403	1183	798	714		
	RadStd		130	193	108	140	188	169	180	158	144	166	111	115		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+0.56	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+131	+83

Nomenclature: See separate page