

DACHEN DAO, China

WMO: 586660

Lat: 28.4514N

Lon: 121.9034E

Elev: 84

StdP: 100.32

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.4	2.6	-7.6	2.0	3.4	-5.5	2.4	4.2	16.5	6.7	15.4	5.8	9.8	0	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.0	30.2	27.1	29.6	26.8	29.0	26.5	27.6	29.3	27.2	28.9	26.8	28.4	4.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	23.1	28.8	26.7	22.5	28.4	26.3	22.0	28.0	88.6	29.5	86.7	29.1	85.2	28.6	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.8	14.2	12.9	-0.2	31.3	1.6	0.9	-1.4	32.0	-2.4	32.6	-3.3	33.1	-4.5	33.8		
			-2.7	28.1	1.7	0.6	-3.9	28.5	-4.9	28.8	-5.9	29.1	-7.2	29.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	7.6	8.0	10.7	15.0	19.8	23.2	26.8	27.5	25.0	21.0	16.1	10.4
	DBStd	7.40	3.15	2.99	2.77	2.63	2.03	1.97	1.38	1.17	1.99	2.22	2.99	3.33
	HDD10.0	219	88	69	24	1	0	0	0	0	0	0	2	36
	HDD18.3	1296	333	289	236	102	9	0	0	0	0	4	77	244
	CDD10.0	3013	13	13	47	152	303	397	521	542	450	342	186	49
	CDD18.3	1048	0	0	0	3	54	147	262	283	200	88	11	0
	CDH23.3	7525	0	0	0	0	32	568	2491	2967	1335	131	2	0
	CDH26.7	1348	0	0	0	0	1	18	455	704	167	3	0	0
Wind	WSAvg	6.5	7.4	7.1	6.1	5.4	4.9	5.6	6.5	6.1	6.7	7.3	7.0	7.6
Precipitation	PrecAvg	1325	58	73	115	137	178	189	88	122	157	81	86	54
	PrecMax	1822	132	159	243	248	408	484	391	433	440	325	308	175
	PrecMin	849	0	2	39	43	50	39	9	4	3	2	2	1
	PrecStd	234	34	40	55	59	75	93	82	96	106	73	71	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.2	17.4	18.7	21.9	25.2	28.1	30.7	31.2	30.1	27.2	23.3	19.1
		MCWB	15.8	15.6	15.5	19.7	22.2	26.0	27.3	27.5	26.8	24.7	21.4	17.5
	2%	DB	15.0	15.2	17.0	20.6	24.2	27.2	30.0	30.5	29.1	25.7	21.9	17.1
		MCWB	13.7	13.7	14.9	18.9	22.1	25.5	27.1	27.2	26.2	23.5	20.5	15.6
	5%	DB	13.2	13.6	15.8	19.6	23.4	26.5	29.3	29.9	28.4	24.8	21.0	15.9
		MCWB	11.8	12.1	14.0	18.2	21.7	25.2	26.8	27.0	25.8	22.7	19.4	14.3
	10%	DB	11.7	12.1	14.7	18.8	22.7	25.8	28.7	29.3	27.6	23.9	20.0	14.8
		MCWB	10.2	10.7	13.1	17.5	21.1	24.8	26.6	26.7	25.4	21.5	18.2	13.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.4	16.3	16.8	20.9	23.8	26.5	28.1	28.4	27.3	25.4	22.1	18.2
		MCDB	16.9	16.8	17.7	21.3	24.4	27.5	29.7	30.1	29.1	26.4	22.7	18.7
	2%	WB	13.8	14.0	15.5	19.7	23.0	25.8	27.6	27.7	26.7	24.3	20.9	16.1
		MCDB	14.7	15.0	16.5	20.1	23.6	26.6	29.1	29.5	28.4	25.3	21.7	16.7
	5%	WB	12.0	12.4	14.4	18.7	22.3	25.5	27.1	27.3	26.2	23.2	19.8	14.7
		MCDB	13.0	13.4	15.3	19.3	23.0	26.2	28.7	29.1	27.8	24.4	20.7	15.6
	10%	WB	10.5	10.9	13.4	17.8	21.5	25.0	26.8	27.0	25.8	22.1	18.7	13.4
		MCDB	11.4	11.8	14.5	18.5	22.3	25.7	28.2	28.7	27.3	23.5	19.7	14.6
Mean Daily Temperature Range	5% DB	MDBR	3.3	3.4	3.7	3.7	3.4	2.8	2.8	3.0	2.9	2.9	3.1	3.5
		MCDBR	5.4	6.0	5.4	4.6	4.3	3.1	3.5	3.7	3.4	3.6	3.8	4.5
		MCWBR	4.5	4.9	4.2	3.5	3.0	1.9	1.9	2.0	2.0	2.5	3.2	3.7
	5% WB	MCDBR	5.0	5.6	5.0	4.0	3.7	2.9	3.3	3.4	3.2	3.3	3.4	4.1
		MCWBR	4.6	5.0	4.2	3.5	3.0	1.9	1.9	2.1	2.0	2.8	3.0	4.0
Clear-Sky Solar Irradiance	taub	0.558	0.604	0.651	0.657	0.616	0.605	0.558	0.571	0.554	0.541	0.541	0.536	
	taud	1.780	1.712	1.649	1.694	1.834	1.909	2.048	2.005	2.010	1.943	1.887	1.837	
	Ebn at Noon	655	667	671	687	718	722	755	742	739	714	668	651	
	Edh at Noon	190	220	248	244	212	196	170	176	170	172	169	172	
All-Sky Solar Radiation	RadAvg	2.20	2.51	3.42	4.01	4.33	4.32	6.11	5.45	4.42	3.73	2.52	2.25	
	RadStd	0.41	0.61	0.34	0.44	0.59	0.53	0.57	0.50	0.45	0.52	0.35	0.36	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page