

SHAOWU, China

WMO: 587250

Lat: 27.333N

Lon: 117.467E

Elev: 719

StdP: 14.32

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 29.3	(c) 32.1	(d) 18.0	(e) 14.0	(f) 45.3	(g) 23.1	(h) 17.9	(i) 43.3	(j) 11.8	(k) 47.1	(l) 9.9	(m) 47.7	(n) 1.5	(o) 200	(p) 0.307

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	96.3	77.2	94.5	77.1	92.5	76.8	80.0	89.5	79.2	88.4	78.6	87.5	4.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.0	149.4	82.9	77.2	145.3	82.3	76.5	141.8	81.9	44.3	89.5	43.5	88.8	42.8	87.5	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.7	(b) 8.0	(c) 7.0	(e) 24.8	(f) 99.2	(g) 2.8	(h) 1.8	(i) 22.7	(j) 100.5	(k) 21.1	(l) 101.5	(m) 19.5	(n) 102.5	(o) 17.4	(p) 103.8		
(a) 9.7	(b) 8.0	(c) 7.0	(e) 23.9	(f) 81.5	(g) 3.0	(h) 1.1	(i) 21.8	(j) 82.3	(k) 20.0	(l) 82.9	(m) 18.3	(n) 83.5	(o) 16.1	(p) 84.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.5	46.8	51.0	56.9	66.3	73.5	78.8	83.5	83.0	78.3	69.9	59.7	49.6
	DBStd	14.03	6.59	7.84	7.24	6.44	4.66	4.27	3.06	3.05	4.94	5.52	6.49	6.35
	HDD50	330	143	76	18	1	0	0	0	0	0	0	7	85
	HDD65	1968	563	396	269	60	3	0	0	0	0	17	181	479
	CDD50	6362	45	103	231	491	730	865	1038	1022	850	617	298	72
	CDD65	2525	0	3	17	101	267	415	573	557	400	169	22	1
	CDH74	22976	2	31	130	631	1756	3487	6424	5807	3494	1104	108	2
CDH80	9424	0	3	18	165	584	1338	3029	2560	1427	288	12	0	
Wind	WSAvg	2.4	2.5	2.6	2.5	2.5	2.4	2.2	2.5	2.6	2.5	2.3	2.2	2.5
Precipitation	PrecAvg	70.6	2.6	4.5	7.4	10.2	12.1	13.2	5.5	4.8	3.3	2.6	2.4	1.7
	PrecMax	94.6	6.8	10.6	13.5	18.9	24.0	25.0	14.4	13.9	7.1	6.3	7.7	5.6
	PrecMin	48.5	0.2	0.3	1.5	4.0	4.4	5.6	0.2	0.2	0.2	0.1	0.1	0.0
	PrecStd	11.9	1.9	2.2	3.1	3.7	4.5	5.0	3.4	2.9	2.0	2.0	2.0	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.5	78.2	82.4	88.6	92.6	95.6	99.3	98.5	95.9	90.6	81.7	70.6
		MCWB	60.0	65.0	66.7	70.9	72.7	78.3	77.2	77.2	76.7	73.2	67.5	61.1
	2%	DB	65.3	72.7	77.8	84.7	89.3	92.9	96.8	96.1	93.0	86.4	77.1	66.0
		MCWB	55.8	61.2	63.5	69.2	71.6	76.6	77.1	77.3	75.7	71.0	64.5	57.7
	5%	DB	61.3	67.7	73.1	81.1	86.3	90.4	94.9	93.8	90.8	83.1	73.5	62.7
		MCWB	54.2	58.3	61.3	67.5	71.0	76.1	77.2	77.4	75.2	68.5	62.7	54.9
	10%	DB	57.4	62.9	68.4	77.3	83.2	87.8	92.8	91.4	88.1	80.3	70.1	59.8
		MCWB	51.5	56.0	60.0	66.4	70.9	75.8	77.3	77.3	74.4	66.8	61.5	53.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.1	66.4	69.9	74.3	78.1	80.4	81.0	81.0	79.8	76.2	70.5	64.3
		MCDB	67.4	75.0	79.2	82.3	85.8	89.3	90.4	90.4	90.1	84.3	76.9	68.1
	2%	WB	58.4	62.9	67.1	72.5	76.3	79.2	80.0	79.9	78.2	74.1	68.2	60.6
		MCDB	63.5	70.2	74.1	80.2	83.3	87.8	89.4	89.5	87.3	80.8	73.0	64.2
	5%	WB	55.4	60.2	64.6	70.9	75.0	78.3	79.2	79.1	77.3	72.6	66.1	57.7
		MCDB	59.9	66.0	69.6	77.7	81.3	86.3	88.5	88.4	85.6	78.7	70.1	60.7
	10%	WB	52.2	57.2	61.8	69.2	73.6	77.5	78.6	78.4	76.3	70.9	63.8	54.7
		MCDB	56.0	62.3	66.7	74.2	79.0	84.4	87.6	87.1	83.9	77.1	68.0	58.4
Mean Daily Temperature Range	5% DB	MDBR	14.2	14.6	14.9	15.6	15.1	13.5	16.6	15.8	16.3	18.0	17.2	17.0
		MCDBR	22.5	24.0	24.4	23.5	22.7	19.5	21.2	20.5	20.1	21.9	22.9	23.0
		MCWBR	12.7	12.2	10.8	9.0	7.3	5.4	4.8	4.8	5.2	7.1	10.2	12.6
	5% WB	MCDBR	17.4	19.8	18.4	17.2	14.6	15.5	17.3	17.1	17.0	15.6	14.9	13.8
		MCWBR	10.6	11.0	10.0	8.1	6.0	5.5	5.2	5.1	5.1	6.0	7.6	9.0
Clear-Sky Solar Irradiance	taub	0.670	0.722	0.803	0.781	0.686	0.650	0.606	0.660	0.661	0.674	0.621	0.605	
	taud	1.537	1.482	1.391	1.468	1.670	1.753	1.867	1.725	1.699	1.608	1.667	1.657	
	Ebn at Noon	180	185	181	192	213	219	228	215	209	193	191	188	
	Edh at Noon	78	89	102	97	79	73	65	74	74	77	68	66	
All-Sky Solar Radiation	RadAvg	696	784	927	1082	1207	1233	1710	1509	1315	1158	861	790	
	RadStd	154	187	133	164	198	167	158	135	115	200	143	160	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.81	N/A	N/A	N/A	N/A	+164	+104
Regional (9 neighbors)	+0.54	N/A	N/A	+0.90	N/A	N/A	N/A	N/A	+202	+148

Nomenclature: See separate page