

WUYISHAN, China

WMO: 587300

Lat: 27.7559N

Lon: 118.0233E

Elev: 221

StdP: 98.70

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.4	(c) 1.0	(d) -9.0	(e) 1.8	(f) 7.4	(g) -6.4	(h) 2.3	(i) 6.7	(j) 5.0	(k) 9.0	(l) 4.3	(m) 9.9	(n) 1.0	(o) 0	(p) 0.299

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	35.5	25.2	34.4	25.0	33.4	24.8	26.4	31.8	26.0	31.3	25.7	30.7	2.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	20.9	28.2	24.8	20.4	27.9	24.5	20.0	27.7	84.1	31.8	82.4	31.3	80.8	30.9	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
4.4	3.5	3.1		-3.6	37.0	2.6	1.2	-5.5	37.9	-7.0	38.5	-8.5	39.2	-10.4	40.0	
			DB	-4.4	27.3	2.3	0.4	-6.1	27.6	-7.4	27.9	-8.7	28.1	-10.4	28.4	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	8.7	10.7	13.9	19.0	23.0	25.8	28.6	28.4	25.9	21.5	15.8	10.4
	DBStd	7.58	3.46	4.17	3.76	3.41	2.40	2.36	1.75	1.69	2.69	2.94	3.43	3.38
	HDD10.0	151	66	38	8	0	0	0	0	0	0	0	3	36
	HDD18.3	1034	297	216	146	33	1	0	0	0	0	7	89	247
	CDD10.0	3562	27	58	129	269	402	473	577	570	476	355	177	48
	CDD18.3	1404	0	2	8	52	144	223	318	312	226	104	14	1
	CDH23.3	12650	1	11	49	293	893	1827	3565	3318	1995	639	59	1
	CDH26.7	4985	0	1	5	65	272	649	1626	1422	780	159	6	0
Wind	WSAvg	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.4	1.4	1.4	1.3	1.2	1.2
Precipitation	PrecAvg	1977	84	106	201	233	278	410	168	178	105	58	92	64
	PrecMax	2790	245	201	405	434	511	1050	438	357	275	220	238	212
	PrecMin	1341	8	17	76	107	121	97	22	73	40	10	11	6
	PrecStd	403	49	47	83	80	111	198	100	72	52	50	66	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.9	25.0	27.1	30.6	33.3	35.0	37.0	36.5	35.4	32.3	27.6	21.7
		MCWB	14.9	17.5	19.0	21.2	22.3	25.2	25.2	25.3	24.6	22.5	19.3	15.9
	2%	DB	18.2	21.9	24.6	28.6	31.3	33.4	35.7	35.3	33.8	30.0	25.1	19.0
		MCWB	12.9	16.0	17.2	20.2	21.6	24.6	25.4	25.2	24.2	21.4	17.8	13.4
	5%	DB	16.1	19.2	22.2	26.7	29.8	32.0	34.7	34.1	32.5	28.4	23.2	17.3
		MCWB	11.9	14.3	15.8	19.1	21.4	24.2	25.3	25.2	24.0	20.3	16.8	12.8
	10%	DB	14.2	16.9	19.7	24.8	28.0	30.5	33.5	32.8	31.1	26.9	21.4	15.8
		MCWB	10.8	13.0	15.1	18.7	21.1	24.2	25.2	25.0	23.4	19.3	16.2	11.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.2	18.7	20.7	23.0	25.3	26.6	27.1	26.9	26.2	24.2	21.2	17.5
		MCDB	19.0	22.9	25.6	27.3	29.5	31.5	32.7	32.4	32.1	29.2	24.5	19.8
	2%	WB	14.4	16.9	19.0	22.1	24.4	26.0	26.5	26.3	25.5	23.2	20.0	15.7
		MCDB	17.3	20.8	22.3	26.3	28.0	30.6	32.0	31.7	30.9	27.1	22.6	17.7
	5%	WB	12.9	15.3	17.6	21.3	23.7	25.5	26.1	25.9	25.0	22.3	18.9	14.3
		MCDB	15.3	18.4	20.4	24.6	26.6	29.7	31.4	31.3	29.8	26.1	21.2	16.2
	10%	WB	11.4	13.8	16.3	20.3	22.9	25.1	25.7	25.6	24.4	21.4	17.6	12.7
		MCDB	13.4	16.4	18.7	22.9	25.3	28.9	30.8	30.6	28.9	25.2	20.2	14.8
Mean Daily Temperature Range	5% DB	MDBR	7.5	7.6	7.8	8.2	8.0	6.9	8.7	8.3	8.7	9.3	8.9	8.9
		MCDBR	11.4	11.9	12.7	12.2	12.1	10.3	11.1	10.7	10.5	11.3	11.9	11.5
		MCWBR	6.2	6.1	5.6	4.8	4.0	2.9	2.6	2.5	2.8	3.7	5.1	6.2
	5% WB	MCDBR	8.4	9.8	9.3	8.7	7.2	7.9	9.3	9.0	9.0	7.9	7.1	7.0
		MCWBR	5.0	5.5	4.9	4.0	3.0	2.7	2.8	2.6	2.8	3.0	3.7	4.5
Clear-Sky Solar Irradiance	taub		0.684	0.736	0.814	0.794	0.705	0.676	0.627	0.682	0.679	0.687	0.634	0.617
	taud		1.507	1.450	1.368	1.441	1.627	1.693	1.812	1.678	1.657	1.577	1.635	1.626
	Ebn at Noon		551	569	561	597	657	672	705	662	644	596	587	579
	Edh at Noon		253	288	330	314	261	243	215	245	243	249	220	215
All-Sky Solar Radiation	RadAvg		2.21	2.51	3.04	3.55	3.94	3.93	5.47	4.84	4.20	3.68	2.70	2.48
	RadStd		0.47	0.61	0.40	0.51	0.62	0.55	0.52	0.44	0.35	0.60	0.43	0.49

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.29	N/A	N/A	+0.53	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.30	N/A	N/A	+0.44	N/A	N/A	N/A	+110	+67

Nomenclature: See separate page