

PUCHENG, China

WMO: 587310

Lat: 27.9232N

Lon: 118.5418E

Elev: 275

StdP: 98.06

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.8	-0.3	-8.9	1.8	6.6	-6.2	2.3	5.7	8.0	6.4	7.2	7.2	0.8	20	0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	35.3	25.2	34.2	25.1	33.2	24.9	26.6	31.7	26.1	31.3	25.7	30.6	2.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.4	21.3	27.9	25.0	20.7	27.7	24.5	20.2	27.5	85.0	31.8	83.0	31.3	81.3	30.9	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.6	5.6	4.7	DB	-4.2	37.1	1.3	1.3	-5.2	38.0	-5.9	38.8	-6.7	39.5	-7.7	40.4	
			WB	-4.6	27.5	1.5	0.8	-5.7	28.0	-6.6	28.4	-7.4	28.9	-8.5	29.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	7.4	9.7	13.2	18.5	22.5	25.3	28.3	28.0	25.1	20.5	14.8	9.2
	DBStd	7.91	3.72	4.48	4.06	3.63	2.53	2.47	1.75	1.84	2.93	3.07	3.65	3.52
	HDD10.0	234	99	57	15	1	0	0	0	0	0	6	57	
	HDD18.3	1206	339	244	167	41	2	0	0	1	13	116	284	
	CDD10.0	3365	18	47	113	256	388	459	567	452	326	150	32	
	CDD18.3	1294	0	1	7	47	132	209	308	298	202	81	10	0
	CDH23.3	11488	1	11	58	299	849	1661	3378	3026	1656	498	51	1
CDH26.7	4598	0	1	7	66	259	592	1552	1338	656	123	6	0	
Wind	WSAvg	1.6	1.7	1.7	1.7	1.7	1.6	1.7	1.7	1.6	1.6	1.5	1.7	
Precipitation	PrecAvg	1687	64	104	170	226	283	345	122	108	98	62	55	42
	PrecMax	2392	152	186	325	468	612	581	326	235	254	122	141	113
	PrecMin	1107	1	6	53	73	120	149	17	19	6	0	2	1
	PrecStd	300	41	47	73	95	134	98	77	52	54	41	42	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.1	25.1	27.3	30.7	32.9	34.3	37.0	36.8	35.4	31.8	27.5	21.2
		MCWB	15.1	17.5	18.8	20.8	21.9	25.0	25.2	25.4	24.5	22.8	19.4	15.3
	2%	DB	18.0	22.1	25.0	28.5	31.2	32.9	35.4	35.3	33.6	29.7	24.8	18.6
		MCWB	12.8	15.8	17.2	19.8	21.6	24.5	25.3	25.3	24.4	21.6	17.9	13.1
	5%	DB	15.7	19.3	22.3	26.8	29.6	31.6	34.4	34.1	32.2	27.8	22.7	16.7
		MCWB	11.2	14.0	16.0	19.1	21.1	24.2	25.3	25.3	24.1	20.0	16.5	12.4
	10%	DB	13.4	16.6	19.7	24.9	27.9	30.2	33.3	32.8	30.6	26.1	20.7	14.8
		MCWB	9.9	12.5	14.6	18.3	21.0	24.0	25.2	25.2	23.6	19.1	15.9	11.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.4	18.7	20.4	22.9	25.2	26.6	27.2	27.2	26.3	24.2	21.1	17.1
		MCDB	19.2	23.0	25.7	27.7	29.1	31.1	32.0	32.6	31.9	28.8	25.2	19.3
	2%	WB	14.2	16.6	18.9	21.9	24.4	25.9	26.6	26.5	25.6	23.0	19.6	15.1
		MCDB	17.3	20.8	22.8	26.2	27.8	30.3	31.6	32.0	30.6	27.3	22.6	17.5
	5%	WB	12.2	15.0	17.4	20.9	23.5	25.4	26.1	26.0	25.1	22.1	18.4	13.6
		MCDB	14.8	18.5	20.3	24.2	26.4	29.4	31.3	31.4	29.5	25.5	20.7	15.4
	10%	WB	10.5	13.3	15.9	20.0	22.7	25.0	25.7	25.6	24.5	21.1	17.1	12.0
		MCDB	12.4	16.0	18.5	22.7	25.3	28.5	30.8	30.6	28.6	24.5	19.8	14.0
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.2	8.6	8.8	8.4	7.2	9.0	9.0	9.2	10.0	9.6	9.2
		MCDBR	12.9	13.3	13.6	12.8	12.6	10.2	11.4	11.5	11.3	12.5	13.1	13.0
		MCWBR	7.2	6.9	6.0	4.8	4.2	3.1	2.8	2.8	3.0	4.1	5.7	6.9
	5% WB	MCDBR	10.1	11.0	10.0	9.0	7.6	8.0	9.6	9.8	9.6	8.9	8.3	8.3
		MCWBR	6.2	6.2	5.4	4.2	3.4	3.0	3.0	3.0	3.1	3.4	4.2	5.1
Clear-Sky Solar Irradiance	taub	0.605	0.654	0.728	0.714	0.638	0.620	0.580	0.619	0.615	0.611	0.565	0.549	
	taud	1.645	1.586	1.491	1.565	1.758	1.819	1.933	1.821	1.795	1.725	1.777	1.761	
	Ebn at Noon	614	629	617	648	702	711	738	707	691	655	646	639	
	Edh at Noon	219	251	291	277	229	214	191	212	212	214	190	187	
All-Sky Solar Radiation	RadAvg	2.25	2.56	3.13	3.65	4.01	3.95	5.50	4.87	4.20	3.69	2.69	2.49	
	RadStd	0.46	0.62	0.39	0.51	0.62	0.56	0.54	0.44	0.34	0.58	0.41	0.47	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.45	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.27	N/A	N/A	+0.46	N/A	N/A	N/A	N/A	+97	+56

Nomenclature: See separate page