

RUIAN, China

WMO: 587520

Lat: 27.7832N

Lon: 120.6489E

Elev: 125

StdP: 14.63

Time Zone: 8.00 (E08)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.4	37.4	14.4	11.5	42.4	19.9	15.0	43.5	13.5	44.9	12.1	45.9	5.4	290	0.337

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	93.6	80.9	91.6	80.5	89.9	79.9	82.7	89.7	81.8	88.5	81.1	87.5	5.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	161.4	86.3	80.1	157.0	85.7	79.3	153.0	85.3	46.8	90.3	45.9	88.8	45.0	87.6	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.5	12.1	10.5	DB	31.6	98.1	3.1	1.8	29.4	99.4	27.5	100.4	25.8	101.4	23.5	102.7
			WB	26.9	84.3	3.2	1.2	24.7	85.1	22.8	85.8	21.0	86.5	18.7	87.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.7	48.1	49.5	54.9	63.4	71.3	77.6	84.4	84.1	79.3	71.4	62.5	52.8	(6)
	DBStd	13.69	6.09	6.32	5.90	5.53	4.53	4.90	3.13	2.52	4.02	4.51	6.09	6.21	(7)
	HDD50	254	108	81	20	1	0	0	0	0	0	0	2	42	(8)
	HDD65	1874	523	435	315	92	6	0	0	0	0	6	117	380	(9)
	CDD50	6347	50	66	173	404	660	828	1065	1056	878	662	376	129	(10)
	CDD65	2491	0	0	3	45	200	378	600	591	428	203	41	2	(11)
	CDH74	23334	0	0	6	106	776	3040	7453	7199	3884	807	62	1	(12)
	CDH80	8505	0	0	0	12	129	917	3260	2994	1095	96	2	0	(13)
(14) Wind	WSAvg	5.0	4.8	4.8	4.8	4.6	4.5	4.4	5.5	6.0	5.7	5.5	4.9	5.0	(14)
(15) Precipitation	PrecAvg	66.6	2.7	3.4	5.6	5.6	7.3	9.9	6.3	9.4	7.8	3.1	3.1	2.4	(15)
	PrecMax	88.9	6.9	6.4	11.7	9.4	15.0	20.6	15.0	16.2	19.7	13.1	6.4	7.9	(16)
	PrecMin	48.0	0.3	0.6	1.8	1.6	3.0	2.3	1.3	0.7	1.6	0.2	0.2	0.2	(17)
	PrecStd	10.7	1.5	1.5	2.5	2.2	3.1	4.1	3.5	4.4	4.5	3.2	1.8	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.9	69.9	74.4	81.5	87.5	94.0	96.0	95.9	91.6	85.9	79.3	71.5	(19)
		MCWB	59.0	61.8	64.1	71.7	77.7	82.2	81.7	81.0	79.5	75.6	69.9	62.7	(20)
	2%	DB	63.2	65.1	69.9	76.7	83.4	90.1	94.2	92.9	89.0	82.5	75.6	66.9	(21)
		MCWB	57.2	57.7	61.3	67.6	73.5	80.8	81.2	80.1	77.5	72.1	67.2	59.5	(22)
	5%	DB	59.6	61.0	66.7	74.0	80.5	87.4	92.2	91.1	87.3	80.2	72.8	63.9	(23)
		MCWB	54.0	55.1	59.4	66.3	72.3	79.5	80.9	80.0	76.9	70.5	66.4	57.2	(24)
	10%	DB	56.4	57.7	63.3	71.5	78.1	85.1	90.4	89.5	85.5	78.2	70.8	61.1	(25)
		MCWB	51.5	53.3	57.6	65.2	70.9	78.3	80.4	79.5	76.3	69.2	65.1	54.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.2	62.4	66.3	73.6	79.2	83.4	83.7	83.6	81.8	78.9	72.3	66.4	(27)
		MCDB	65.2	68.8	71.8	77.8	86.0	90.8	91.9	90.4	87.3	81.8	75.1	68.3	(28)
	2%	WB	58.3	59.0	63.2	70.9	76.8	81.6	82.7	82.5	80.4	76.8	70.3	61.8	(29)
		MCDB	62.4	63.6	67.7	74.1	81.1	88.2	90.4	88.7	85.9	80.2	73.8	65.3	(30)
	5%	WB	55.1	56.3	60.9	68.8	75.0	80.2	81.9	81.7	79.3	74.0	68.6	58.6	(31)
		MCDB	58.4	60.0	64.6	72.2	78.7	86.0	89.3	87.7	84.4	78.4	71.8	62.2	(32)
	10%	WB	52.4	54.0	58.8	66.4	73.1	79.1	81.2	80.9	78.3	71.4	66.4	56.3	(33)
		MCDB	55.7	56.9	63.0	70.4	76.3	84.2	88.2	86.9	83.4	76.2	69.8	60.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	9.8	11.0	11.2	10.2	9.1	10.1	10.2	10.0	11.0	10.2	11.2	(35)
		MCDBR	14.9	15.9	16.0	14.8	13.8	12.3	13.2	12.7	11.8	12.5	12.6	14.7	(36)
	5% WB	MCWBR	9.1	9.8	9.2	7.9	6.5	5.7	5.1	4.4	4.4	5.6	6.5	8.3	(37)
		MCWBR	12.9	14.0	13.1	13.0	11.5	12.1	11.7	11.2	10.7	9.7	10.1	11.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.578	0.634	0.686	0.692	0.642	0.618	0.567	0.594	0.587	0.581	0.565	0.546	(40)
		taud	1.729	1.653	1.589	1.632	1.775	1.859	2.001	1.917	1.900	1.829	1.824	1.810	(41)
	Ebn at Noon		203	205	205	211	222	226	238	230	226	216	206	205	(42)
		Edh at Noon	64	74	84	82	71	65	56	61	61	61	57	56	(43)
(44) All-Sky Solar Radiation	RadAvg		717	816	1066	1225	1308	1342	1850	1626	1335	1158	803	755	(44)
	RadStd		147	190	105	143	195	164	172	148	134	195	120	132	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		N/A	N/A	N/A	+0.74	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page