

FUDING, China

WMO: 587540

Lat: 27.3351N

Lon: 120.2071E

Elev: 38

StdP: 100.87

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.3	2.7	-7.1	2.1	7.8	-4.5	2.6	7.3	5.4	10.1	4.5	10.8	0.8	20	0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.4	34.9	26.5	33.9	26.2	32.9	25.9	27.6	32.9	27.1	32.1	26.6	31.2	3.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.7	30.3	25.7	21.1	29.7	25.4	20.7	29.3	88.1	33.2	85.8	32.3	83.9	31.4	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.4	4.6	4.0	-1.2	37.2	1.5	1.3	-2.2	38.1	-3.1	38.9	-3.9	39.6	-5.0	40.5		
			-2.4	28.5	1.5	0.7	-3.4	28.9	-4.3	29.3	-5.2	29.7	-6.3	30.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	9.8	10.7	13.5	18.2	22.4	25.8	29.1	28.8	26.2	21.9	17.1	12.1
	DBStd	7.36	3.39	3.70	3.50	3.45	2.61	2.80	1.59	1.41	2.41	2.65	3.29	3.33
	HDD10.0	103	46	32	8	0	0	0	0	0	0	0	1	17
	HDD18.3	939	264	215	153	44	2	0	0	0	0	3	61	196
	CDD10.0	3638	40	52	117	246	384	475	592	583	485	369	214	81
	CDD18.3	1432	0	1	4	39	128	225	334	324	235	115	24	1
	CDH23.3	13453	1	6	23	184	711	1982	4041	3751	2104	581	68	2
	CDH26.7	5066	0	0	2	33	167	699	1806	1559	688	106	6	0
Wind	WSAvg	1.5	1.3	1.4	1.4	1.4	1.4	1.5	1.9	1.8	1.7	1.6	1.3	1.3
Precipitation	PrecAvg	1677	50	77	129	159	212	229	131	264	244	87	59	36
	PrecMax	2484	140	154	255	395	410	383	408	757	661	509	247	91
	PrecMin	1046	0	2	33	50	77	85	0	73	0	0	0	1
	PrecStd	341	39	41	61	76	86	77	89	164	170	99	55	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.5	24.3	26.1	29.6	32.1	35.0	36.8	35.9	34.3	31.2	27.6	23.0
		MCWB	15.9	17.5	18.6	22.3	24.5	26.8	26.8	26.5	25.8	23.3	20.7	17.5
	2%	DB	18.8	20.8	23.1	27.4	30.1	33.4	35.2	34.5	32.7	29.2	25.3	20.3
		MCWB	14.5	15.6	17.1	20.8	23.2	26.5	26.7	26.3	25.0	22.0	19.4	15.6
	5%	DB	16.6	18.3	21.0	25.5	28.5	32.0	34.2	33.5	31.7	27.7	23.6	18.5
		MCWB	12.9	14.2	15.9	19.8	22.3	26.1	26.4	26.0	24.6	20.9	18.6	14.6
	10%	DB	14.7	15.9	18.8	23.6	27.1	30.5	33.1	32.6	30.4	26.4	22.1	17.0
		MCWB	11.5	12.7	14.6	18.7	21.6	25.4	26.2	25.8	23.9	20.3	18.0	13.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.2	18.5	19.8	23.4	25.9	28.0	28.2	28.1	27.4	25.2	22.5	18.8
		MCDB	20.1	22.9	24.0	27.9	30.7	33.1	34.0	33.9	32.5	28.2	25.7	21.0
	2%	WB	15.2	16.5	18.2	22.1	24.9	27.2	27.6	27.3	26.4	24.2	21.0	17.2
		MCDB	17.9	20.0	21.8	25.9	28.5	31.9	33.1	32.5	30.4	27.2	23.6	19.3
	5%	WB	13.6	14.9	16.8	20.9	23.9	26.5	27.1	26.8	25.8	23.1	20.0	15.7
		MCDB	16.1	17.7	20.0	24.1	26.8	30.8	32.4	31.5	29.3	26.2	22.4	17.7
	10%	WB	12.2	13.2	15.5	19.8	23.0	25.9	26.7	26.4	25.2	22.0	18.8	14.3
		MCDB	14.1	15.6	18.1	22.7	25.6	29.7	31.5	30.7	28.6	24.9	21.1	16.2
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.1	7.6	7.9	7.3	6.5	7.4	7.1	7.1	7.7	7.4	7.8
		MCDBR	10.7	11.4	11.6	10.8	9.9	8.5	9.4	8.9	8.5	9.5	9.6	10.1
		MCWBR	6.2	6.5	6.0	5.0	4.2	3.1	2.9	2.8	2.6	3.3	4.2	5.4
	5% WB	MCDBR	8.7	10.4	9.7	9.0	7.7	8.0	8.3	7.7	7.2	6.7	6.7	7.2
		MCWBR	5.6	6.5	5.8	4.7	3.9	3.3	3.0	2.9	2.6	3.0	3.8	4.8
Clear-Sky Solar Irradiance	taub	0.582	0.635	0.697	0.699	0.636	0.608	0.561	0.594	0.585	0.587	0.565	0.546	
	taud	1.725	1.657	1.572	1.622	1.791	1.881	2.010	1.912	1.904	1.820	1.826	1.813	
	Ebn at Noon	641	648	641	659	704	720	753	726	717	679	653	650	
	Edh at Noon	203	234	269	262	222	202	177	194	190	196	182	179	
All-Sky Solar Radiation	RadAvg	2.26	2.57	3.29	3.76	4.04	4.23	5.77	5.11	4.23	3.65	2.54	2.40	
	RadStd	0.48	0.59	0.34	0.45	0.64	0.50	0.55	0.45	0.42	0.64	0.39	0.42	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.42	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page