

NANPING, China

WMO: 588340

Lat: 26.6484N

Lon: 118.1726E

Elev: 502

StdP: 14.43

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.7	38.1	20.9	16.0	48.3	25.8	20.2	46.5	9.7	50.6	8.8	49.3	2.5	20	0.302

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	97.5	77.5	95.8	77.5	94.0	77.3	80.5	90.9	79.8	89.5	79.1	88.2	4.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.3	149.6	83.0	77.6	146.0	82.8	76.9	143.0	82.6	44.6	91.0	43.9	89.7	43.1	88.3	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
9.7	7.8	7.0	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			31.5	100.0	2.7	1.9	29.5	101.4	27.9	102.5	26.4	103.6	24.4	105.0		
			29.6	81.8	3.2	1.2	27.3	82.7	25.5	83.4	23.7	84.0	21.4	84.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.4	51.2	54.7	60.2	68.8	75.6	80.6	85.4	84.8	80.5	72.8	63.5	53.9
	DBStd	13.23	6.70	8.01	7.21	6.67	5.05	4.56	3.20	3.25	4.87	5.24	6.26	6.31
	HDD50	145	67	38	6	0	0	0	0	0	0	0	2	32
	HDD65	1411	430	300	185	39	2	0	0	0	0	6	100	349
	CDD50	7222	103	169	323	564	792	917	1096	1079	915	707	405	152
	CDD65	3013	1	11	37	152	329	467	631	614	465	248	53	5
	CDH74	29644	5	66	220	920	2390	4506	7861	7307	4636	1538	184	11
	CDH80	12649	0	10	42	268	812	1837	3921	3454	1889	391	25	0
(14) Wind	WSAvg	3.0	2.9	2.9	2.9	2.8	2.9	3.0	3.4	3.3	3.1	2.9	2.8	2.8
(15) Precipitation	PrecAvg	63.9	2.3	3.7	7.1	8.5	11.0	10.6	5.2	4.8	4.2	2.5	1.9	1.5
	PrecMax	80.4	7.8	8.7	12.4	17.7	21.5	25.7	15.5	9.1	11.2	7.8	5.6	5.8
	PrecMin	36.3	0.0	0.2	1.3	3.1	4.4	2.7	0.5	1.3	1.2	0.0	0.0	0.0
	PrecStd	10.2	2.0	1.8	3.4	3.6	4.6	5.1	3.7	2.1	2.0	2.0	1.5	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.7	81.2	84.7	90.6	94.4	97.0	100.3	99.6	96.8	91.5	83.3	75.1
		MCWB	61.8	65.6	68.9	72.0	75.0	78.5	77.2	77.0	77.2	74.6	69.7	65.4
	2%	DB	68.3	75.3	79.8	86.6	90.5	94.4	97.8	97.2	94.3	87.2	78.8	69.0
		MCWB	58.8	63.4	65.5	70.7	73.3	77.6	77.4	77.6	76.6	72.3	66.6	60.8
	5%	DB	64.7	70.8	75.5	83.1	87.6	92.2	96.1	95.3	92.2	84.1	75.5	65.8
		MCWB	57.0	61.2	64.1	69.4	72.2	77.0	77.5	77.8	76.1	70.5	65.0	58.8
	10%	DB	61.3	66.4	71.3	79.6	84.8	89.6	94.2	93.2	89.5	81.5	72.7	62.8
		MCWB	54.9	58.8	62.4	67.9	72.0	76.4	77.6	77.6	75.2	68.6	63.8	56.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.9	67.5	71.0	74.7	78.7	80.9	81.7	81.3	80.4	76.9	72.5	66.4
		MCDB	70.0	77.0	81.7	83.1	86.5	90.5	92.9	91.9	91.9	84.9	79.5	71.5
	2%	WB	60.8	64.8	68.5	73.2	77.3	79.7	80.6	80.3	79.1	75.2	70.1	63.3
		MCDB	66.5	72.2	76.2	81.9	84.6	88.9	91.2	90.2	88.5	81.6	75.0	67.6
	5%	WB	58.2	62.6	66.5	71.9	76.1	78.9	79.8	79.6	78.1	73.8	68.1	60.7
		MCDB	63.6	69.1	72.4	79.8	82.6	87.4	89.6	89.1	86.6	80.2	73.0	64.0
	10%	WB	55.9	60.0	64.2	70.5	74.8	78.2	79.0	78.9	77.1	72.2	66.1	58.1
		MCDB	60.1	65.5	69.9	76.8	80.7	85.8	88.2	88.0	85.0	79.1	70.5	61.7
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	12.5	13.6	14.3	13.9	13.2	15.8	15.0	14.1	14.3	13.4	13.1
		MCDBR	17.4	20.2	21.1	20.4	19.8	18.2	19.2	18.5	17.6	17.4	17.5	17.0
		MCWBR	8.7	9.4	8.9	7.1	6.0	4.4	4.1	4.1	3.9	5.1	6.8	8.4
	5% WB	MCDBR	14.4	17.7	17.5	16.5	14.1	15.3	16.3	16.1	15.5	13.4	13.0	11.9
		MCWBR	7.7	9.2	8.8	6.8	5.4	4.7	4.7	4.5	4.1	4.8	6.1	6.6
(40) Clear-Sky Solar Irradiance	taub		0.589	0.639	0.718	0.704	0.613	0.578	0.544	0.590	0.588	0.587	0.549	0.536
	taud		1.705	1.645	1.536	1.608	1.840	1.945	2.046	1.903	1.883	1.808	1.851	1.827
	Ebn at Noon		203	206	199	208	229	235	243	232	227	216	213	211
	Edh at Noon		66	75	89	85	67	60	54	62	62	63	57	56
(44) All-Sky Solar Radiation	RadAvg		746	844	978	1128	1251	1316	1747	1569	1347	1177	871	810
	RadStd		154	181	150	162	198	159	168	128	120	206	128	148

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) +0.56	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (11 neighbors)	+0.49	N/A	N/A	+0.77	N/A	N/A	N/A	N/A	+169	+130

Nomenclature: See separate page