

YONG'AN, China

WMO: 589210

Lat: 25.9731N

Lon: 117.3610E

Elev: 669

StdP: 14.34

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.5	37.3	23.4	18.1	47.5	28.0	22.4	44.9	12.7	50.4	11.1	51.0	2.9	200	0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	96.8	77.5	95.1	77.3	93.3	77.0	79.9	90.7	79.1	89.5	78.5	88.4	5.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.5	146.6	82.8	76.8	143.0	82.3	76.2	140.0	82.1	44.1	91.1	43.3	89.9	42.6	88.7	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
11.7	9.8	8.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			30.2	99.7	2.5	1.6	28.4	100.8	27.0	101.8	25.6	102.6	23.8	103.8
			28.8	81.2	3.0	1.1	26.6	82.0	24.9	82.6	23.2	83.2	21.0	84.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.4	51.6	55.5	61.0	69.8	75.9	80.7	84.5	83.7	79.7	72.3	63.2	53.6
	DBStd	12.93	7.03	8.70	7.73	6.72	4.92	4.22	2.97	3.11	4.63	5.26	6.40	6.38
	HDD50	142	64	36	6	0	0	0	0	0	0	0	2	34
	HDD65	1382	417	284	174	33	2	0	0	0	0	7	106	359
	CDD50	7214	115	190	347	595	803	922	1070	1046	891	691	398	146
	CDD65	2978	3	19	50	178	339	472	605	581	441	233	52	5
	CDH74	28132	15	133	333	1182	2579	4611	7133	6372	4055	1478	224	17
	CDH80	11542	1	24	67	358	890	1876	3415	2860	1622	391	37	1
Wind	WSAvg	3.7	3.4	3.6	3.7	3.8	3.7	4.0	4.3	4.0	3.8	3.6	3.5	3.3
Precipitation	PrecAvg	61.7	2.3	3.7	7.3	7.7	10.2	10.8	3.7	5.4	4.6	2.7	1.9	1.5
	PrecMax	92.0	7.8	9.5	14.8	14.5	22.0	23.7	9.5	12.1	13.5	6.7	6.4	5.2
	PrecMin	41.1	0.0	0.1	1.7	3.0	2.0	1.4	0.3	0.9	0.3	0.0	0.0	0.0
	PrecStd	9.1	2.2	2.0	4.1	3.1	4.1	5.4	2.3	2.7	2.6	2.1	1.5	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.9	83.4	85.5	90.6	93.9	96.4	99.3	98.6	96.2	91.1	84.3	76.4
		MCWB	63.0	66.6	69.0	71.4	74.3	78.1	77.3	77.3	77.5	74.2	69.4	66.5
	2%	DB	71.1	78.1	81.6	87.4	90.8	94.0	97.1	96.4	93.7	87.2	79.7	70.1
		MCWB	61.0	64.5	66.8	70.9	73.4	77.1	77.3	77.6	76.5	72.4	67.6	61.7
	5%	DB	66.6	73.7	77.8	84.3	88.1	91.9	95.4	94.5	91.3	84.3	76.1	66.4
		MCWB	58.0	62.8	65.3	70.1	72.8	76.6	77.4	77.6	76.0	70.6	65.4	58.7
	10%	DB	62.4	69.0	73.6	81.0	85.2	89.5	93.4	92.2	88.8	81.6	73.1	63.2
		MCWB	56.0	60.6	63.6	68.8	72.6	76.2	77.3	77.5	75.3	68.8	64.0	57.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.7	68.5	71.0	74.7	78.8	80.2	81.0	80.8	79.5	76.5	72.5	67.9
		MCDB	72.4	79.7	82.1	83.6	87.0	89.6	92.5	91.9	90.7	85.2	80.3	72.0
	2%	WB	62.0	66.1	69.0	73.2	77.2	79.1	79.9	79.8	78.3	74.9	70.2	63.9
		MCDB	68.6	75.9	77.8	82.7	85.4	88.3	91.1	90.7	88.5	82.1	76.2	68.9
	5%	WB	59.6	63.9	67.2	72.1	76.0	78.3	79.1	79.0	77.5	73.5	68.4	61.2
		MCDB	65.4	71.4	75.1	80.7	83.2	87.1	89.8	89.6	86.7	80.4	73.3	64.5
	10%	WB	57.1	61.5	65.3	70.9	74.8	77.6	78.3	78.3	76.7	72.2	66.3	58.5
		MCDB	61.5	68.0	71.7	78.4	81.1	85.9	88.5	88.0	85.0	78.8	71.1	61.8
Mean Daily Temperature Range	5% DB	MDBR	13.7	14.0	14.5	15.0	14.4	13.5	16.1	15.4	14.8	15.8	14.9	14.6
		MCDBR	20.9	22.0	22.1	21.0	20.6	18.4	19.9	19.5	18.6	19.0	19.7	19.2
		MCWBR	10.8	9.7	9.1	7.3	6.3	5.0	4.7	4.8	4.7	6.0	8.1	10.1
	5% WB	MCDBR	17.2	19.2	18.2	16.4	14.4	15.2	16.9	16.5	16.1	14.6	15.1	13.5
		MCWBR	9.3	9.3	8.8	6.6	5.6	5.2	5.0	4.9	4.7	5.1	7.1	7.9
Clear-Sky Solar Irradiance	taub	0.639	0.700	0.803	0.786	0.664	0.619	0.588	0.650	0.662	0.656	0.600	0.585	
	taud	1.612	1.541	1.408	1.475	1.727	1.835	1.914	1.749	1.706	1.661	1.737	1.727	
	Ebn at Noon	191	192	182	192	217	226	233	218	210	200	200	198	
	Edh at Noon	73	84	101	97	75	67	62	73	74	74	64	63	
All-Sky Solar Radiation	RadAvg	788	858	955	1103	1215	1298	1715	1545	1356	1201	922	859	
	RadStd	154	174	148	170	195	152	157	137	124	203	130	154	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.67	N/A	N/A	+0.88	N/A	+0.31	N/A	N/A	+247	+185
(47)	Regional (11 neighbors)	+0.58	N/A	N/A	+0.77	N/A	N/A	N/A	N/A	+178	+146

Nomenclature: See separate page