

ZHANG PING, China

WMO: 589260

Lat: 25.2980N

Lon: 117.4137E

Elev: 666

StdP: 14.35

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.8	39.2	23.8	18.4	49.3	29.0	23.6	49.3	11.6	61.1	9.6	58.1	1.7	20	0.288

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	97.1	76.9	95.3	76.9	93.4	76.8	79.8	90.2	79.1	88.9	78.4	87.6	5.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.6	147.2	81.8	77.0	143.9	81.4	76.3	140.8	81.1	44.0	90.6	43.2	89.1	42.6	87.9	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.1	9.1	7.4	30.9	100.4	3.0	1.5	28.8	101.5	27.0	102.4	25.3	103.2	23.1	104.3		
			29.7	81.0	3.4	1.4	27.3	82.0	25.3	82.8	23.5	83.6	21.0	84.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	71.0	55.1	58.5	63.6	71.0	76.6	81.1	84.1	83.7	80.5	73.9	65.7	57.0
	DBStd	11.62	6.66	7.95	6.94	6.08	4.79	3.84	2.91	3.11	4.10	5.04	6.05	6.36
	HDD50	56	25	16	2	0	0	0	0	0	0	0	0	13
	HDD65	975	311	207	111	20	1	0	0	0	0	4	62	259
	CDD50	7712	184	255	424	630	825	933	1058	1045	916	742	471	229
	CDD65	3155	5	26	69	199	361	483	593	580	466	280	83	10
	CDH74	28845	20	162	409	1302	2798	4613	6722	6094	4325	1976	397	27
	CDH80	11784	0	26	80	408	1026	1845	3201	2748	1783	595	71	1
Wind	WSAvg	2.8	2.5	2.8	2.9	3.0	3.0	2.9	3.3	3.1	2.9	2.7	2.4	2.4
Precipitation	PrecAvg	62.7	2.6	3.8	6.3	6.9	8.9	9.8	5.8	8.3	4.6	1.9	1.9	1.9
	PrecMax	95.4	10.6	10.7	15.3	14.2	16.0	19.5	10.5	17.2	10.5	7.6	7.8	6.5
	PrecMin	41.4	0.1	0.2	2.7	1.8	3.0	3.9	1.0	3.1	0.5	0.0	0.0	0.0
	PrecStd	11.7	2.2	2.6	2.8	3.1	3.8	3.6	2.5	3.3	2.2	2.0	2.2	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.0	83.6	86.1	90.9	95.1	97.1	99.5	99.0	96.7	91.4	86.0	77.4
		MCWB	63.4	67.0	69.5	71.8	75.4	77.6	76.6	77.1	76.4	74.1	70.8	65.8
	2%	DB	72.8	78.9	82.2	87.7	91.6	94.4	97.3	96.7	94.0	88.3	81.8	72.8
		MCWB	61.6	64.7	66.7	71.1	73.2	76.9	76.8	77.2	76.3	72.5	67.8	62.9
	5%	DB	69.2	75.0	78.8	84.9	88.9	92.0	95.5	94.6	91.7	85.9	78.5	69.5
		MCWB	59.3	63.0	65.5	70.4	73.2	76.4	76.9	77.3	75.6	70.7	65.9	60.8
	10%	DB	65.7	70.8	75.0	81.6	86.1	89.5	93.2	92.2	89.3	83.3	75.6	66.7
		MCWB	57.3	61.1	64.2	68.8	72.8	76.3	77.2	77.3	75.0	69.6	64.8	59.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.8	68.6	71.6	75.1	79.1	80.6	80.7	80.6	79.7	77.0	72.9	68.9
		MCDB	73.2	80.3	82.0	85.0	88.3	90.6	91.5	92.5	90.1	86.6	82.6	72.8
	2%	WB	63.3	66.4	69.5	73.5	77.3	79.4	79.6	79.5	78.4	75.5	70.9	65.4
		MCDB	69.9	75.3	78.7	82.9	85.9	88.1	90.1	90.5	88.0	83.0	78.0	70.6
	5%	WB	61.3	64.4	67.8	72.3	76.2	78.6	78.9	78.8	77.5	74.3	69.1	63.1
		MCDB	67.3	72.2	75.2	80.9	84.0	86.4	89.1	89.0	86.0	81.1	74.8	67.8
	10%	WB	59.1	62.4	66.1	71.1	75.1	77.8	78.2	78.0	76.7	72.8	67.5	60.8
		MCDB	64.4	69.0	72.9	78.6	81.9	85.0	87.8	87.3	84.4	79.3	72.7	64.8
Mean Daily Temperature Range	5% DB	MDBR	15.4	15.2	15.2	15.3	14.8	14.0	16.9	16.2	16.0	17.4	17.2	16.8
		MCDBR	20.3	22.2	22.2	21.1	21.1	19.2	21.3	20.4	19.5	20.7	21.3	20.0
		MCWBR	9.6	9.4	8.7	7.0	5.9	4.7	4.6	4.4	4.2	5.8	7.9	9.5
	5% WB	MCDBR	16.5	18.7	17.6	17.2	15.5	14.9	17.3	17.2	16.5	15.6	15.1	14.1
		MCWBR	8.2	8.4	7.8	6.5	5.5	5.0	4.8	4.8	4.5	5.0	6.3	7.5
Clear-Sky Solar Irradiance	taub	0.611	0.685	0.799	0.791	0.666	0.614	0.582	0.655	0.669	0.651	0.581	0.565	
	taud	1.672	1.574	1.417	1.472	1.726	1.849	1.928	1.738	1.692	1.676	1.789	1.781	
	Ebn at Noon	200	197	184	191	217	227	234	217	209	202	207	206	
	Edh at Noon	69	82	101	97	75	66	61	74	75	73	61	60	
All-Sky Solar Radiation	RadAvg	858	900	999	1133	1223	1316	1697	1533	1379	1235	972	910	
	RadStd	145	168	148	176	199	160	153	148	127	193	122	149	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.79	N/A	N/A	+0.90	N/A	N/A	N/A	N/A	N/A	N/A
Regional (9 neighbors)	+0.56	N/A	N/A	+0.77	N/A	N/A	N/A	N/A	+176	+158

Nomenclature: See separate page