

JIUXIAN SHAN, China

WMO: 589310

Lat: 25.7104N

Lon: 118.1058E

Elev: 5417

StdP: 12.04

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.7	26.8	-2.1	6.0	35.9	6.8	9.5	35.9	42.9	46.6	38.9	45.5	19.5	40	0.663

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.6	76.2	68.2	74.6	67.7	72.9	67.2	69.7	73.6	68.8	72.6	68.0	71.5	7.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.4	128.1	71.4	67.6	124.6	70.5	67.0	121.7	69.7	37.5	74.0	36.7	72.9	36.0	71.7	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4)	42.0	37.0	33.1	DB	18.0	80.8	4.5	2.9	14.7	82.9	12.1	84.6	9.5	86.3	6.3	88.4
(5)				WB	15.7	72.0	4.1	2.4	12.8	73.7	10.4	75.2	8.1	76.5	5.2	78.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.6	42.2	44.5	49.2	55.6	60.8	64.8	67.5	67.1	62.9	56.8	50.7	43.9
	DBStd	10.53	7.59	8.10	6.91	5.81	4.32	3.37	2.92	2.89	4.35	5.04	6.27	7.32
	HDD50	834	252	181	97	22	1	0	0	0	0	8	65	208
	HDD65	3682	706	574	490	284	140	42	10	12	86	257	428	653
	CDD50	2864	12	27	72	188	335	443	543	531	388	218	87	20
	CDD65	237	0	0	0	1	9	35	88	78	24	2	0	0
	CDH74	207	0	0	1	0	6	24	103	61	11	1	0	0
	CDH80	5	0	0	0	0	0	1	3	1	0	0	0	0
Wind	WSAvg	15.0	13.5	15.0	16.5	15.4	14.4	17.7	16.0	14.4	14.0	14.6	14.3	13.8
Precipitation	PrecAvg	67.7	2.1	3.1	5.4	6.8	9.6	10.2	6.8	9.1	7.4	3.3	2.3	1.6
	PrecMax	93.6	7.3	10.5	11.0	13.3	18.3	20.5	14.3	27.0	17.3	9.2	6.3	4.4
	PrecMin	54.6	0.1	0.4	1.8	3.2	4.3	2.0	2.6	1.3	1.5	0.0	0.2	0.0
	PrecStd	10.3	1.9	2.1	2.9	2.5	3.7	4.4	3.2	4.9	3.9	2.1	1.6	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.3	63.0	66.3	70.8	74.5	76.5	79.3	77.9	75.6	70.9	67.4	61.9
		MCWB	51.9	55.6	58.1	61.8	65.3	68.0	68.5	68.9	67.9	63.1	59.5	54.1
	2%	DB	56.1	58.9	62.3	67.3	71.1	73.9	76.5	75.7	72.8	67.5	63.8	57.8
		MCWB	51.0	53.7	56.0	60.2	63.4	67.4	68.2	68.5	66.9	62.0	57.3	52.5
	5%	DB	53.8	56.4	59.4	64.8	68.6	71.7	74.7	74.0	70.7	65.3	61.0	55.7
		MCWB	49.7	52.9	55.1	59.5	62.5	66.4	67.8	68.0	65.9	60.7	56.1	51.3
	10%	DB	51.6	54.3	57.4	62.4	66.5	69.4	72.9	72.2	68.7	63.4	58.8	53.4
		MCWB	48.5	52.0	54.6	59.0	62.2	65.6	67.4	67.5	65.0	59.9	55.3	49.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.4	58.2	60.5	64.5	68.3	70.0	70.6	70.9	69.3	66.3	62.5	57.4
		MCDB	56.7	59.8	63.4	67.7	72.1	73.4	75.2	74.6	72.8	68.5	65.4	58.8
	2%	WB	52.9	55.7	58.4	62.6	66.4	68.6	69.6	69.7	67.9	63.9	60.2	55.1
		MCDB	54.5	57.2	60.0	65.1	68.8	71.8	73.8	73.7	71.2	65.7	61.9	56.4
	5%	WB	51.1	54.1	57.1	61.3	65.1	67.5	68.8	68.7	66.8	62.5	58.4	52.9
		MCDB	52.7	55.5	58.4	63.2	66.7	70.2	72.6	72.4	69.4	64.0	59.7	54.7
	10%	WB	49.3	52.4	55.5	60.1	63.9	66.5	67.9	67.9	65.8	61.2	56.6	50.7
		MCDB	51.1	53.8	56.5	61.6	65.1	68.5	71.5	71.2	67.8	62.5	57.8	52.5
Mean Daily Temperature Range	5% DB	MDBR	10.1	9.6	9.8	9.3	8.2	7.1	8.6	7.9	8.1	9.0	9.8	10.8
		MCDBR	11.4	11.3	11.7	12.3	11.5	10.9	11.9	11.2	10.6	10.9	11.7	12.0
		MCWBR	7.5	7.1	7.8	8.1	7.9	6.5	6.3	6.4	6.6	7.5	8.5	8.5
	5% WB	MCDBR	9.0	9.1	9.0	9.8	8.5	9.2	10.3	9.9	9.1	8.1	8.7	9.5
		MCWBR	6.7	6.5	6.4	7.0	6.0	5.8	6.1	6.3	6.0	5.8	6.7	7.3
Clear-Sky Solar Irradiance	taub	0.423	0.465	0.533	0.533	0.464	0.441	0.421	0.460	0.458	0.442	0.408	0.397	
	taud	2.043	1.966	1.814	1.877	2.141	2.236	2.289	2.166	2.137	2.100	2.163	2.143	
	Ebn at Noon	257	255	245	249	266	270	275	265	263	259	261	260	
	Edh at Noon	47	55	67	65	49	45	43	48	48	47	42	41	
All-Sky Solar Radiation	RadAvg	820	885	1017	1151	1241	1331	1728	1544	1357	1199	923	868	
	RadStd	148	171	145	171	202	154	161	145	131	193	120	141	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.83	+0.63	+0.68	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	+0.52	N/A	N/A	+0.72	N/A	N/A	N/A	N/A	+178	+146

Nomenclature: See separate page